

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE <b>J</b>	PAGE OF PAGES <b>1   2</b>
2. AMENDMENT/MODIFICATION NO. <b>0001</b>		3. EFFECTIVE DATE <b>20-Jun-2002</b>	4. REQUISITION/PURCHASE REQ. NO. <b>W25PHS-2130-8002</b>		5. PROJECT NO.(If applicable)
6. ISSUED BY CONTRACTING DIVISION WANAMAHER BUILDING 100 PENN SQUARE EAST PHILADELPHIA PA 19107-3390		CODE <b>DACW61</b>	7. ADMINISTERED BY (If other than item 6) US ARMY ENGINEER DISTRICT, PHILADELPHIA POC: SANDI FLETCHER WANAMAHER BUILDING 100 PENN SQUARE EAST PHILADELPHIA PA 19107-3390		CODE <b>E5CTCSGF</b>
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X	9A. AMENDMENT OF SOLICITATION NO. <b>DACW61-02-B-0019</b>
				X	9B. DATED (SEE ITEM 11) <b>7-Jun-2002</b>
					10A. MOD. OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE			
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended.					
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
<b>Pea Patch Island, Bank Stabilization</b>					
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) <b>THIS AMENDMENT DOES NOT EXTEND THE 10 JULY 2002 BID OPENING DATE AT 11:00 AM</b>					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED

14. DESCRIPTION OF AMENDMENT (continued)

a. SPECIAL CONTRACT REQUIREMENTS: Section 00830: Please change the IFB Number on these pages from "DACW61-02-B-0001" to the correct IFB Number "DACW61-02-B-0019."

b. SPECIFICATIONS:

1. Section 02275 STONE MATERIALS, Paragraph 3.6 entitled "PLACEMENT OF RIPRAP": Please insert the following sentence at the end of subparagraph "b.":

***"The ends of the riprap shall be sloped at 2H:1V from the ending station shown on the drawing to existing ground."***

2. Section 04410 STONE WALL, Paragraph 3.2 entitled "WALL CONSTRUCTION" - Please delete this paragraph in its entirety and replace it with the following:

"3.3 WALL CONSTRUCTION

The stone wall is to be constructed three (3) feet wide by four (4) feet high with sloped fill on the shore side and exposed on the inshore side. The south wall is approximately 770 feet long, and the north wall is approximately 515 feet long. The stone wall is to be founded on bedding stone as shown on the drawings and specified in Section 02275 STONE MATERIALS. The wall shall be constructed in accordance with the contract drawings and the shop drawings provided by the stone material supplier. The lengths of stone provided are to be randomly distributed to produce a wall of generally consistent appearance. The shop drawings provided by the stone material supplier show the stone pattern for **86** lineal feet of wall, which is to be repeated throughout the entire length of the new wall. The stone is to be laid out so that all vertical joints are staggered at least 6 inches. The ends of the stone wall will not meet tolerances of the face. ***It will be necessary to make field modifications to the stones on the ends of the wall to ensure they fall within face tolerances.***"

c. CONTRACT DRAWINGS:

1. Drawing No. 61525: Please add the following drawing to the "List of Contract Drawings:"

Drawing No.	Sheet No.	Title
61535	11	Stone Wall Layout

2. Drawing No. 61535, Sheet 11 of 11, entitled "STONE WALL LAYOUT," dated 18 June 2002, shall be added to the contract drawings.

3. Please change all contract drawings to indicate a total of 11 sheets, e.g. Sheet 1 of 11.

d. Please indicate receipt of this amendment on Standard Form 1442(SOLICITATION, OFFER, AND AWARD) as Amendment No.0001. Failure to acknowledge all amendments may be cause for rejection of the bid.