



**US Army Corps
of Engineers**
Philadelphia District

Seepage Weir 3A Modification

**F.E. Walter Dam
Lehigh River, Pennsylvania**

Construction Solicitation and Specifications

23 July 2002

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

CAUTION TO BIDDERS

All information required by the terms of the Solicitation must be furnished. **MISTAKES OR OMISSIONS CAN BE COSTLY.** Important items for you to check are included in but not limited to those listed below. This checklist is furnished only to assist you in submitting a proper bid. Check as you read.

Are you registered in the Central Contractor Database? See DFARS Clause 252.204-7004 "REQUIRED CENTRAL CONTRACTOR REGISTRATION" in Section 00700 of this solicitation.

Have you acknowledged all amendments? Have you submitted your bid on the latest amended bid schedule?

Have you completed the "Representations and Certifications" {Section 00600} portion of the Solicitation? Is your Contractor Establishment Code listed on the Standard Form 1442?

Is your bid properly signed by an officer of your company?

If a bid guarantee is required, is it included with your bid {A late bid guarantee is treated the same as a late bid.} and is it in the proper amount? {Usually 20 percent of the total bid price, including any options or additives.} If your bid guarantee is in the form of a bid bond, is the bond properly signed by both the bidder and surety and are all required seals affixed? A bid guarantee is required when your bid exceeds \$100,000.00.

Is the name in which you submitted the bid the same on your bid as on the bid bond?

If required, have you entered a unit price for each bid item? {The solicitation will specifically state when this is necessary.}

The Government may reject a bid as nonresponsive if it is materially and mathematically unbalanced as to price for any bid item or combination of items. A bid is unbalanced when it is based on prices significantly less than cost for some work and prices which are significantly overstated for other work.

Are decimals in unit prices in the proper places? Are your figures legible?

Are the extensions of your unit prices, and your total bid price correct?

Are all erasures or corrections initialed by the person signing the bid?

Have you restricted your bid by altering the provisions of the solicitation?

If you are a large business and your bid is greater than \$1,000,000.00 have you included your Sub-Contracting Plan in your bid package? {NOTE: AN AWARD WILL NOT BE MADE WITHOUT AN APPROVED SUB-CONTRACTING PLAN. IN ORDER TO BE APPROVED YOUR PLAN MUST DESIGNATE 5% OF THE TOTAL SUB-CONTRACTING DOLLARS TO SMALL DISADVANTAGED BUSINESSES}.

Is the envelope containing your bid properly identified that it is a sealed bid and does it contain the correct solicitation number and bid opening time?

Will your bid arrive on time? See paragraph entitled "Late Submissions, Modifications, and Withdrawals of Bids" in the Instructions to Bidders {Section 00100} of the solicitation.

July 02, 1998

THIS PAGE INTENTIONALLY LEFT BLANK

INVITATION NO. DACW61-02-B-0029

PHILADELPHIA DISTRICT
CORPS OF ENGINEERS

INVITATION FOR BIDS
FOR

SEEPAGE WEIR 3A MODIFICATION

F.E. WALTER DAM
LEHIGH RIVER, PENNSYLVANIA

I. NOTE THE AFFIRMATIVE ACTION REQUIREMENT OF THE EQUAL OPPORTUNITY CLAUSE WHICH MAY APPLY TO THE CONTRACT RESULTING FROM THIS SOLICITATION.

II. BIDDERS ARE REQUIRED TO COMPLETE THE REPRESENTATIONS AND CERTIFICATIONS PORTION OF SECTION 00600 OF THIS SOLICITATIONS AND SUBMIT THIS WITH THEIR BID.

III. OFFERORS ARE CAUTIONED TO NOTE THE CERTIFICATION OF NONSEGREGATED FACILITIES" IN THE SOLICITATION. FAILURE OF A OFFEROR TO AGREE TO THE CERTIFICATION WILL RENDER HIS OFFER NONRESPONSIVE TO THE TERMS OF SOLICITATIONS INVOLVING AWARDS OF CONTRACTS EXCEEDING \$10,000 WHICH ARE NOT EXEMPT FROM THE PROVISIONS OF THE EQUAL OPPORTUNITY CLAUSE. (1984 APR)

IV. PROSPECTIVE BIDDERS ARE INVITED TO VISIT THE SITE OF THE WORK TO ACQUAINT THEMSELVES WITH THE SITE CONDITIONS AND ANY PROBLEMS INCIDENT TO THE PROSECUTION OF THE WORK. A SITE VISIT OF THE PROJECT SITE WILL BE HELD ON 30 JUL 2002 BEGINNING AT 10:00 AM. ALL ATTENDEES SHALL MEET AT F.E. WALTER DAM IN WHITE HAVEN, PA. ALL THOSE PLANNING TO ATTEND SHALL CONTACT MR. BILL ROTHERT AT (215) 656-6893 PRIOR TO COB 29 JUL 2002.

23 July 2002

This page was intentionally left blank for duplex printing.

SOLICITATION, OFFER, AND AWARD (Continued)

(Construction, Alteration, or Repair)

OFFER (Must be fully completed by offeror)

14. NAME AND ADDRESS OF OFFEROR *(Include ZIP Code)*

15. TELEPHONE NO. *(Include area code)*

16. REMITTANCE ADDRESS *(Include only if different than Item 14)*

See Item 14

CODE

FACILITY CODE

17. The offeror agrees to perform the work required at the prices specified below in strict accordance with the terms of this solicitation, if this offer is accepted by the Government in writing within _____ calendar days after the date offers are due. *(Insert any number equal to or greater than the minimum requirements stated in Item 13D. Failure to insert any number means the offeror accepts the minimum in Item 13D.)*

AMOUNTS

SEE SCHEDULE OF PRICES

18. The offeror agrees to furnish any required performance and payment bonds.

19. ACKNOWLEDGMENT OF AMENDMENTS

(The offeror acknowledges receipt of amendments to the solicitation -- give number and date of each)

AMENDMENT NO.										
DATE										

20A. NAME AND TITLE OF PERSON AUTHORIZED TO SIGN OFFER *(Type or print)*

20B. SIGNATURE

20C. OFFER DATE

AWARD (To be completed by Government)

21. ITEMS ACCEPTED:

SEE SCHEDULE

22. AMOUNT

23. ACCOUNTING AND APPROPRIATION DATA

24. SUBMIT INVOICES TO ADDRESS SHOWN IN *(4 copies unless otherwise specified)*

ITEM

25. OTHER THAN FULL AND OPEN COMPETITION PURSUANT TO
 10 U.S.C. 2304(c) 41 U.S.C. 253(c)

26. ADMINISTERED BY

CODE

27. PAYMENT WILL BE MADE BY

CODE

CONTRACTING OFFICER WILL COMPLETE ITEM 28 OR 29 AS APPLICABLE

28. NEGOTIATED AGREEMENT *(Contractor is required to sign this document and return _____ copies to issuing office.)* Contractor agrees to furnish and deliver all items or perform all work, requisitions identified on this form and any continuation sheets for the consideration stated in this contract. The rights and obligations of the parties to this contract shall be governed by (a) this contract award, (b) the solicitation, and (c) the clauses, representations, certifications, and specifications or incorporated by reference in or attached to this contract.

29. AWARD *(Contractor is not required to sign this document.)*
 Your offer on this solicitation, is hereby accepted as to the items listed. This award consummates the contract, which consists of (a) the Government solicitation and your offer, and (b) this contract award. No further contractual document is necessary.

30A. NAME AND TITLE OF CONTRACTOR OR PERSON AUTHORIZED TO SIGN *(Type or print)*

31A. NAME OF CONTRACTING OFFICER *(Type or print)*

30B. SIGNATURE

30C. DATE

31B. UNITED STATES OF AMERICA
BY

31C. AWARD DATE

BIDDING SCHEDULE
(To be attached to SF 1442)

Item No.	Description	Estimated Quantity	Unit	Unit Price	Estimated Amount
1.	Access Road Improvements	1	Job	L.S.	\$
2.	Site Clearing	1	Job	L.S.	\$
3.	Drainage and Dewatering	1	Job	L.S.	\$
4.	Stone Riprap	2,373	Tons	\$	\$
5.	Cutoff Trench Excavation and Backfill	189	C.Y.	\$	\$
6.	Embankment Fill	2,172	C.Y.	\$	\$
7.	GCL Cover Soil	220	C.Y.	\$	\$
8.	Embankment Geotextile	25,126	S.F.	\$	\$
9.	Cutoff Trench Geotextile	2,216	S.F.	\$	\$
10.	Geosynthetic Clay Liner	6,136	S.F.	\$	\$
11.	Concrete Weir Frame	1	Job	L.S.	\$
12.	Metal Weir and Accessories	1	Job	L.S.	\$
TOTAL ESTIMATED CONTRACT PRICE					\$

This page was intentionally left blank for duplex printing.

SECTION 00100 Bidding Schedule/Instructions to Bidders

CLAUSES INCORPORATED BY FULL TEXT

52.204-6 DATA UNIVERSAL NUMBERING SYSTEM (DUNS) NUMBER (JUN 99)

(a) The offeror shall enter, in the block with its name and address on the cover page of its offer, the annotation "DUNS" followed by the DUNS number that identifies the offerors' name and address exactly as stated in the offer.

(b) If the offeror does not have a DUNS number, it should contact Dun and Bradstreet directly to obtain one. A DUNS number will be provided immediately by telephone at no charge to the offeror. For information on obtaining a DUNS number, the offeror, if located within the United States, should call Dun and Bradstreet at 1-800-333-0505. The offeror should be prepared to provide the following information:

- (1) Company name.
- (2) Company address.
- (3) Company telephone number.
- (4) Line of business.
- (5) Chief executive officer/key manager.
- (6) Date the company was started.
- (7) Number of people employed by the company.
- (8) Company affiliation.

(c) Offerors located outside the United States may obtain the location and phone number of the local Dun and Bradstreet Information Services office from the Internet Home Page at <http://www.customerservice@dnb.com>. If an offeror is unable to locate a local service center, it may send an e-mail to Dun and Bradstreet at globalinfo@mail.dnb.com.

52.214-3 AMENDMENTS TO INVITATIONS FOR BIDS (DEC 1989)

(a) If this solicitation is amended, then all terms and conditions which are not modified remain unchanged.

(b) Bidders shall acknowledge receipt of any amendment to this solicitation (1) by signing and returning the amendment, (2) by identifying the amendment number and date

in the space provided for this purpose on the form for submitting a bid, (3) by letter or telegram, or (4) by facsimile, if facsimile bids are authorized in the solicitation. The Government must receive the acknowledgment by the time and at the place specified for receipt of bids.

52.214-4 FALSE STATEMENTS IN BIDS (APR 1984)

Bidders must provide full, accurate, and complete information as required by this solicitation and its attachments. The penalty for making false statements in bids is prescribed in 18 U.S.C. 1001.

52.214-5 SUBMISSION OF BIDS (MAR 1997)

(a) Bids and bid modifications shall be submitted in sealed envelopes or packages (unless submitted by electronic means) (1) addressed to the office specified in the solicitation, and (2) showing the time and date specified for receipt, the solicitation number, and the name and address of the bidder.

(b) Bidders using commercial carrier services shall ensure that the bid is addressed and marked on the outermost envelope or wrapper as prescribed in subparagraphs (a)(1) and (2) of this provision when delivered to the office specified in the solicitation.

(c) Telegraphic bids will not be considered unless authorized by the solicitation; however, bids may be modified or withdrawn by written or telegraphic notice.

(d) Facsimile bids, modifications, or withdrawals, will not be considered unless authorized by the solicitation.

(e) Bids submitted by electronic commerce shall be considered only if the electronic commerce method was specifically stipulated or permitted by the solicitation.

52.214-6 EXPLANATION TO PROSPECTIVE BIDDERS (APR 1984)

Any prospective bidder desiring an explanation or interpretation of the solicitation, drawings, specifications, etc., must request it in writing soon enough to allow a reply to reach all prospective bidders before the submission of their bids. Oral explanations or instructions given before the award of a contract will not be binding. Any information given a prospective bidder concerning a solicitation will be furnished promptly to all other prospective bidders as an amendment to the solicitation, if that information is necessary in submitting bids or if the lack of it would be prejudicial to other prospective bidders.

52.214-7 LATE SUBMISSIONS, MODIFICATIONS, AND WITHDRAWALS OF BIDS (NOV 1999)

(a) Bidders are responsible for submitting bids, and any modifications or withdrawals, so as to reach the Government office designated in the invitation for bids (IFB) by the time specified in the IFB. If no time is specified in the IFB, the time for receipt is 4:30 p.m., local time, for the designated Government office on the date that bids are due.

(b)(1) Any bid, modification, or withdrawal received at the Government office designated in the IFB after the exact time specified for receipt of bids is "late" and will not be considered unless it is received before award is made, the Contracting Officer determines that accepting the late bid would not unduly delay the acquisition; and--

(i) If it was transmitted through an electronic commerce method authorized by the IFB, it was received at the initial point of entry to the Government infrastructure not later than 5:00 p.m. one working day prior to the date specified for receipt of bids; or

(ii) There is acceptable evidence to establish that it was received at the Government installation designated for receipt of bids and was under the Government's control prior to the time set for receipt of bids.

(2) However, a late modification of an otherwise successful bid that makes its terms more favorable to the Government, will be considered at any time it is received and may be accepted.

(c) Acceptable evidence to establish the time of receipt at the Government installation includes the time/date stamp of that installation on the bid wrapper, other documentary evidence of receipt maintained by the installation, or oral testimony or statements of Government personnel.

(d) If an emergency or unanticipated event interrupts normal Government processes so that bids cannot be received at the Government office designated for receipt of bids by the exact time specified in the IFB and urgent Government requirements preclude amendment of the IFB, the time specified for receipt of bids will be deemed to be extended to the same time of day specified in the solicitation on the first work day on which normal Government processes resume.

(e) Bids may be withdrawn by written notice received at any time before the exact time set for receipt of bids. If the IFB authorizes facsimile bids, bids may be withdrawn via facsimile received at any time before the exact time set for receipt of bids, subject to the conditions specified in the provision at 52.214-31, Facsimile Bids. A bid may be withdrawn in person by a bidder or its authorized representative if, before the exact time set for receipt of bids, the identity of the person requesting withdrawal is established and the person signs a receipt for the bid.

52.214-12 PREPARATION OF BIDS (APR 1984)

(a) Bidders are expected to examine the drawings, specifications, Schedule, and all instructions. Failure to do so will be at the bidder's risk.

(b) Each bidder shall furnish the information required by the solicitation. The bidder shall sign the bid and print or type its name on the Schedule and each continuation sheet on which it makes an entry. Erasures or other changes must be initialed by the person signing the bid. Bids signed by an agent shall be accompanied by evidence of that agent's authority, unless that evidence has been previously furnished to the issuing office.

(c) For each item offered, bidders shall (1) show the unit price, including, unless otherwise specified, packaging, packing, and preservation and (2) enter the extended price for the quantity of each item offered in the "Amount" column of the Schedule. In case of discrepancy between a unit price and an extended price, the unit price will be presumed to be correct, subject, however, to correction to the same extent and in the same manner as any other mistake.

(d) Bids for supplies or services other than those specified will not be considered unless authorized by the solicitation.

(e) Bidders must state a definite time for delivery of supplies or for performance of services, unless otherwise specified in the solicitation.

(f) Time, if stated as a number of days, will include Saturdays, Sundays, and holidays.

52.214-18 PREPARATION OF BIDS--CONSTRUCTION (APR 1984)

(a) Bids must be (1) submitted on the forms furnished by the Government or on copies of those forms, and (2) manually signed. The person signing a bid must initial each erasure or change appearing on any bid form.

(b) The bid form may require bidders to submit bid prices for one or more items on various bases, including--

(1) Lump sum bidding;

(2) Alternate prices;

(3) Units of construction; or

(4) Any combination of subparagraphs (1) through (3) above.

(c) If the solicitation requires bidding on all items, failure to do so will disqualify the bid. If bidding on all items is not required, bidders should insert the words "no bid" in the

space provided for any item on which no price is submitted.

(d) Alternate bids will not be considered unless this solicitation authorizes their submission.

52.214-19 CONTRACT AWARD--SEALED BIDDING--CONSTRUCTION (AUG 1996)

(a) The Government will evaluate bids in response to this solicitation without discussions and will award a contract to the responsible bidder whose bid, conforming to the solicitation, will be most advantageous to the Government, considering only price and the price-related factors specified elsewhere in the solicitation.

(b) The Government may reject any or all bids, and waive informalities or minor irregularities in bids received.

(c) The Government may accept any item or combination of items, unless doing so is precluded by a restrictive limitation in the solicitation or the bid.

(d) The Government may reject a bid as nonresponsive if the prices bid are materially unbalanced between line items or subline items. A bid is materially unbalanced when it is based on prices significantly less than cost for some work and prices which are significantly overstated in relation to cost for other work, and if there is a reasonable doubt that the bid will result in the lowest overall cost to the Government even though it may be the low evaluated bid, or if it is so unbalanced as to be tantamount to allowing an advance payment.

52.216-1 TYPE OF CONTRACT (APR 1984)

The Government contemplates award of a firm, fixed price contract resulting from this solicitation.

52.225-10 NOTICE OF BUY AMERICAN ACT REQUIREMENT--CONSTRUCTION MATERIALS (MAY 2002)

(a) Definitions. Construction material, domestic construction material, and foreign construction material, as used in this provision, are defined in the clause of this solicitation entitled "Buy American Act--Construction Materials" (Federal Acquisition Regulation (FAR) clause 52.225-9).

(b) Requests for determinations of inapplicability. An offeror requesting a determination regarding the inapplicability of the Buy American Act should submit the request to the Contracting Officer in time to allow a determination before submission of offers. The

offeror shall include the information and applicable supporting data required by paragraphs (c) and (d) of the clause at FAR 52.225-9 in the request. If an offeror has not requested a determination regarding the inapplicability of the Buy American Act before submitting its offer, or has not received a response to a previous request, the offeror shall include the information and supporting data in the offer.

(c) Evaluation of offers. (1) The Government will evaluate an offer requesting exception to the requirements of the Buy American Act, based on claimed unreasonable cost of domestic construction material, by adding to the offered price the appropriate percentage of the cost of such foreign construction material, as specified in paragraph (b)(3)(i) of the clause at FAR 52.225-9.

(2) If evaluation results in a tie between an offeror that requested the substitution of foreign construction material based on unreasonable cost and an offeror that did not request an exception, the Contracting Officer will award to the offeror that did not request an exception based on unreasonable cost.

(d) Alternate offers.

(1) When an offer includes foreign construction material not listed by the Government in this solicitation in paragraph (b)(2) of the clause at FAR 52.225-9, the offeror also may submit an alternate offer based on use of equivalent domestic construction material.

(2) If an alternate offer is submitted, the offeror shall submit a separate Standard Form 1442 for the alternate offer, and a separate price comparison table prepared in accordance with paragraphs (c) and (d) of the clause at FAR 52.225-9 for the offer that is based on the use of any foreign construction material for which the Government has not yet determined an exception applies.

(3) If the Government determines that a particular exception requested in accordance with paragraph (c) of the clause at FAR 52.225-9 does not apply, the Government will evaluate only those offers based on use of the equivalent domestic construction material, and the offeror shall be required to furnish such domestic construction material. An offer based on use of the foreign construction material for which an exception was requested--

(i) Will be rejected as nonresponsive if this acquisition is conducted by sealed bidding; or

(ii) May be accepted if revised during negotiations.

52.233-2 SERVICE OF PROTEST (AUG 1996)

(a) Protests, as defined in section 33.101 of the Federal Acquisition Regulation, that are filed directly with an agency, and copies of any protests that are filed with the General Accounting Office (GAO), shall be served on the Contracting Officer (addressed as follows) by obtaining written and dated acknowledgment of receipt from:

Denise DeTitta, Contracting Officer
USAED Philadelphia
100 Penn Square East
Wanmaker Bldg, Rm 643
Philadelphia, PA 19107-3390

(b) The copy of any protest shall be received in the office designated above within one day of filing a protest with the GAO.

52.236-27 SITE VISIT (CONSTRUCTION) (FEB 1995)

(a) The clauses at 52.236-2, Differing Site Conditions, and 52.236-3, Site Investigations and Conditions Affecting the Work, will be included in any contract awarded as a result of this solicitation. Accordingly, offerors or quoters are urged and expected to inspect the site where the work will be performed.

(b) Site visits may be arranged during normal duty hours by contacting:

Name: William Rothert
Telephone: 215-656-6693

This page intentionally left blank

SECTION 00600 Representations & Certifications

CLAUSES INCORPORATED BY FULL TEXT

52.203-2 CERTIFICATE OF INDEPENDENT PRICE DETERMINATION (APR 1985)

(a) The offeror certifies that --

(1) The prices in this offer have been arrived at independently, without, for the purpose of restricting competition, any consultation, communication, or agreement with any other offeror or competitor relating to --

(i) Those prices,

(ii) The intention to submit an offer, or

(iii) The methods of factors used to calculate the prices offered:

(2) The prices in this offer have not been and will not be knowingly disclosed by the offeror, directly or indirectly, to any other offeror or competitor before bid opening (in the case of a sealed bid solicitation) or contract award (in the case of a negotiated solicitation) unless otherwise required by law; and

(3) No attempt has been made or will be made by the offeror to induce any other concern to submit or not to submit an offer for the purpose of restricting competition.

(b) Each signature on the offer is considered to be a certification by the signatory that the signatory --

(1) Is the person in the offeror's organization responsible for determining the prices offered in this bid or proposal, and that the signatory has not participated and will not participate in any action contrary to subparagraphs (a)(1) through (a)(3) of this provision; or

(2) (i) Has been authorized, in writing, to act as agent for the following principals in certifying that those principals have not participated, and will not participate in any action contrary to subparagraphs (a)(1) through (a)(3) of this provision

_____ (insert full name of person(s) in the offeror's organization responsible for determining the prices offered in this bid or proposal, and the title of his or her position in the offeror's organization);

(ii) As an authorized agent, does certify that the principals named in subdivision (b)(2)(i) above have not participated, and will not participate, in any action contrary to subparagraphs (a)(1) through (a)(3) above; and

(iii) As an agent, has not personally participated, and will not participate, in any action contrary to subparagraphs (a)(1) through (a)(3) of this provision.

(c) If the offeror deletes or modifies subparagraph (a)(2) of this provision, the offeror must furnish with its offer a signed statement setting forth in detail the circumstances of the disclosure.

52.203-11 CERTIFICATION AND DISCLOSURE REGARDING PAYMENTS TO INFLUENCE CERTAIN FEDERAL TRANSACTIONS (APR 1991)

(a) The definitions and prohibitions contained in the clause, at FAR 52.203-12, Limitation on Payments to Influence Certain Federal Transactions, included in this solicitation, are hereby incorporated by reference in paragraph (b) of this Certification.

(b) The offeror, by signing its offer, hereby certifies to the best of his or her knowledge and belief that on or after December 23, 1989,--

(1) No Federal appropriated funds have been paid or will be paid to any person for influencing or attempting to influence an officer or employee of any agency, a Member of Congress, an officer or employee of Congress, or an employee of a Member of Congress on his or her behalf in connection with the awarding of any Federal contract, the making of any Federal grant, the making of any Federal loan, the entering into of any cooperative agreement, and the extension, continuation, renewal, amendment or modification of any Federal contract, grant, loan, or cooperative agreement;

(2) If any funds other than Federal appropriated funds (including profit or fee received under a covered Federal transaction) have been paid, or will be paid to any person for influencing or attempting to influence an officer or employee of any agency, a Member of Congress, an officer or employee of Congress or an employee of a Member of Congress on his or her behalf in connection with this solicitation, the offeror shall complete and submit, with its offer, OMB standard form LLL, Disclosure of Lobbying Activities, to the Contracting Officer; and

(3) He or she will include the language of this certification in all subcontract awards at any tier and require that all recipients of subcontract awards in excess of \$100,000 shall certify and disclose accordingly.

(c) Submission of this certification and disclosure is a prerequisite for making or entering into this contract imposed by section 1352, Title 31, United States Code. Any person who makes an expenditure prohibited under this provision, shall be subject to a civil penalty of not less than \$10,000, and not more than \$100,000, for each such failure.

52.204-5 WOMEN-OWNED BUSINESS (OTHER THAN SMALL BUSINESS)
(MAY 1999)

(a) Definition. Women-owned business concern, as used in this provision, means a concern that is at least 51 percent owned by one or more women; or in the case of any publicly owned business, at least 51 percent of its stock is owned by one or more women; and whose management and daily business operations are controlled by one or more women.

(b) Representation. [Complete only if the offeror is a women-owned business concern and has not represented itself as a small business concern in paragraph (b)(1) of FAR 52.219-1, Small Business Program Representations, of this solicitation.] The offeror represents that it () is a women-owned business concern.

52.209-5 CERTIFICATION REGARDING DEBARMENT, SUSPENSION,
PROPOSED DEBARMENT, AND OTHER RESPONSIBILITY MATTERS (DEC
2001)

(a)(1) The Offeror certifies, to the best of its knowledge and belief, that--

(i) The Offeror and/or any of its Principals--

(A) Are () are not () presently debarred, suspended, proposed for debarment, or declared ineligible for the award of contracts by any Federal agency;

(B) Have () have not (), within a three-year period preceding this offer, been convicted of or had a civil judgment rendered against them for: commission of fraud or a criminal offense in connection with obtaining, attempting to obtain, or performing a public (Federal, state, or local) contract or subcontract; violation of Federal or state antitrust statutes relating to the submission of offers; or commission of embezzlement, theft, forgery, bribery, falsification or destruction of records, making false statements, tax evasion, or receiving stolen property; and

(C) Are () are not () presently indicted for, or otherwise criminally or civilly charged by a governmental entity with, commission of any of the offenses enumerated in subdivision (a)(1)(i)(B) of this provision.

(ii) The Offeror has () has not (), within a three-year period preceding this offer, had one or more contracts terminated for default by any Federal agency.

(2) "Principals," for the purposes of this certification, means officers; directors; owners; partners; and, persons having primary management or supervisory responsibilities within a business entity (e.g., general manager; plant manager; head of a subsidiary, division, or business segment, and similar positions).

THIS CERTIFICATION CONCERNS A MATTER WITHIN THE JURISDICTION OF AN AGENCY OF THE UNITED STATES AND THE MAKING OF A FALSE, FICTITIOUS, OR FRAUDULENT CERTIFICATION MAY RENDER THE MAKER SUBJECT TO PROSECUTION UNDER SECTION 1001, TITLE 18, UNITED STATES CODE.

(b) The Offeror shall provide immediate written notice to the Contracting Officer if, at any time prior to contract award, the Offeror learns that its certification was erroneous when submitted or has become erroneous by reason of changed circumstances.

(c) A certification that any of the items in paragraph (a) of this provision exists will not necessarily result in withholding of an award under this solicitation. However, the certification will be considered in connection with a determination of the Offeror's responsibility. Failure of the Offeror to furnish a certification or provide such additional information as requested by the Contracting Officer may render the Offeror nonresponsible.

(d) Nothing contained in the foregoing shall be construed to require establishment of a system of records in order to render, in good faith, the certification required by paragraph (a) of this provision. The knowledge and information of an Offeror is not required to exceed that which is normally possessed by a prudent person in the ordinary course of business dealings.

(e) The certification in paragraph (a) of this provision is a material representation of fact upon which reliance was placed when making award. If it is later determined that the Offeror knowingly rendered an erroneous certification, in addition to other remedies available to the Government, the Contracting Officer may terminate the contract resulting from this solicitation for default.

52.219-2 EQUAL LOW BIDS. (OCT 1995)

(a) This provision applies to small business concerns only.

(b) The bidder's status as a labor surplus area (LSA) concern may affect entitlement to award in case of tie bids. If the bidder wishes to be considered for this priority, the bidder must identify, in the following space, the LSA in which the costs to be incurred on account of manufacturing or production (by the bidder or the first-tier subcontractors) amount to more than 50 percent of the contract price.

(c) Failure to identify the labor surplus area as specified in paragraph (b) of this provision

will preclude the bidder from receiving priority consideration. If the bidder is awarded a contract as a result of receiving priority consideration under this provision and would not have otherwise received award, the bidder shall perform the contract or cause the contract to be performed in accordance with the obligations of an LSA concern.

52.219-22 SMALL DISADVANTAGED BUSINESS STATUS (OCT 1999)

(a) General. This provision is used to assess an offeror's small disadvantaged business status for the purpose of obtaining a benefit on this solicitation. Status as a small business and status as a small disadvantaged business for general statistical purposes is covered by the provision at FAR 52.219-1, Small Business Program Representation.

(b) Representations.

(1) General. The offeror represents, as part of its offer, that it is a small business under the size standard applicable to this acquisition; and either--

___ (i) It has received certification by the Small Business Administration as a small disadvantaged business concern consistent with 13 CFR 124, Subpart B; and

(A) No material change in disadvantaged ownership and control has occurred since its certification;

(B) Where the concern is owned by one or more disadvantaged individuals, the net worth of each individual upon whom the certification is based does not exceed \$750,000 after taking into account the applicable exclusions set forth at 13 CFR 124.104(c)(2); and

(C) It is identified, on the date of this representation, as a certified small disadvantaged business concern in the database maintained by the Small Business Administration(PROONet); or

___ (ii) It has submitted a completed application to the Small Business Administration or a Private Certifier to be certified as a small disadvantaged business concern in accordance with 13 CFR 124, Subpart B, and a decision on that application is pending, and that no material change in disadvantaged ownership and control has occurred since its application was submitted.

(2)___ For Joint Ventures. The offeror represents, as part of its offer, that it is a joint venture that complies with the requirements at 13 CFR 124.1002(f) and that the representation in paragraph (b)(1) of this provision is accurate for the small disadvantaged business concern that is participating in the joint venture. [The offeror shall enter the name of the small disadvantaged business concern that is participating in the joint venture: _____.]

(c) Penalties and Remedies. Anyone who misrepresents any aspects of the disadvantaged status of a concern for the purposes of securing a contract or subcontract shall:

- (1) Be punished by imposition of a fine, imprisonment, or both;
- (2) Be subject to administrative remedies, including suspension and debarment; and
- (3) Be ineligible for participation in programs conducted under the authority of the Small Business Act.

52.222-22 PREVIOUS CONTRACTS AND COMPLIANCE REPORTS (FEB 1999)

The offeror represents that --

- (a) It has, has not participated in a previous contract or subcontract subject to the Equal Opportunity clause of this solicitation;
- (b) It has, has not, filed all required compliance reports; and
- (c) Representations indicating submission of required compliance reports, signed by proposed subcontractors, will be obtained before subcontract awards.

52.223-13 CERTIFICATION OF TOXIC CHEMICAL RELEASE REPORTING (OCT 2000)

- (a) Submission of this certification is a prerequisite for making or entering into this contract imposed by Executive Order 12969, August 8, 1995.
- (b) By signing this offer, the offeror certifies that--

(1) As the owner or operator of facilities that will be used in the performance of this contract that are subject to the filing and reporting requirements described in section 313 of the Emergency Planning and Community Right-to-Know Act of 1986 (EPCRA) (42 U.S.C. 11023) and section 6607 of the Pollution Prevention Act of 1990 (PPA) (42 U.S.C. 13106), the offeror will file and continue to file for such facilities for the life of the contract the Toxic Chemical Release Inventory Form (Form R) as described in sections 313(a) and (g) of EPCRA and section 6607 of PPA; or

(2) None of its owned or operated facilities to be used in the performance of this contract is subject to the Form R filing and reporting requirements because each such facility is exempt for at least one of the following reasons: (Check each block that is applicable.)

(i) The facility does not manufacture, process or otherwise use any toxic chemicals listed under section 313(c) of EPCRA, 42 U.S.C. 11023(c);

(ii) The facility does not have 10 or more full-time employees as specified in section 313.(b)(1)(A) of EPCRA 42 U.S.C. 11023(b)(1)(A);

(iii) The facility does not meet the reporting thresholds of toxic chemicals established under section 313(f) of EPCRA, 42 U.S.C. 11023(f) (including the alternate thresholds at 40 CFR 372.27, provided an appropriate certification form has been filed with EPA);

(iv) The facility does not fall within Standard Industrial Classification Code (SIC) major groups 20 through 39 or their corresponding North American Industry Classification System (NAICS) sectors 31 through 33; or

(v) The facility is not located within any State of the United States, the District of Columbia, the Commonwealth of Puerto Rico, Guam, American Samoa, the United States Virgin Islands, the Northern Mariana Islands, or any other territory or possession over which the United States has jurisdiction.

252.209-7001 DISCLOSURE OF OWNERSHIP OR CONTROL BY THE GOVERNMENT OF A TERRORIST COUNTRY (MAR 1998)

(a) "Definitions."

As used in this provision --

(a) "Government of a terrorist country" includes the state and the government of a terrorist country, as well as any political subdivision, agency, or instrumentality thereof.

(2) "Terrorist country" means a country determined by the Secretary of State, under section 6(j)(1)(A) of the Export Administration Act of 1979 (50 U.S.C. App. 2405(j)(i)(A)), to be a country the government of which has repeatedly provided support for such acts of international terrorism. As of the date of this provision, terrorist countries include: Cuba, Iran, Iraq, Libya, North Korea, Sudan, and Syria.

(3) "Significant interest" means --

(i) Ownership of or beneficial interest in 5 percent or more of the firm's or subsidiary's securities. Beneficial interest includes holding 5 percent or more of any class of the firm's securities in "nominee shares," "street names," or some other method of holding securities that does not disclose the beneficial owner;

(ii) Holding a management position in the firm, such as a director or officer;

(iii) Ability to control or influence the election, appointment, or tenure of directors or officers in the firm;

(iv) Ownership of 10 percent or more of the assets of a firm such as equipment, buildings, real estate, or other tangible assets of the firm; or

(v) Holding 50 percent or more of the indebtedness of a firm.

(b) "Prohibition on award."

In accordance with 10 U.S.C. 2327, no contract may be awarded to a firm or a subsidiary of a firm if the government of a terrorist country has a significant interest in the firm or subsidiary or, in the case of a subsidiary, the firm that owns the subsidiary, unless a waiver is granted by the Secretary of Defense.

(c) "Disclosure."

If the government of a terrorist country has a significant interest in the Offeror or a subsidiary of the Offeror, the Offeror shall disclose such interest in an attachment to its offer. If the Offeror is a subsidiary, it shall also disclose any significant interest the government of a terrorist country has in any firm that owns or controls the subsidiary.

The disclosure shall include --

- (1) Identification of each government holding a significant interest; and
- (2) A description of the significant interest held by each government.

252.225-7017 PROHIBITION ON AWARD TO COMPANIES OWNED BY THE PEOPLE'S REPUBLIC OF CHINA (FEB 2000)

(a) Definition. "People's Republic of China," as used in this provision, means the government of the People's Republic of China, including its political subdivisions, agencies, and instrumentalities.

(b) Prohibition on award. Section 8120 of the Department of Defense Appropriations Act for fiscal year 1999 (Pub. L. 105-262), as amended by Section 144 of Title I, Division C, of the Omnibus Consolidated and Emergency Supplemental Appropriations Act, 1999 (Pub. L. 105-277), prohibits the award of a contract under this solicitation to any company in which the Director of Defense Procurement (Office of the Under Secretary of Defense (Acquisition, Technology, and Logistics)) has determined that the People's Republic of China or the People's Liberation Army of the People's Republic of China owns more than 50 percent interest.

(c) Representation. By submission of an offer, the offeror represents that the People's Republic of China or the People's Liberation Army of the People's Republic of China does not own more than 50 percent interest in the offeror.

252.247-7022 REPRESENTATION OF EXTENT OF TRANSPORTATION BY SEA (AUG 1992)

(a) The Offeror shall indicate by checking the appropriate blank in paragraph (b) of this provision whether transportation of supplies by sea is anticipated under the resultant contract. The term supplies is defined in the Transportation of Supplies by Sea clause of this solicitation.

(b) Representation. The Offeror represents that it:

____ (1) Does anticipate that supplies will be transported by sea in the performance of any contract or subcontract resulting from this solicitation.

____ (2) Does not anticipate that supplies will be transported by sea in the performance of any contract or subcontract resulting from this solicitation.

(c) Any contract resulting from this solicitation will include the Transportation of Supplies by Sea clause. If the Offeror represents that it will not use ocean transportation,

the resulting contract will also include the Defense FAR Supplement clause at 252.247-7024, Notification of Transportation of Supplies by Sea.

SMALL, VETERAN-OWNED SMALL, HUBZONE SMALL, SMALL DISADVANTAGED AND WOMEN-OWNED SMALL BUSINESS SUBCONTRACTING PLAN

DATE: _____

CONTRACTOR: _____
 ADDRESS: _____
 SOLICITATION OR CONTRACT NUMBER: _____
 ITEM/SERVICE: _____

The following, together with any attachments, is hereby submitted as a Subcontracting Plan to satisfy the applicable requirements of Public Law 95-507 as implemented by OFPP Policy Letter 80-2.

1. (a) The following percentage goals (expressed in terms of a percentage of total planned subcontracting dollars) are applicable to the contract cited above or to the contract awarded under the solicitation cited.

(i) Small Business Concerns: _____% of total planned subcontracting dollars under this contract will go to subcontractors who are small business concerns.

(ii) Veteran-Owned Small Business Concerns: _____ % of total planned subcontracting dollars under this contract will go to subcontractors who are veteran-owned small business concerns. Service-disabled veteran-owned small business concerns meet the definition of veteran-owned small business concerns, and offerors may include them within the subcontracting plan goal for veteran-owned small business concerns. A separate goal for service-disabled veteran-owned small business concerns is not required.

(iii) HUBZone Small Business Concerns: _____ % of total planned subcontracting dollars under this contract will go to subcontractors who are small business concerns located in a historically underutilized business zone which is an area located within one or more qualified census tracts, qualified nonmetropolitan counties, or lands within the external boundaries of an Indian reservation and appear on the List of Qualified HUBZone Small Business Concerns maintained by the SBA. (<http://www.sba.gov/hubzone/>).

(iv) Small Disadvantaged Business Concerns: _____% of total planned subcontracting dollars under this contract will go to subcontractors who are small concerns owned and controlled by socially and economically disadvantaged individuals. This percentage is included in the percentage shown under 1.(a)(i) above, as a subset.

(v) Women-Owned Small Business Concerns: _____% of total planned subcontracting dollars under this contract will go to subcontractors who are women-owned small business concerns. This percentage is included in the percentage shown under 1.(a)(i) above, as a subset.

(b) The following dollar values correspond to the percentage goals shown in (a) above.

(i) Total dollars planned to be subcontracted to small business concerns:
 \$ _____.

(ii) Total dollars planned to be subcontracted to veteran-owned small business concerns:
\$ _____.

(iii) Total dollars planned to be subcontracted to HUBZone small business concerns:
\$ _____.

(iv) Total dollars planned to be subcontracted to small disadvantaged business concerns:
\$ _____. This dollar amount is included in the amount shown under 1.(b)(i) above, as a subset.

(v) Total dollars planned to be subcontracted to women-owned small business concerns:
\$ _____. This dollar amount is included in the amount shown under 1.(b)(i) above, as a subset.

(c) The total estimated dollar value of all planned subcontracting (to all types of business concerns) under this contract is \$ _____.

(d) The following principal products and/or services will be subcontracted under this contract, and the distribution among small, veteran-owned small, HUBZone small business, small disadvantaged, and women-owned small business concerns is as follows:

(Products/services planned to be subcontracted to small business concerns are identified by *, veteran-owned small business concerns by **, HUBZone small business concerns by ***, small disadvantaged business concerns by **** and women-owned small business concerns by *****)

(Attachment may be used if additional space is required)

(e) The following method was used in developing subcontract goals (i.e., statement explaining how the product and service areas to be subcontracted were established, how the areas to be subcontracted to small, veteran-owned small, HUBZone small, small disadvantaged, and women-owned small business concerns were determined, and how small, veteran-owned small, HUBZone small, small disadvantaged, and women-owned small business concerns capabilities were determined, to include identification of source lists utilized in making those determination).

(f) Indirect and over head costs [_____] have [_____] have not been included in the goals specified in 1(a) and 1(b).

(g) If “have” is checked, explain the method used in determining the proportionate share of indirect and overhead cost to be allocated as subcontracts to small business concerns, veteran-owned small, HUBZone small business concerns, small disadvantaged business concerns, and women-owned small business concerns.

2. The following individual will administer the subcontracting program:

Name: _____
Address & Telephone: _____
Telephone: _____

This individual's specific duties, as they relate to the firm's subcontracting program are as follows:

General overall responsibility for this company's Small Business Program, the development, preparation and execution of individual subcontracting plans and for monitoring performance relative to contractual subcontracting requirements contained in this plan, including but not limited to:

- (a) Developing and maintaining bidders lists of small, veteran-owned small, HUBZone small, small disadvantaged, and women-owned small business concerns from all possible sources.
- (b) Ensuring that procurement packages are structured to permit small, veteran-owned small, HUBZone small, small disadvantaged, and women-owned business concerns to participate to the maximum extent possible.
- (c) Assuring inclusion of small, veteran-owned small, HUBZone small, small disadvantaged, and women-owned business concerns in all solicitations for products or services which they are capable of providing.
- (d) Reviewing solicitations to remove statements, clauses, etc., which may tend to restrict or prohibit small, veteran-owned small, HUBZone small, small disadvantaged, and women-owned business participation.
- (e) Ensuring periodic rotation of potential subcontractors on bidders lists.
- (f) Ensuring that the bid proposal review board documents its reasons for rejecting low bids submitted by small, veteran-owned small, HUBZone small, small disadvantaged, and women-owned business concerns.
- (g) Ensuring the establishment and maintenance of records of solicitations and subcontract award activity.

(h) Attending or arranging for attendance of company counselors at Business Opportunity Workshops, Minority Business Enterprise Seminars, Trade Fairs, etc.

(i) Conducting or arranging for conduct of motivational training for purchasing personnel pursuant to the intent of P.O. 95-507.

(j) Monitoring attainment of proposed goals.

(k) Preparing and submitting periodic subcontracting reports required.

(l) Coordinating contractor's activities during the conduct of compliance reviews by Federal Agencies.

(m) Coordinating the conduct of contractor's activities involving its small, veteran-owned small, HUBZone small, small disadvantaged, and women-owned business subcontracting program.

(n) Additions to (or deletions from) the duties specified above are as follows:

3. The following efforts will be taken to assure that small, veteran-owned small, HUBZone, small, small disadvantaged, and women-owned business concerns will have an equitable opportunity to compete for subcontracts:

(a) Outreach efforts will be made as follows:

(i) Contacts with minority and small business trade associations

(ii) Contacts with business development organizations

(iii) Attendance at small and minority business procurement conferences

(iv) Sources will be requested from SBA's PASS system.

(b) The following internal efforts will be made to guide and encourage buyers:

(i) Workshops, seminars and training programs will be conducted

(ii) Activities will be monitored to evaluate compliance with this subcontracting plan.

(c) Small, veteran-owned small, HUBZone small, small disadvantaged, and women-owned business concern source lists, guides and other data identifying small, veteran-owned small,

HUBZone small, small disadvantaged, and women-owned business concerns will be maintained and utilized by buyers in soliciting subcontracts.

(d) Additions to (or deletions from) the above listed efforts are as follows:

4. The bidder (contractor) agrees that the clause entitled Utilization of Small, veteran-owned small, HUBZone Small, Small Disadvantaged, and Women-Owned Small Business Concerns will be included in all subcontracts which offer further subcontracting opportunities, and all subcontractors except small business concerns who receive subcontracts in excess of \$500,000 will be required to adopt and comply with a subcontracting plan similar to this one. Such plans will be reviewed by comparing them with the provisions of Public Law 95-507, and assuring that all minimum requirements of an acceptable subcontracting plan have been satisfied. The acceptability of percentage goals shall be determined on a case-by-case basis depending on the supplies/services involved, the availability of potential small, veteran-owned small, HUBZone small, small disadvantaged, and women-owned subcontractors, and prior experience. Once approved and implemented, plans will be monitored through the submission of periodic reports, and/or, as time and availability of funds permit, periodic visits to subcontractors facilities to review applicable records and subcontracting program progress.

5. The bidder (contractor) agrees to submit such periodic reports and cooperate in any studies or surveys as may be required by the contracting agency or the Small business Administration in order to determine the extent of compliance by the bidder with the subcontracting plan and with the clause entitled Utilization of Small, veteran-owned small, HUBZone Small, Small Disadvantaged, and Women-Owned Small Business Concerns, contained in the contract.

6. The bidder (contractor) agrees that he will maintain at least the following types of records to document compliance with this subcontracting plan:

(a) Small, veteran-owned small, HUBZone Small, Small Disadvantaged, and Women-Owned Business concern source lists, guides and other data identifying SB/HZSB/SDB/WO vendors.

(b) Organizations contacted for small, veteran-owned small, HUBZone small, small disadvantaged, and women-owned business sources.

(c) On a contract-by-contract basis, records on all subcontract solicitations over \$100,000, indicating on each solicitation (1) whether small business concerns were solicited, and if not, why not; (2) whether veteran-owned small business concerns were solicited, and if not, why not; (3) whether HUBZone small business concerns were solicited, and if not, why not; (4) whether small disadvantaged business concerns were solicited, and if not, why not; (5) whether women-owned business concerns were solicited and if not, why not; and (6) reasons for the failure of

solicited small, veteran-owned small, HUBZone small, small disadvantaged, or women-owned business concerns to receive the subcontract award.

(d) Records to support other outreach efforts: Contacts with Minority and Small Business Trade Associations, etc. Attendance at small and minority business procurement conferences and trade fairs.

(e) Records to support internal activities to guide and encourage buyers: Workshops, seminars, training programs, etc. Monitoring activities to evaluate compliance.

(f) On a contract-by-contract basis, records to support subcontract award data to include name and address or subcontractor .

(g) Records to be maintained in addition to the above are as follows:

Signed: _____
Typed Name: _____
Title: _____
Date: _____

Plan Accepted By: _____
Contracting Officer

Date: _____

NOTE TO CONTRACTING OFFICER: Upon incorporation of a plan into the contract, indicate herein the estimated dollar value of the contract:

\$ _____.

SECTION 00700 Contract Clauses

CLAUSES INCORPORATED BY FULL TEXT

52.203-3 GRATUITIES (APR 1984)

(a) The right of the Contractor to proceed may be terminated by written notice if, after notice and hearing, the agency head or a designee determines that the Contractor, its agent, or another representative--

(1) Offered or gave a gratuity (e.g., an entertainment or gift) to an officer, official, or employee of the Government; and

(2) Intended, by the gratuity, to obtain a contract or favorable treatment under a contract.

(b) The facts supporting this determination may be reviewed by any court having lawful jurisdiction.

(c) If this contract is terminated under paragraph (a) of this clause, the Government is entitled--

(1) To pursue the same remedies as in a breach of the contract; and

(2) In addition to any other damages provided by law, to exemplary damages of not less than 3 nor more than 10 times the cost incurred by the Contractor in giving gratuities to the person concerned, as determined by the agency head or a designee. (This subparagraph (c)(2) is applicable only if this contract uses money appropriated to the Department of Defense.)

(d) The rights and remedies of the Government provided in this clause shall not be exclusive and are in addition to any other rights and remedies provided by law or under this contract.

52.203-5 COVENANT AGAINST CONTINGENT FEES (APR 1984)

(a) The Contractor warrants that no person or agency has been employed or retained to solicit or obtain this contract upon an agreement or understanding for a contingent fee, except a bona fide employee or agency. For breach or violation of this warranty, the Government shall have the right to annul this contract without liability or, in its discretion, to deduct from the contract price or consideration, or otherwise recover, the full amount of the contingent fee.

(b) "Bona fide agency," as used in this clause, means an established commercial or selling agency, maintained by a contractor for the purpose of securing business, that neither exerts nor proposes to exert improper influence to solicit or obtain Government contracts nor holds itself out as being able to obtain any Government contract or contracts through improper influence.

"Bona fide employee," as used in this clause, means a person, employed by a contractor and subject to the contractor's supervision and control as to time, place, and manner of performance, who neither exerts nor proposes to exert improper influence to solicit or obtain Government contracts nor holds out as being able to obtain any Government contract or contracts through improper influence.

"Contingent fee," as used in this clause, means any commission, percentage, brokerage, or other fee that is contingent upon the success that a person or concern has in securing a Government contract.

"Improper influence," as used in this clause, means any influence that induces or tends to induce a Government employee or officer to give consideration or to act regarding a Government contract on any basis other than the merits of the matter.

52.203-7 ANTI-KICKBACK PROCEDURES. (JUL 1995)

(a) Definitions.

"Kickback," as used in this clause, means any money, fee, commission, credit, gift, gratuity, thing of value, or compensation of any kind which is provided, directly or indirectly, to any prime Contractor, prime Contractor employee, subcontractor, or subcontractor employee for the purpose of improperly obtaining or rewarding favorable treatment in connection with a prime contract or in connection with a subcontract relating to a prime contract.

"Person," as used in this clause, means a corporation, partnership, business association of any kind, trust, joint-stock company, or individual.

"Prime contract," as used in this clause, means a contract or contractual action entered into by the United States for the purpose of obtaining supplies, materials, equipment, or services of any kind.

"Prime Contractor," as used in this clause, means a person who has entered into a prime contract with the United States.

"Prime Contractor employee," as used in this clause, means any officer, partner, employee, or agent of a prime Contractor.

"Subcontract," as used in this clause, means a contract or contractual action entered into by a prime Contractor or subcontractor for the purpose of obtaining supplies, materials, equipment, or services of any kind under a prime contract.

"Subcontractor," as used in this clause, (1) means any person, other than the prime Contractor, who offers to furnish or furnishes any supplies, materials, equipment, or services of any kind under a prime contract or a subcontract entered into in connection with such prime contract, and (2) includes any person who offers to furnish or furnishes general supplies to the prime Contractor or a higher tier subcontractor.

"Subcontractor employee," as used in this clause, means any officer, partner, employee, or agent of a subcontractor.

(b) The Anti-Kickback Act of 1986 (41 U.S.C. 51-58) (the Act), prohibits any person from -

(1) Providing or attempting to provide or offering to provide any kickback;

(2) Soliciting, accepting, or attempting to accept any kickback; or

(3) Including, directly or indirectly, the amount of any kickback in the contract price charged by a prime Contractor to the United States or in the contract price charged by a subcontractor to a prime Contractor or higher tier subcontractor.

(c)(1) The Contractor shall have in place and follow reasonable procedures designed to prevent and detect possible violations described in paragraph (b) of this clause in its own operations and direct business relationships.

(2) When the Contractor has reasonable grounds to believe that a violation described in paragraph (b) of this clause may have occurred, the Contractor shall promptly report in writing the possible violation. Such reports shall be made to the inspector general of the contracting agency, the head of the contracting agency if the agency does not have an inspector general, or the Department of Justice.

(3) The Contractor shall cooperate fully with any Federal agency investigating a possible violation described in paragraph (b) of this clause.

(4) The Contracting Officer may (i) offset the amount of the kickback against any monies owed by the United States under the prime contract and/or (ii) direct that the Prime Contractor withhold, from sums owed a subcontractor under the prime contract, the amount of any kickback. The Contracting Officer may order the monies withheld under subdivision (c)(4)(ii) of this clause be paid over to the Government unless the Government has already offset those monies under subdivision (c)(4)(i) of this clause. In either case, the Prime Contractor shall notify the Contracting Officer when the monies are withheld.

(5) The Contractor agrees to incorporate the substance of this clause, including this subparagraph (c)(5) but excepting subparagraph (c)(1), in all subcontracts under this contract which exceed \$100,000.

52.203-8 CANCELLATION, RESCISSION, AND RECOVERY OF FUNDS FOR ILLEGAL OR IMPROPER ACTIVITY (JAN 1997)

(a) If the Government receives information that a contractor or a person has engaged in conduct constituting a violation of subsection (a), (b), (c), or (d) of Section 27 of the Office of Federal Procurement Policy Act (41 U.S.C. 423) (the Act), as amended by section 4304 of the 1996

National Defense Authorization Act for Fiscal Year 1996 (Pub. L. 104-106), the Government may--

(1) Cancel the solicitation, if the contract has not yet been awarded or issued; or

(2) Rescind the contract with respect to which--

(i) The Contractor or someone acting for the Contractor has been convicted for an offense where the conduct constitutes a violation of subsection 27(a) or (b) of the Act for the purpose of either--

(A) Exchanging the information covered by such subsections for anything of value; or

(B) Obtaining or giving anyone a competitive advantage in the award of a Federal agency procurement contract; or

(ii) The head of the contracting activity has determined, based upon a preponderance of the evidence, that the Contractor or someone acting for the Contractor has engaged in conduct constituting an offense punishable under subsections 27(e)(1) of the Act.

(b) If the Government rescinds the contract under paragraph (a) of this clause, the Government is entitled to recover, in addition to any penalty prescribed by law, the amount expended under the contract.

(c) The rights and remedies of the Government specified herein are not exclusive, and are in addition to any other rights and remedies provided by law, regulation, or under this contract.

52.203-10 PRICE OR FEE ADJUSTMENT FOR ILLEGAL OR IMPROPER ACTIVITY (JAN 1997)

(a) The Government, at its election, may reduce the price of a fixed-price type contract and the total cost and fee under a cost-type contract by the amount of profit or fee determined as set forth in paragraph (b) of this clause if the head of the contracting activity or designee determines that there was a violation of subsection 27 (a), (b), or (c) of the Office of Federal Procurement Policy Act, as amended (41 U.S.C. 423), as implemented in section 3.104 of the Federal Acquisition Regulation.

(b) The price or fee reduction referred to in paragraph (a) of this clause shall be--

(1) For cost-plus-fixed-fee contracts, the amount of the fee specified in the contract at the time of award;

(2) For cost-plus-incentive-fee contracts, the target fee specified in the contract at the time of award, notwithstanding any minimum fee or "fee floor" specified in the contract;

(3) For cost-plus-award-fee contracts--

(i) The base fee established in the contract at the time of contract award;

(ii) If no base fee is specified in the contract, 30 percent of the amount of each award fee otherwise payable to the Contractor for each award fee evaluation period or at each award fee determination point.

(4) For fixed-price-incentive contracts, the Government may--

(i) Reduce the contract target price and contract target profit both by an amount equal to the initial target profit specified in the contract at the time of contract award; or

(ii) If an immediate adjustment to the contract target price and contract target profit would have a significant adverse impact on the incentive price revision relationship under the contract, or adversely affect the contract financing provisions, the Contracting Officer may defer such adjustment until establishment of the total final price of the contract. The total final price established in accordance with the incentive price revision provisions of the contract shall be reduced by an amount equal to the initial target profit specified in the contract at the time of contract award and such reduced price shall be the total final contract price.

(5) For firm-fixed-price contracts, by 10 percent of the initial contract price or a profit amount determined by the Contracting Officer from records or documents in existence prior to the date of the contract award.

(c) The Government may, at its election, reduce a prime contractor's price or fee in accordance with the procedures of paragraph (b) of this clause for violations of the Act by its subcontractors by an amount not to exceed the amount of profit or fee reflected in the subcontract at the time the subcontract was first definitively priced.

(d) In addition to the remedies in paragraphs (a) and (c) of this clause, the Government may terminate this contract for default. The rights and remedies of the Government specified herein are not exclusive, and are in addition to any other rights and remedies provided by law or under this contract.

52.203-12 LIMITATION ON PAYMENTS TO INFLUENCE CERTAIN FEDERAL TRANSACTIONS (JUN 1997)

(a) Definitions.

"Agency," as used in this clause, means executive agency as defined in 2.101.

"Covered Federal action," as used in this clause, means any of the following Federal actions:

(1) The awarding of any Federal contract.

(2) The making of any Federal grant.

- (3) The making of any Federal loan.
- (4) The entering into of any cooperative agreement.
- (5) The extension, continuation, renewal, amendment, or modification of any Federal contract, grant, loan, or cooperative agreement.

"Indian tribe" and "tribal organization," as used in this clause, have the meaning provided in section 4 of the Indian Self-Determination and Education Assistance Act (25 U.S.C. 450B) and include Alaskan Natives.

"Influencing or attempting to influence," as used in this clause, means making, with the intent to influence, any communication to or appearance before an officer or employee of any agency, a Member of Congress, an officer or employee of Congress, or an employee of a Member of Congress in connection with any covered Federal action.

"Local government," as used in this clause, means a unit of government in a State and, if chartered, established, or otherwise recognized by a State for the performance of a governmental duty, including a local public authority, a special district, an intrastate district, a council of governments, a sponsor group representative organization, and any other instrumentality of a local government.

"Officer or employee of an agency," as used in this clause, includes the following individuals who are employed by an agency:

- (1) An individual who is appointed to a position in the Government under Title 5, United States Code, including a position under a temporary appointment.
- (2) A member of the uniformed services, as defined in subsection 101(3), Title 37, United States Code.
- (3) A special Government employee, as defined in section 202, Title 18, United States Code.
- (4) An individual who is a member of a Federal advisory committee, as defined by the Federal Advisory Committee Act, Title 5, United States Code, appendix 2.

"Person," as used in this clause, means an individual, corporation, company, association, authority, firm, partnership, society, State, and local government, regardless of whether such entity is operated for profit, or not for profit. This term excludes an Indian tribe, tribal organization, or any other Indian organization with respect to expenditures specifically permitted by other Federal law.

"Reasonable compensation," as used in this clause, means, with respect to a regularly employed officer or employee of any person, compensation that is consistent with the normal compensation for such officer or employee for work that is not furnished to, not funded by, or not furnished in cooperation with the Federal Government.

"Reasonable payment," as used in this clause, means, with respect to professional and other technical services, a payment in an amount that is consistent with the amount normally paid for such services in the private sector.

"Recipient," as used in this clause, includes the Contractor and all subcontractors. This term excludes an Indian tribe, tribal organization, or any other Indian organization with respect to expenditures specifically permitted by other Federal law.

"Regularly employed," as used in this clause, means, with respect to an officer or employee of a person requesting or receiving a Federal contract, an officer or employee who is employed by such person for at least 130 working days within 1 year immediately preceding the date of the submission that initiates agency consideration of such person for receipt of such contract. An officer or employee who is employed by such person for less than 130 working days within 1 year immediately preceding the date of the submission that initiates agency consideration of such person shall be considered to be regularly employed as soon as he or she is employed by such person for 130 working days.

"State," as used in this clause, means a State of the United States, the District of Columbia, the Commonwealth of Puerto Rico, a territory or possession of the United States, an agency or instrumentality of a State, and multi-State, regional, or interstate entity having governmental duties and powers.

(b) Prohibitions.

(1) Section 1352 of Title 31, United States Code, among other things, prohibits a recipient of a Federal contract, grant, loan, or cooperative agreement from using appropriated funds to pay any person for influencing or attempting to influence an officer or employee of any agency, a Member of Congress, an officer or employee of Congress, or an employee of a Member of Congress in connection with any of the following covered Federal actions: the awarding of any Federal contract; the making of any Federal grant; the making of any Federal loan; the entering into of any cooperative agreement; or the modification of any Federal contract, grant, loan, or cooperative agreement.

(2) The Act also requires Contractors to furnish a disclosure if any funds other than Federal appropriated funds (including profit or fee received under a covered Federal transaction) have been paid, or will be paid, to any person for influencing or attempting to influence an officer or employee of any agency, a Member of Congress, an officer or employee of Congress, or an employee of a Member of Congress in connection with a Federal contract, grant, loan, or cooperative agreement.

(3) The prohibitions of the Act do not apply under the following conditions:

(i) Agency and legislative liaison by own employees.

(A) The prohibition on the use of appropriated funds, in subparagraph (b)(1) of this clause, does not apply in the case of a payment of reasonable compensation made to an officer or employee of a

person requesting or receiving a covered Federal action if the payment is for agency and legislative liaison activities not directly related to a covered Federal action.

(B) For purposes of subdivision (b)(3)(i)(A) of this clause, providing any information specifically requested by an agency or Congress is permitted at any time.

(C) The following agency and legislative liaison activities are permitted at any time where they are not related to a specific solicitation for any covered Federal action:

(1) Discussing with an agency the qualities and characteristics (including individual demonstrations) of the person's products or services, conditions or terms of sale, and service capabilities.

(2) Technical discussions and other activities regarding the application or adaptation of the person's products or services for an agency's use.

(D) The following agency and legislative liaison activities are permitted where they are prior to formal solicitation of any covered Federal action--

(1) Providing any information not specifically requested but necessary for an agency to make an informed decision about initiation of a covered Federal action;

(2) Technical discussions regarding the preparation of an unsolicited proposal prior to its official submission; and

(3) Capability presentations by persons seeking awards from an agency pursuant to the provisions of the Small Business Act, as amended by Pub. L. 95-507, and subsequent amendments.

(E) Only those services expressly authorized by subdivision (b)(3)(i)(A) of this clause are permitted under this clause.

(ii) Professional and technical services.

(A) The prohibition on the use of appropriated funds, in subparagraph (b)(1) of this clause, does not apply in the case of--

(1) A payment of reasonable compensation made to an officer or employee of a person requesting or receiving a covered Federal action or an extension, continuation, renewal, amendment, or modification of a covered Federal action, if payment is for professional or technical services rendered directly in the preparation, submission, or negotiation of any bid, proposal, or application for that Federal action or for meeting requirements imposed by or pursuant to law as a condition for receiving that Federal action.

(2) Any reasonable payment to a person, other than an officer or employee of a person requesting or receiving a covered Federal action or an extension, continuation, renewal, amendment, or modification of a covered Federal action if the payment is for professional or technical services

rendered directly in the preparation, submission, or negotiation of any bid, proposal, or application for that Federal action or for meeting requirements imposed by or pursuant to law as a condition for receiving that Federal action. Persons other than officers or employees of a person requesting or receiving a covered Federal action include consultants and trade associations.

(B) For purposes of subdivision (b)(3)(ii)(A) of this clause, "professional and technical services" shall be limited to advice and analysis directly applying any professional or technical discipline. For example, drafting of a legal document accompanying a bid or proposal by a lawyer is allowable. Similarly, technical advice provided by an engineer on the performance or operational capability of a piece of equipment rendered directly in the negotiation of a contract is allowable. However, communications with the intent to influence made by a professional (such as a licensed lawyer) or a technical person (such as a licensed accountant) are not allowable under this section unless they provide advice and analysis directly applying their professional or technical expertise and unless the advice or analysis is rendered directly and solely in the preparation, submission or negotiation of a covered Federal action. Thus, for example, communications with the intent to influence made by a lawyer that do not provide legal advice or analysis directly and solely related to the legal aspects of his or her client's proposal, but generally advocate one proposal over another are not allowable under this section because the lawyer is not providing professional legal services. Similarly, communications with the intent to influence made by an engineer providing an engineering analysis prior to the preparation or submission of a bid or proposal are not allowable under this section since the engineer is providing technical services but not directly in the preparation, submission or negotiation of a covered Federal action.

(C) Requirements imposed by or pursuant to law as a condition for receiving a covered Federal award include those required by law or regulation and any other requirements in the actual award documents.

(D) Only those services expressly authorized by subdivisions (b)(3)(ii)(A)(1) and (2) of this clause are permitted under this clause.

(E) The reporting requirements of FAR 3.803(a) shall not apply with respect to payments of reasonable compensation made to regularly employed officers or employees of a person.

(c) Disclosure.

(1) The Contractor who requests or receives from an agency a Federal contract shall file with that agency a disclosure form, OMB standard form LLL, Disclosure of Lobbying Activities, if such person has made or has agreed to make any payment using nonappropriated funds (to include profits from any covered Federal action), which would be prohibited under subparagraph (b)(1) of this clause, if paid for with appropriated funds.

(2) The Contractor shall file a disclosure form at the end of each calendar quarter in which there occurs any event that materially affects the accuracy of the information contained in any disclosure form previously filed by such person under subparagraph (c)(1) of this clause. An event that materially affects the accuracy of the information reported includes--

(i) A cumulative increase of \$25,000 or more in the amount paid or expected to be paid for influencing or attempting to influence a covered Federal action; or

(ii) A change in the person(s) or individual(s) influencing or attempting to influence a covered Federal action; or

(iii) A change in the officer(s), employee(s), or Member(s) contacted to influence or attempt to influence a covered Federal action.

(3) The Contractor shall require the submittal of a certification, and if required, a disclosure form by any person who requests or receives any subcontract exceeding \$100,000 under the Federal contract.

(4) All subcontractor disclosure forms (but not certifications) shall be forwarded from tier to tier until received by the prime Contractor. The prime Contractor shall submit all disclosures to the Contracting Officer at the end of the calendar quarter in which the disclosure form is submitted by the subcontractor. Each subcontractor certification shall be retained in the subcontract file of the awarding Contractor.

(d) Agreement. The Contractor agrees not to make any payment prohibited by this clause.

(e) Penalties.

(1) Any person who makes an expenditure prohibited under paragraph (a) of this clause or who fails to file or amend the disclosure form to be filed or amended by paragraph (b) of this clause shall be subject to civil penalties as provided for by 31 U.S.C. 1352. An imposition of a civil penalty does not prevent the Government from seeking any other remedy that may be applicable.

(2) Contractors may rely without liability on the representation made by their subcontractors in the certification and disclosure form.

(f) Cost allowability. Nothing in this clause makes allowable or reasonable any costs which would otherwise be unallowable or unreasonable. Conversely, costs made specifically unallowable by the requirements in this clause will not be made allowable under any other provision.

52.204-4 PRINTED OR COPIED DOUBLE-SIDED ON RECYCLED PAPER (AUG 2000)

(a) Definitions. As used in this clause--

“Postconsumer material” means a material or finished product that has served its intended use and has been discarded for disposal or recovery, having completed its life as a consumer item. Postconsumer material is a part of the broader category of “recovered material.” For paper and paper products, postconsumer material means “postconsumer fiber” defined by the U.S. Environmental Protection Agency (EPA) as--

- (1) Paper, paperboard, and fibrous materials from retail stores, office buildings, homes, and so forth, after they have passed through their end-usage as a consumer item, including: used corrugated boxes; old newspapers; old magazines; mixed waste paper; tabulating cards; and used cordage; or
- (2) All paper, paperboard, and fibrous materials that enter and are collected from municipal solid waste; but not
- (3) Fiber derived from printers' over-runs, converters' scrap, and over-issue publications.

“Printed or copied double-sided” means printing or reproducing a document so that information is on both sides of a sheet of paper.

“Recovered material,” for paper and paper products, is defined by EPA in its Comprehensive Procurement Guideline as “recovered fiber” and means the following materials:

- (1) Postconsumer fiber; and
- (2) Manufacturing wastes such as--
 - (i) Dry paper and paperboard waste generated after completion of the papermaking process (that is, those manufacturing operations up to and including the cutting and trimming of the paper machine reel into smaller rolls or rough sheets) including: envelope cuttings, bindery trimmings, and other paper and paperboard waste resulting from printing, cutting, forming, and other converting operations; bag, box, and carton manufacturing wastes; and butt rolls, mill wrappers, and rejected unused stock; and
 - (ii) Repulped finished paper and paperboard from obsolete inventories of paper and paperboard manufacturers, merchants, wholesalers, dealers, printers, converters, or others.
- (b) In accordance with Section 101 of Executive Order 13101 of September 14, 1998, Greening the Government through Waste Prevention, Recycling, and Federal Acquisition, the Contractor is encouraged to submit paper documents, such as offers, letters, or reports, that are printed or copied double-sided on recycled paper that meet minimum content standards specified in Section 505 of Executive Order 13101, when not using electronic commerce methods to submit information or data to the Government.
- (c) If the Contractor cannot purchase high-speed copier paper, offset paper, forms bond, computer printout paper, carbonless paper, file folders, white wove envelopes, writing and office paper, book paper, cotton fiber paper, and cover stock meeting the 30 percent postconsumer material standard for use in submitting paper documents to the Government, it should use paper containing no less than 20 percent postconsumer material. This lesser standard should be used only when paper meeting the 30 percent postconsumer material standard is not obtainable at a reasonable price or does not meet reasonable performance standards.

2.209-6 PROTECTING THE GOVERNMENT'S INTEREST WHEN SUBCONTRACTING WITH CONTRACTORS DEBARRED, SUSPENDED, OR PROPOSED FOR DEBARMENT (JUL 1995)

(a) The Government suspends or debar Contractors to protect the Government's interests. The Contractor shall not enter into any subcontract in excess of the \$25,000 with a Contractor that is debarred, suspended, or proposed for debarment unless there is a compelling reason to do so.

(b) The Contractor shall require each proposed first-tier subcontractor, whose subcontract will exceed \$25,000, to disclose to the Contractor, in writing, whether as of the time of award of the subcontract, the subcontractor, or its principals, is or is not debarred, suspended, or proposed for debarment by the Federal Government.

(c) A corporate officer or a designee of the Contractor shall notify the Contracting Officer, in writing, before entering into a subcontract with a party that is debarred, suspended, or proposed for debarment (see FAR 9.404 for information on the List of Parties Excluded from Federal Procurement and Nonprocurement Programs). The notice must include the following:

(1) The name of the subcontractor.

(2) The Contractor's knowledge of the reasons for the subcontractor being on the List of Parties Excluded from Federal Procurement and Nonprocurement Programs.

(3) The compelling reason(s) for doing business with the subcontractor notwithstanding its inclusion on the List of Parties Excluded from Federal Procurement and Nonprocurement Programs.

(4) The systems and procedures the Contractor has established to ensure that it is fully protecting the Government's interests when dealing with such subcontractor in view of the specific basis for the party's debarment, suspension, or proposed debarment.

52.211-13 TIME EXTENSIONS (SEP 2000)

Time extensions for contract changes will depend upon the extent, if any, by which the changes cause delay in the completion of the various elements of construction. The change order granting the time extension may provide that the contract completion date will be extended only for those specific elements related to the changed work and that the remaining contract completion dates for all other portions of the work will not be altered. The change order also may provide an equitable readjustment of liquidated damages under the new completion schedule.

52.211-18 VARIATION IN ESTIMATED QUANTITY (APR 1984)

If the quantity of a unit-priced item in this contract is an estimated quantity and the actual quantity of the unit-priced item varies more than 15 percent above or below the estimated quantity, an equitable adjustment in the contract price shall be made upon demand of either party. The equitable

adjustment shall be based upon any increase or decrease in costs due solely to the variation above 115 percent or below 85 percent of the estimated quantity. If the quantity variation is such as to cause an increase in the time necessary for completion, the Contractor may request, in writing, an extension of time, to be received by the Contracting Officer within 10 days from the beginning of the delay, or within such further period as may be granted by the Contracting Officer before the date of final settlement of the contract. Upon the receipt of a written request for an extension, the Contracting Officer shall ascertain the facts and make an adjustment for extending the completion date as, in the judgement of the Contracting Officer, is justified.

52.214-29 ORDER OF PRECEDENCE--SEALED BIDDING (JAN 1986)

Any inconsistency in this solicitation or contract shall be resolved by giving precedence in the following order: (a) the Schedule (excluding the specifications); (b) representations and other instructions; (c) contract clauses; (d) other documents, exhibits, and attachments; and (e) the specifications.

52.219-4 NOTICE OF PRICE EVALUATION PREFERENCE FOR HUBZONE SMALL BUSINESS CONCERNS (JAN 1999)

(a) Definition. HUBZone small business concern, as used in this clause, means a small business concern that appears on the List of Qualified HUBZone Small Business Concerns maintained by the Small Business Administration.

(b) Evaluation preference. (1) Offers will be evaluated by adding a factor of 10 percent to the price of all offers, except--

(i) Offers from HUBZone small business concerns that have not waived the evaluation preference;

(ii) Otherwise successful offers from small business concerns;

(iii) Otherwise successful offers of eligible products under the Trade Agreements Act when the dollar threshold for application of the Act is exceeded (see 25.402 of the Federal Acquisition Regulation (FAR)); and

(iv) Otherwise successful offers where application of the factor would be inconsistent with a Memorandum of Understanding or other international agreement with a foreign government.

(2) The factor of 10 percent shall be applied on a line item basis or to any group of items on which award may be made. Other evaluation factors described in the solicitation shall be applied before application of the factor.

(3) A concern that is both a HUBZone small business concern and a small disadvantaged business concern will receive the benefit of both the HUBZone small business price evaluation preference and the small disadvantaged business price evaluation adjustment (see FAR clause 52.219-23).

Each applicable price evaluation preference or adjustment shall be calculated independently against an offeror's base offer.

These individual preference amounts shall be added together to arrive at the total evaluated price for that offer.

(c) Waiver of evaluation preference. A HUBZone small business concern may elect to waive the evaluation preference, in which case the factor will be added to its offer for evaluation purposes. The agreements in paragraph (d) of this clause do not apply if the offeror has waived the evaluation preference.

___ Offeror elects to waive the evaluation preference.

(d) Agreement. A HUBZone small business concern agrees that in the performance of the contract, in the case of a contract for

(1) Services (except construction), at least 50 percent of the cost of personnel for contract performance will be spent for employees of the concern or employees of other HUBZone small business concerns;

(2) Supplies (other than procurement from a nonmanufacturer of such supplies), at least 50 percent of the cost of manufacturing, excluding the cost of materials, will be performed by the concern or other HUBZone small business concerns;

(3) General construction, at least 15 percent of the cost of the contract performance incurred for personnel will be spent on the concern's employees or the employees of other HUBZone small business concerns; or

(4) Construction by special trade contractors, at least 25 percent of the cost of the contract performance incurred for personnel will be spent on the concern's employees or the employees of other HUBZone small business concerns.

(e) A HUBZone joint venture agrees that in the performance of the contract, the applicable percentage specified in paragraph (d) of this clause will be performed by the HUBZone small business participant or participants.

(f) A HUBZone small business concern nonmanufacturer agrees to furnish in performing this contract only end items manufactured or produced by HUBZone small business manufacturer concerns. This paragraph does not apply in connection with construction or service contracts.

52.219-8 UTILIZATION OF SMALL BUSINESS CONCERNS (OCT 2000)

(a) It is the policy of the United States that small business concerns, veteran-owned small business concerns, service-disabled veteran-owned small business concerns, HUBZone small business concerns, small disadvantaged business concerns, and women-owned small business concerns shall

have the maximum practicable opportunity to participate in performing contracts let by any Federal agency, including contracts and subcontracts for subsystems, assemblies, components, and related services for major systems. It is further the policy of the United States that its prime contractors establish procedures to ensure the timely payment of amounts due pursuant to the terms of their subcontracts with small business concerns, veteran-owned small business concerns, service-disabled veteran-owned small business concerns, HUBZone small business concerns, small disadvantaged business concerns, and women-owned small business concerns.

(b) The Contractor hereby agrees to carry out this policy in the awarding of subcontracts to the fullest extent consistent with efficient contract performance. The Contractor further agrees to cooperate in any studies or surveys as may be conducted by the United States Small Business Administration or the awarding agency of the United States as may be necessary to determine the extent of the Contractor's compliance with this clause.

Definitions. As used in this contract--

HUBZone small business concern means a small business concern that appears on the List of Qualified HUBZone Small Business Concerns maintained by the Small Business Administration.

Service-disabled veteran-owned small business concern--

(1) Means a small business concern--

(i) Not less than 51 percent of which is owned by one or more service-disabled veterans or, in the case of any publicly owned business, not less than 51 percent of the stock of which is owned by one or more service-disabled veterans; and

(ii) The management and daily business operations of which are controlled by one or more service-disabled veterans or, in the case of a veteran with permanent and severe disability, the spouse or permanent caregiver of such veteran.

(2) Service-disabled veteran means a veteran, as defined in 38 U.S.C. 101(2), with a disability that is service-connected, as defined in 38 U.S.C. 101(16).

Small business concern means a small business as defined pursuant to Section 3 of the Small Business Act and relevant regulations promulgated pursuant thereto.

Small disadvantaged business concern means a small business concern that represents, as part of its offer that--

(1) It has received certification as a small disadvantaged business concern consistent with 13 CFR part 124, subpart B;

(2) No material change in disadvantaged ownership and control has occurred since its certification;

(3) Where the concern is owned by one or more individuals, the net worth of each individual upon whom the certification is based does not exceed \$750,000 after taking into account the applicable exclusions set forth at 13 CFR 124.104(c)(2); and

(4) It is identified, on the date of its representation, as a certified small disadvantaged business in the database maintained by the Small Business Administration (PRO-Net).

Veteran-owned small business concern means a small business concern--

(1) Not less than 51 percent of which is owned by one or more veterans (as defined at 38 U.S.C. 101(2)) or, in the case of any publicly owned business, not less than 51 percent of the stock of which is owned by one or more veterans; and

(2) The management and daily business operations of which are controlled by one or more veterans.

Women-owned small business concern means a small business concern--

(1) That is at least 51 percent owned by one or more women, or, in the case of any publicly owned business, at least 51 percent of the stock of which is owned by one or more women; and

(2) Whose management and daily business operations are controlled by one or more women.

(d) Contractors acting in good faith may rely on written representations by their subcontractors regarding their status as a small business concern, a veteran-owned small business concern, a service-disabled veteran-owned small business concern, a HUBZone small business concern, a small disadvantaged business concern, or a women-owned small business concern.

52.222-1 NOTICE TO THE GOVERNMENT OF LABOR DISPUTES (FEB 1997)

If the Contractor has knowledge that any actual or potential labor dispute is delaying or threatens to delay the timely performance of this contract, the Contractor shall immediately give notice, including all relevant information, to the Contracting Officer.

52.222-3 CONVICT LABOR (AUG 1996)

The Contractor agrees not to employ in the performance of this contract any person undergoing a sentence of imprisonment which has been imposed by any court of a State, the District of Columbia, the Commonwealth of Puerto Rico, the Virgin Islands, Guam, American Samoa, the Commonwealth of the Northern Mariana Islands, or the Trust Territory of the Pacific Islands. This limitation, however, shall not prohibit the employment by the Contractor in the performance of this contract of persons on parole or probation to work at paid employment during the term of their sentence or persons who have been pardoned or who have served their terms. Nor shall it prohibit the employment by the Contractor in the performance of this contract of persons confined for violation of the laws of any of the States, the District of Columbia, the Commonwealth of Puerto

Rico, the Virgin Islands, Guam, American Samoa, the Commonwealth of the Northern Mariana Islands, or the Trust Territory of the Pacific Islands who are authorized to work at paid employment in the community under the laws of such jurisdiction, if--

- (a)(1) The worker is paid or is in an approved work training program on a voluntary basis;
 - (2) Representatives of local union central bodies or similar labor union organizations have been consulted;
 - (3) Such paid employment will not result in the displacement of employed workers, or be applied in skills, crafts, or trades in which there is a surplus of available gainful labor in the locality, or impair existing contracts for services; and
 - (4) The rates of pay and other conditions of employment will not be less than those paid or provided for work of a similar nature in the locality in which the work is being performed; and
- (b) The Attorney General of the United States has certified that the work-release laws or regulations of the jurisdiction involved are in conformity with the requirements of Executive Order 11755, as amended by Executive Orders 12608 and 12943.

52.222-4 CONTRACT WORK HOURS AND SAFETY STANDARDS ACT - OVERTIME COMPENSATION. (SEP 2000)

- (a) Overtime requirements. No Contractor or subcontractor employing laborers or mechanics (see Federal Acquisition Regulation 22.300) shall require or permit them to work over 40 hours in any workweek unless they are paid at least 1 and 1/2 times the basic rate of pay for each hour worked over 40 hours.
- (b) Violation; liability for unpaid wages; liquidated damages. The responsible Contractor and subcontractor are liable for unpaid wages if they violate the terms in paragraph (a) of this clause. In addition, the Contractor and subcontractor are liable for liquidated damages payable to the Government. The Contracting Officer will assess liquidated damages at the rate of \$10 per affected employee for each calendar day on which the employer required or permitted the employee to work in excess of the standard workweek of 40 hours without paying overtime wages required by the Contract Work Hours and Safety Standards Act.
- (c) Withholding for unpaid wages and liquidated damages. The Contracting Officer will withhold from payments due under the contract sufficient funds required to satisfy any Contractor or subcontractor liabilities for unpaid wages and liquidated damages. If amounts withheld under the contract are insufficient to satisfy Contractor or subcontractor liabilities, the Contracting Officer will withhold payments from other Federal or Federally assisted contracts held by the same Contractor that are subject to the Contract Work Hours and Safety Standards Act.
- (d) Payrolls and basic records.

(1) The Contractor and its subcontractors shall maintain payrolls and basic payroll records for all laborers and mechanics working on the contract during the contract and shall make them available to the Government until 3 years after contract completion. The records shall contain the name and address of each employee, social security number, labor classifications, hourly rates of wages paid, daily and weekly number of hours worked, deductions made, and actual wages paid. The records need not duplicate those required for construction work by Department of Labor regulations at 29 CFR 5.5(a)(3) implementing the Davis-Bacon Act.

(2) The Contractor and its subcontractors shall allow authorized representatives of the Contracting Officer or the Department of Labor to inspect, copy, or transcribe records maintained under paragraph (d)(1) of this clause. The Contractor or subcontractor also shall allow authorized representatives of the Contracting Officer or Department of Labor to interview employees in the workplace during working hours.

(e) Subcontracts. The Contractor shall insert the provisions set forth in paragraphs (a) through (d) of this clause in subcontracts exceeding \$100,000 and require subcontractors to include these provisions in any lower tier subcontracts. The Contractor shall be responsible for compliance by any subcontractor or lower-tier subcontractor with the provisions set forth in paragraphs (a) through (d) of this clause.

52.222-6 DAVIS-BACON ACT (FEB 1995)

(a) All laborers and mechanics employed or working upon the site of the work will be paid unconditionally and not less often than once a week, and without subsequent deduction or rebate on any account (except such payroll deductions as are permitted by regulations issued by the Secretary of Labor under the Copeland Act (29 CFR Part 3), the full amount of wages and bona fide fringe benefits (or cash equivalents thereof) due at time of payment computed at rates not less than those contained in the wage determination of the Secretary of Labor which is attached hereto and made a part hereof, regardless of any contractual relationship which may be alleged to exist between the Contractor and such laborers and mechanics. Contributions made or costs reasonably anticipated for bona fide fringe benefits under section 1(b)(2) of the Davis-Bacon Act on behalf of laborers or mechanics are considered wages paid to such laborers or mechanics, subject to the provisions of paragraph (d) of this clause; also, regular contributions made or costs incurred for more than a weekly period (but not less often than quarterly) under plans, funds, or programs which cover the particular weekly period, are deemed to be constructively made or incurred during such period. Such laborers and mechanics shall be paid not less than the appropriate wage rate and fringe benefits in the wage determination for the classification of work actually performed, without regard to skill, except as provided in the clause entitled Apprentices and Trainees. Laborers or mechanics performing work in more than one classification may be compensated at the rate specified for each classification for the time actually worked therein; provided, That the employer's payroll records accurately set forth the time spent in each classification in which work is performed. The wage determination (including any additional classifications and wage rates conformed under paragraph (b) of this clause) and the Davis-Bacon poster (WH-1321) shall be posted at all times by the Contractor and its subcontractors at the site of the work in a prominent and accessible place where it can be easily seen by the workers.

(b)(1) The Contracting Officer shall require that any class of laborers or mechanics which is not listed in the wage determination and which is to be employed under the contract shall be classified in conformance with the wage determination. The Contracting Officer shall approve an additional classification and wage rate and fringe benefits therefor only when all the following criteria have been met:

(i) The work to be performed by the classification requested is not performed by a classification in the wage determination.

(ii) The classification is utilized in the area by the construction industry.

(iii) The proposed wage rate, including any bona fide fringe benefits, bears a reasonable relationship to the wage rates contained in the wage determination.

(2) If the Contractor and the laborers and mechanics to be employed in the classification (if known), or their representatives, and the Contracting Officer agree on the classification and wage rate (including the amount designated for fringe benefits, where appropriate), a report of the action taken shall be sent by the Contracting Officer to the Administrator of the Wage and Hour Division, Employment Standards Administration, U.S. Department of Labor, Washington, DC 20210. The Administrator or an authorized representative will approve, modify, or disapprove every additional classification action within 30 days of receipt and so advise the Contracting Officer or will notify the Contracting Officer within the 30-day period that additional time is necessary.

(3) In the event the Contractor, the laborers or mechanics to be employed in the classification, or their representatives, and the Contracting Officer do not agree on the proposed classification and wage rate (including the amount designated for fringe benefits, where appropriate), the Contracting Officer shall refer the questions, including the views of all interested parties and the recommendation of the Contracting Officer, to the Administrator of the Wage and Hour Division for determination. The Administrator, or an authorized representative, will issue a determination within 30 days of receipt and so advise the Contracting Officer or will notify the Contracting Officer within the 30-day period that additional time is necessary.

(4) The wage rate (including fringe benefits, where appropriate) determined pursuant to subparagraphs (b)(2) and (b)(3) of this clause shall be paid to all workers performing work in the classification under this contract from the first day on which work is performed in the classification.

(c) Whenever the minimum wage rate prescribed in the contract for a class of laborers or mechanics includes a fringe benefit which is not expressed as an hourly rate, the Contractor shall either pay the benefit as stated in the wage determination or shall pay another bona fide fringe benefit or an hourly cash equivalent thereof.

(d) If the Contractor does not make payments to a trustee or other third person, the Contractor may consider as part of the wages of any laborer or mechanic the amount of any costs reasonably anticipated in providing bona fide fringe benefits under a plan or program; provided, That the Secretary of Labor has found, upon the written request of the Contractor, that the applicable

standards of the Davis-Bacon Act have been met. The Secretary of Labor may require the Contractor to set aside in a separate account assets for the meeting of obligations under the plan or program.

52.222-7 WITHHOLDING OF FUNDS (FEB 1988)

The Contracting Officer shall, upon his or her own action or upon written request of an authorized representative of the Department of Labor, withhold or cause to be withheld from the Contractor under this contract or any other Federal contract with the same Prime Contractor, or any other Federally assisted contract subject to Davis-Bacon prevailing wage requirements, which is held by the same Prime Contractor, so much of the accrued payments or advances as may be considered necessary to pay laborers and mechanics, including apprentices, trainees, and helpers, employed by the Contractor or any subcontractor the full amount of wages required by the contract. In the event of failure to pay any laborer or mechanic, including any apprentice, trainee, or helper, employed or working on the site of the work, all or part of the wages required by the contract, the Contracting Officer may, after written notice to the Contractor, take such action as may be necessary to cause the suspension of any further payment, advance, or guarantee of funds until such violations have ceased.

52.222-8 PAYROLLS AND BASIC RECORDS (FEB 1988)

(a) Payrolls and basic records relating thereto shall be maintained by the Contractor during the course of the work and preserved for a period of 3 years thereafter for all laborers and mechanics working at the site of the work. Such records shall contain the name, address, and social security number of each such worker, his or her correct classification, hourly rates of wages paid (including rates of contributions or costs anticipated for bona fide fringe benefits or cash equivalents thereof of the types described in section 1(b)(2)(B) of the Davis-Bacon Act), daily and weekly number of hours worked, deductions made, and actual wages paid. Whenever the Secretary of Labor has found, under paragraph (d) of the clause entitled Davis-Bacon Act, that the wages of any laborer or mechanic include the amount of any costs reasonably anticipated in providing benefits under a plan or program described in section 1(b)(2)(B) of the Davis-Bacon Act, the Contractor shall maintain records which show that the commitment to provide such benefits is enforceable, that the plan or program is financially responsible, and that the plan or program has been communicated in writing to the laborers or mechanics affected, and records which show the costs anticipated or the actual cost incurred in providing such benefits. Contractors employing apprentices or trainees under approved programs shall maintain written evidence of the registration of apprenticeship programs and certification of trainee programs, the registration of the apprentices and trainees, and the ratios and wage rates prescribed in the applicable programs.

(b)(1) The Contractor shall submit weekly for each week in which any contract work is performed a copy of all payrolls to the Contracting Officer. The payrolls submitted shall set out accurately and completely all of the information required to be maintained under paragraph (a) of this clause. This information may be submitted in any form desired. Optional Form WH-347 (Federal Stock Number 029-005-00014-1) is available for this purpose and may be purchased from the Superintendent of

Documents, U.S. Government Printing Office, Washington, DC 20402. The Prime Contractor is responsible for the submission of copies of payrolls by all subcontractors.

(2) Each payroll submitted shall be accompanied by a "Statement of Compliance," signed by the Contractor or subcontractor or his or her agent who pays or supervises the payment of the persons employed under the contract and shall certify--

(i) That the payroll for the payroll period contains the information required to be maintained under paragraph (a) of this clause and that such information is correct and complete;

(ii) That each laborer or mechanic (including each helper, apprentice, and trainee) employed on the contract during the payroll period has been paid the full weekly wages earned, without rebate, either directly or indirectly, and that no deductions have been made either directly or indirectly from the full wages earned, other than permissible deductions as set forth in the Regulations, 29 CFR Part 3; and

(iii) That each laborer or mechanic has been paid not less than the applicable wage rates and fringe benefits or cash equivalents for the classification of work performed, as specified in the applicable wage determination incorporated into the contract.

(3) The weekly submission of a properly executed certification set forth on the reverse side of Optional Form WH-347 shall satisfy the requirement for submission of the "Statement of Compliance" required by subparagraph (b)(2) of this clause.

(4) The falsification of any of the certifications in this clause may subject the Contractor or subcontractor to civil or criminal prosecution under Section 1001 of Title 18 and Section 3729 of Title 31 of the United States Code.

(c) The Contractor or subcontractor shall make the records required under paragraph (a) of this clause available for inspection, copying, or transcription by the Contracting Officer or authorized representatives of the Contracting Officer or the Department of Labor. The Contractor or subcontractor shall permit the Contracting Officer or representatives of the Contracting Officer or the Department of Labor to interview employees during working hours on the job. If the Contractor or subcontractor fails to submit required records or to make them available, the Contracting Officer may, after written notice to the Contractor, take such action as may be necessary to cause the suspension of any further payment. Furthermore, failure to submit the required records upon request or to make such records available may be grounds for debarment action pursuant to 29 CFR 5.12.

52.222-9 APPRENTICES AND TRAINEES (FEB 1988)

(a) Apprentices. Apprentices will be permitted to work at less than the predetermined rate for the work they performed when they are employed pursuant to and individually registered in a bona fide apprenticeship program registered with the U.S. Department of Labor, Employment and Training Administration, Bureau of Apprenticeship and Training, or with a State Apprenticeship Agency

recognized by the Bureau, or if a person is employed in his or her first 90 days of probationary employment as an apprentice in such an apprenticeship program, who is not individually registered in the program, but who has been certified by the Bureau of Apprenticeship and Training or a State Apprenticeship Agency (where appropriate) to be eligible for probationary employment as an apprentice. The allowable ratio of apprentices to journeymen on the job site in any craft classification shall not be greater than the ratio permitted to the Contractor as to the entire work force under the registered program. Any worker listed on a payroll at an apprentice wage rate, who is not registered or otherwise employed as stated in this paragraph, shall be paid not less than the applicable wage determination for the classification of work actually performed. In addition, any apprentice performing work on the job site in excess of the ratio permitted under the registered program shall be paid not less than the applicable wage rate on the wage determination for the work actually performed. Where a contractor is performing construction on a project in a locality other than that in which its program is registered, the ratios and wage rates (expressed in percentages of the journeyman's hourly rate) specified in the Contractor's or subcontractor's registered program shall be observed. Every apprentice must be paid at not less than the rate specified in the registered program for the apprentice's level of progress, expressed as a percentage of the journeyman hourly rate specified in the applicable wage determination. Apprentices shall be paid fringe benefits in accordance with the provisions of the apprenticeship program. If the apprenticeship program does not specify fringe benefits, apprentices must be paid the full amount of fringe benefits listed on the wage determination for the applicable classification. If the Administrator determines that a different practice prevails for the applicable apprentice classification, fringes shall be paid in accordance with that determination. In the event the Bureau of Apprenticeship and Training, or a State Apprenticeship Agency recognized by the Bureau, withdraws approval of an apprenticeship program, the Contractor will no longer be permitted to utilize apprentices at less than the applicable predetermined rate for the work performed until an acceptable program is approved.

(b) Trainees. Except as provided in 29 CFR 5.16, trainees will not be permitted to work at less than the predetermined rate for the work performed unless they are employed pursuant to and individually registered in a program which has received prior approval, evidenced by formal certification by the U.S. Department of Labor, Employment and Training Administration. The ratio of trainees to journeymen on the job site shall not be greater than permitted under the plan approved by the Employment and Training Administration. Every trainee must be paid at not less than the rate specified in the approved program for the trainee's level of progress, expressed as a percentage of the journeyman hourly rate specified in the applicable wage determination. Trainees shall be paid fringe benefits in accordance with the provisions of the trainee program. If the trainee program does not mention fringe benefits, trainees shall be paid the full amount of fringe benefits listed in the wage determination unless the Administrator of the Wage and Hour Division determines that there is an apprenticeship program associated with the corresponding journeyman wage rate in the wage determination which provides for less than full fringe benefits for apprentices. Any employee listed on the payroll at a trainee rate who is not registered and participating in a training plan approved by the Employment and Training Administration shall be paid not less than the applicable wage rate in the wage determination for the classification of work actually performed. In addition, any trainee performing work on the job site in excess of the ratio permitted under the registered program shall be paid not less than the applicable wage rate in the wage determination for the work actually performed. In the event the Employment and Training Administration withdraws approval of a training program, the Contractor will no longer be permitted to utilize trainees at less than the

applicable predetermined rate for the work performed until an acceptable program is approved.

(c) Equal employment opportunity. The utilization of apprentices, trainees, and journeymen under this clause shall be in conformity with the equal employment opportunity requirements of Executive Order 11246, as amended, and 29 CFR Part 30.

52.222-10 COMPLIANCE WITH COPELAND ACT REQUIREMENTS (FEB 1988)

The Contractor shall comply with the requirements of 29 CFR Part 3, which are hereby incorporated by reference in this contract.

52.222-11 SUBCONTRACTS (LABOR STANDARDS (FEB 1988)

(a) The Contractor or subcontractor shall insert in any subcontracts the clauses entitled Davis-Bacon Act, Contract Work Hours and Safety Standards Act-Overtime Compensation, Apprentices and Trainees, Payrolls and Basic Records, Compliance with Copeland Act Requirements, Withholding of Funds, Subcontracts (Labor Standards), Contract Termination-Debarment, Disputes Concerning Labor Standards, Compliance with Davis-Bacon and Related Act Regulations, and Certification of Eligibility, and such other clauses as the Contracting Officer may, by appropriate instructions, require, and also a clause requiring subcontractors to include these clauses in any lower tier subcontracts. The Prime Contractor shall be responsible for compliance by any subcontractor or lower tier subcontractor with all the contract clauses cited in this paragraph.

(b)(1) Within 14 days after award of the contract, the Contractor shall deliver to the Contracting Officer a completed Statement and Acknowledgment Form (SF 1413) for each subcontract, including the subcontractor's signed and dated acknowledgment that the clauses set forth in paragraph (a) of this clause have been included in the subcontract.

(2) Within 14 days after the award of any subsequently awarded subcontract the Contractor shall deliver to the Contracting Officer an updated completed SF 1413 for such additional subcontract.

52.222-12 CONTRACT TERMINATION--DEBARMENT (FEB 1988)

A breach of the contract clauses entitled Davis-Bacon Act, Contract Work Hours and Safety Standards Act--Overtime Compensation, Apprentices and Trainees, Payrolls and Basic Records, Compliance with Copeland Act Requirements, Subcontracts (Labor Standards), Compliance with Davis-Bacon and Related Act Regulations, or Certification of Eligibility may be grounds for termination of the contract, and for debarment as a Contractor and subcontractor as provided in 29 CFR 5.12.

52.222-13 COMPLIANCE WITH DAVIS-BACON AND RELATED ACT REGULATIONS
(FEB 1988)

All rulings and interpretations of the Davis-Bacon and Related Acts contained in 29 CFR Parts 1, 3, and 5 are hereby incorporated by reference in this contract.

52.222-14 DISPUTES CONCERNING LABOR STANDARDS (FEB 1988)

The United States Department of Labor has set forth in 29 CFR Parts 5, 6, and 7 procedures for resolving disputes concerning labor standards requirements. Such disputes shall be resolved in accordance with those procedures and not the Disputes clause of this contract. Disputes within the meaning of this clause include disputes between the Contractor (or any of its subcontractors) and the contracting agency, the U.S. Department of Labor, or the employees or their representatives.

52.222-15 CERTIFICATION OF ELIGIBILITY (FEB 1988)

(a) By entering into this contract, the Contractor certifies that neither it (nor he or she) nor any person or firm who has an interest in the Contractor's firm is a person or firm ineligible to be awarded Government contracts by virtue of section 3(a) of the Davis-Bacon Act or 29 CFR 5.12(a)(1).

(b) No part of this contract shall be subcontracted to any person or firm ineligible for award of a Government contract by virtue of section 3(a) of the Davis-Bacon Act or 29 CFR 5.12(a)(1).

(c) The penalty for making false statements is prescribed in the U.S. Criminal Code, 18 U.S.C. 1001.

52.222-21 PROHIBITION OF SEGREGATED FACILITIES (FEB 1999)

(a) Segregated facilities, as used in this clause, means any waiting rooms, work areas, rest rooms and wash rooms, restaurants and other eating areas, time clocks, locker rooms and other storage or dressing areas, parking lots, drinking fountains, recreation or entertainment areas, transportation, and housing facilities provided for employees, that are segregated by explicit directive or are in fact segregated on the basis of race, color, religion, sex, or national origin because of written or oral policies or employee custom. The term does not include separate or single-user rest rooms or necessary dressing or sleeping areas provided to assure privacy between the sexes.

(b) The Contractor agrees that it does not and will not maintain or provide for its employees any segregated facilities at any of its establishments, and that it does not and will not permit its employees to perform their services at any location under its control where segregated facilities are maintained. The Contractor agrees that a breach of this clause is a violation of the Equal Opportunity clause in this contract.

(c) The Contractor shall include this clause in every subcontract and purchase order that is subject to the Equal Opportunity clause of this contract.

52.222-23 NOTICE OF REQUIREMENT FOR AFFIRMATIVE ACTION TO ENSURE EQUAL EMPLOYMENT OPPORTUNITY FOR CONSTRUCTION (FEB 1999)

(a) The offeror's attention is called to the Equal Opportunity clause and the Affirmative Action Compliance Requirements for Construction clause of this solicitation.

(b) The goals for minority and female participation, expressed in percentage terms for the Contractor's aggregate workforce in each trade on all construction work in the covered area, are as follows:

Goals for minority participation for each trade	Goals for female participation for each trade
1.6 %	6.9 %

These goals are applicable to all the Contractor's construction work performed in the covered area. If the Contractor performs construction work in a geographical area located outside of the covered area, the Contractor shall apply the goals established for the geographical area where the work is actually performed. Goals are published periodically in the Federal Register in notice form, and these notices may be obtained from any Office of Federal Contract Compliance Programs office.

(c) The Contractor's compliance with Executive Order 11246, as amended, and the regulations in 41 CFR 60-4 shall be based on (1) its implementation of the Equal Opportunity clause, (2) specific affirmative action obligations required by the clause entitled "Affirmative Action Compliance Requirements for Construction," and (3) its efforts to meet the goals. The hours of minority and female employment and training must be substantially uniform throughout the length of the contract, and in each trade. The Contractor shall make a good faith effort to employ minorities and women evenly on each of its projects. The transfer of minority or female employees or trainees from Contractor to Contractor, or from project to project, for the sole purpose of meeting the Contractor's goals shall be a violation of the contract, Executive Order 11246, as amended, and the regulations in 41 CFR 60-4. Compliance with the goals will be measured against the total work hours performed.

(d) The Contractor shall provide written notification to the Deputy Assistant Secretary for Federal Contract Compliance, U.S. Department of Labor, within 10 working days following award of any construction subcontract in excess of \$10,000 at any tier for construction work under the contract resulting from this solicitation. The notification shall list the --

(1) Name, address, and telephone number of the subcontractor;

- (2) Employer's identification number of the subcontractor;
 - (3) Estimated dollar amount of the subcontract;
 - (4) Estimated starting and completion dates of the subcontract; and
 - (5) Geographical area in which the subcontract is to be performed.
- (e) As used in this Notice, and in any contract resulting from this solicitation, the "covered area" is:

CARBON COUNTY

52.222-26 EQUAL OPPORTUNITY (APR 2002)

(a) Definition. United States, as used in this clause, means the 50 States, the District of Columbia, Puerto Rico, the Northern Mariana Islands, American Samoa, Guam, the U.S. Virgin Islands, and Wake Island.

(b) If, during any 12-month period (including the 12 months preceding the award of this contract), the Contractor has been or is awarded nonexempt Federal contracts and/or subcontracts that have an aggregate value in excess of \$10,000, the Contractor shall comply with paragraphs (b)(1) through (b)(11) of this clause, except for work performed outside the United States by employees who were not recruited within the United States. Upon request, the Contractor shall provide information necessary to determine the applicability of this clause.

(1) The Contractor shall not discriminate against any employee or applicant for employment because of race, color, religion, sex, or national origin. However, it shall not be a violation of this clause for the Contractor to extend a publicly announced preference in employment to Indians living on or near an Indian reservation, in connection with employment opportunities on or near an Indian reservation, as permitted by 41 CFR 60-1.5.

(2) The Contractor shall take affirmative action to ensure that applicants are employed, and that employees are treated during employment, without regard to their race, color, religion, sex, or national origin. This shall include, but not be limited to, (i) employment, (ii) upgrading, (iii) demotion, (iv) transfer, (v) recruitment or recruitment advertising, (vi) layoff or termination, (vii) rates of pay or other forms of compensation, and (viii) selection for training, including apprenticeship.

(3) The Contractor shall post in conspicuous places available to employees and applicants for employment the notices to be provided by the Contracting Officer that explain this clause.

(4) The Contractor shall, in all solicitations or advertisements for employees placed by or on behalf of the Contractor, state that all qualified applicants will receive consideration for employment without regard to race, color, religion, sex, or national origin.

(5) The Contractor shall send, to each labor union or representative of workers with which it has a

collective bargaining agreement or other contract or understanding, the notice to be provided by the Contracting Officer advising the labor union or workers' representative of the Contractor's commitments under this clause, and post copies of the notice in conspicuous places available to employees and applicants for employment.

(6) The Contractor shall comply with Executive Order 11246, as amended, and the rules, regulations, and orders of the Secretary of Labor.

(7) The Contractor shall furnish to the contracting agency all information required by Executive Order 11246, as amended, and by the rules, regulations, and orders of the Secretary of Labor. The Contractor shall also file Standard Form 100 (EEO-1), or any successor form, as prescribed in 41 CFR part 60-1. Unless the Contractor has filed within the 12 months preceding the date of contract award, the Contractor shall, within 30 days after contract award, apply to either the regional Office of Federal Contract Compliance Programs (OFCCP) or the local office of the Equal Employment Opportunity Commission for the necessary forms.

(8) The Contractor shall permit access to its premises, during normal business hours, by the contracting agency or the OFCCP for the purpose of conducting on-site compliance evaluations and complaint investigations. The Contractor shall permit the Government to inspect and copy any books, accounts, records (including computerized records), and other material that may be relevant to the matter under investigation and pertinent to compliance with Executive Order 11246, as amended, and rules and regulations that implement the Executive Order.

(9) If the OFCCP determines that the Contractor is not in compliance with this clause or any rule, regulation, or order of the Secretary of Labor, this contract may be canceled, terminated, or suspended in whole or in part and the Contractor may be declared ineligible for further Government contracts, under the procedures authorized in Executive Order 11246, as amended. In addition, sanctions may be imposed and remedies invoked against the Contractor as provided in Executive Order 11246, as amended; in the rules, regulations, and orders of the Secretary of Labor; or as otherwise provided by law.

(10) The Contractor shall include the terms and conditions of subparagraphs (b)(1) through (11) of this clause in every subcontract or purchase order that is not exempted by the rules, regulations, or orders of the Secretary of Labor issued under Executive Order 11246, as amended, so that these terms and conditions will be binding upon each subcontractor or vendor.

(11) The Contractor shall take such action with respect to any subcontract or purchase order as the contracting officer may direct as a means of enforcing these terms and conditions, including sanctions for noncompliance; provided, that if the Contractor becomes involved in, or is threatened with, litigation with a subcontractor or vendor as a result of any direction, the Contractor may request the United States to enter into the litigation to protect the interests of the United States.

(c) Notwithstanding any other clause in this contract, disputes relative to this clause will be governed by the procedures in 41 CFR 60-1.1.

CONSTRUCTION (FEB 1999)

(a) Definitions. "Covered area," as used in this clause, means the geographical area described in the solicitation for this contract.

"Deputy Assistant Secretary," as used in this clause, means Deputy Assistant Secretary for Federal Contract Compliance, U.S. Department of Labor, or a designee.

"Employer's identification number," as used in this clause, means the Federal Social Security number used on the employer's quarterly federal tax return, U.S. Treasury Department Form 941.

"Minority," as used in this clause, means--

(1) American Indian or Alaskan Native (all persons having origins in any of the original peoples of North America and maintaining identifiable tribal affiliations through membership and participation or community identification).

(2) Asian and Pacific Islander (all persons having origins in any of the original peoples of the Far East, Southeast Asia, the Indian Subcontinent, or the Pacific Islands);

(3) Black (all persons having origins in any of the black African racial groups not of Hispanic origin); and

(4) Hispanic (all persons of Mexican, Puerto Rican, Cuban, Central or South American, or other Spanish culture or origin, regardless of race).

(b) If the Contractor, or a subcontractor at any tier, subcontracts a portion of the work involving any construction trade, each such subcontract in excess of \$10,000 shall include this clause and the Notice containing the goals for minority and female participation stated in the solicitation for this contract.

(c) If the Contractor is participating in a Hometown Plan (41 CFR 60-4) approved by the U.S. Department of Labor in a covered area, either individually or through an association, its affirmative action obligations on all work in the plan area (including goals) shall comply with the plan for those trades that have unions participating in the plan. Contractors must be able to demonstrate participation in, and compliance with, the provisions of the plan. Each Contractor or subcontractor participating in an approved plan is also required to comply with its obligations under the Equal Opportunity clause, and to make a good faith effort to achieve each goal under the plan in each trade in which it has employees. The overall good-faith performance by other Contractors or subcontractors toward a goal in an approved plan does not excuse any Contractor's or subcontractor's failure to make good-faith efforts to achieve the plan's goals.

(d) The Contractor shall implement the affirmative action procedures in subparagraphs (g)(1) through (16) of this clause. The goals stated in the solicitation for this contract are expressed as percentages of the total hours of employment and training of minority and female utilization that the Contractor should reasonably be able to achieve in each construction trade in which it has

employees in the covered area. If the Contractor performs construction work in a geographical area located outside of the covered area, it shall apply the goals established for the geographical area where that work is actually performed. The Contractor is expected to make substantially uniform progress toward its goals in each craft.

(e) Neither the terms and conditions of any collective bargaining agreement, nor the failure by a union with which the Contractor has a collective bargaining agreement, to refer minorities or women shall excuse the Contractor's obligations under this clause, Executive Order 11246, as amended, or the regulations thereunder.

(f) In order for the nonworking training hours of apprentices and trainees to be counted in meeting the goals, apprentices and trainees must be employed by the Contractor during the training period, and the Contractor must have made a commitment to employ the apprentices and trainees at the completion of their training, subject to the availability of employment opportunities. Trainees must be trained pursuant to training programs approved by the U.S. Department of Labor.

(g) The Contractor shall take affirmative action to ensure equal employment opportunity. The evaluation of the Contractor's compliance with this clause shall be based upon its effort to achieve maximum results from its actions. The Contractor shall document these efforts fully and implement affirmative action steps at least as extensive as the following:

(1) Ensure a working environment free of harassment, intimidation, and coercion at all sites and in all facilities where the Contractor's employees are assigned to work. The Contractor, if possible, will assign two or more women to each construction project. The Contractor shall ensure that foremen, superintendents, and other onsite supervisory personnel are aware of and carry out the Contractor's obligation to maintain such a working environment, with specific attention to minority or female individuals working at these sites or facilities.

(2) Establish and maintain a current list of sources for minority and female recruitment. Provide written notification to minority and female recruitment sources and community organizations when the Contractor or its unions have employment opportunities available, and maintain a record of the organizations' responses.

(3) Establish and maintain a current file of the names, addresses, and telephone numbers of each minority and female off-the-street applicant, referrals of minorities or females from unions, recruitment sources, or community organizations, and the action taken with respect to each individual. If an individual was sent to the union hiring hall for referral and not referred back to the Contractor by the union or, if referred back, not employed by the Contractor, this shall be documented in the file, along with whatever additional actions the Contractor may have taken.

(4) Immediately notify the Deputy Assistant Secretary when the union or unions with which the Contractor has a collective bargaining agreement has not referred back to the Contractor a minority or woman sent by the Contractor, or when the Contractor has other information that the union referral process has impeded the Contractor's efforts to meet its obligations.

(5) Develop on-the-job training opportunities and/or participate in training programs for the area that expressly include minorities and women, including upgrading programs and apprenticeship and trainee programs relevant to the Contractor's employment needs, especially those programs funded or approved by the Department of Labor. The Contractor shall provide notice of these programs to the sources compiled under subparagraph (g)(2) of this clause.

(6) Disseminate the Contractor's equal employment policy by--

(i) Providing notice of the policy to unions and to training, recruitment, and outreach programs, and requesting their cooperation in assisting the Contractor in meeting its contract obligations;

(ii) Including the policy in any policy manual and in collective bargaining agreements;

(iii) Publicizing the policy in the company newspaper, annual report, etc.;

(iv) Reviewing the policy with all management personnel and with all minority and female employees at least once a year; and

(v) Posting the policy on bulletin boards accessible to employees at each location where construction work is performed.

(7) Review, at least annually, the Contractor's equal employment policy and affirmative action obligations with all employees having responsibility for hiring, assignment, layoff, termination, or other employment decisions. Conduct review of this policy with all on-site supervisory personnel before initiating construction work at a job site. A written record shall be made and maintained identifying the time and place of these meetings, persons attending, subject matter discussed, and disposition of the subject matter.

(8) Disseminate the Contractor's equal employment policy externally by including it in any advertising in the news media, specifically including minority and female news media. Provide written notification to, and discuss this policy with, other Contractors and subcontractors with which the Contractor does or anticipates doing business.

(9) Direct recruitment efforts, both oral and written, to minority, female, and community organizations, to schools with minority and female students, and to minority and female recruitment and training organizations serving the Contractor's recruitment area and employment needs. Not later than 1 month before the date for acceptance of applications for apprenticeship or training by any recruitment source, send written notification to organizations such as the above, describing the openings, screening procedures, and tests to be used in the selection process.

(10) Encourage present minority and female employees to recruit minority persons and women. Where reasonable, provide after-school, summer, and vacation employment to minority and female youth both on the site and in other areas of the Contractor's workforce.

(11) Validate all tests and other selection requirements where required under 41 CFR 60-3.

(12) Conduct, at least annually, an inventory and evaluation at least of all minority and female personnel for promotional opportunities. Encourage these employees to seek or to prepare for, through appropriate training, etc., opportunities for promotion.

(13) Ensure that seniority practices, job classifications, work assignments, and other personnel practices do not have a discriminatory effect by continually monitoring all personnel and employment-related activities to ensure that the Contractor's obligations under this contract are being carried out.

(14) Ensure that all facilities and company activities are nonsegregated except that separate or single-user rest rooms and necessary dressing or sleeping areas shall be provided to assure privacy between the sexes.

(15) Maintain a record of solicitations for subcontracts for minority and female construction contractors and suppliers, including circulation of solicitations to minority and female contractor associations and other business associations.

(16) Conduct a review, at least annually, of all supervisors' adherence to and performance under the Contractor's equal employment policy and affirmative action obligations.

(h) The Contractor is encouraged to participate in voluntary associations that may assist in fulfilling one or more of the affirmative action obligations contained in subparagraphs (g)(1) through (16) of this clause. The efforts of a contractor association, joint contractor-union, contractor-community, or similar group of which the contractor is a member and participant may be asserted as fulfilling one or more of its obligations under subparagraphs (g)(1) through (16) of this clause, provided the Contractor--

(1) Actively participates in the group;

(2) Makes every effort to ensure that the group has a positive impact on the employment of minorities and women in the industry;

(3) Ensures that concrete benefits of the program are reflected in the Contractor's minority and female workforce participation;

(4) Makes a good-faith effort to meet its individual goals and timetables; and

(5) Can provide access to documentation that demonstrates the effectiveness of actions taken on behalf of the Contractor. The obligation to comply is the Contractor's, and failure of such a group to fulfill an obligation shall not be a defense for the Contractor's noncompliance.

(i) A single goal for minorities and a separate single goal for women shall be established. The Contractor is required to provide equal employment opportunity and to take affirmative action for all minority groups, both male and female, and all women, both minority and nonminority. Consequently, the Contractor may be in violation of Executive Order 11246, as amended, if a particular group is employed in a substantially disparate manner.

(j) The Contractor shall not use goals or affirmative action standards to discriminate against any person because of race, color, religion, sex, or national origin.

(k) The Contractor shall not enter into any subcontract with any person or firm debarred from Government contracts under Executive Order 11246, as amended.

(l) The Contractor shall carry out such sanctions and penalties for violation of this clause and of the Equal Opportunity clause, including suspension, termination, and cancellation of existing subcontracts, as may be imposed or ordered under Executive Order 11246, as amended, and its implementing regulations, by the OFCCP. Any failure to carry out these sanctions and penalties as ordered shall be a violation of this clause and Executive Order 11246, as amended.

(m) The Contractor in fulfilling its obligations under this clause shall implement affirmative action procedures at least as extensive as those prescribed in paragraph (g) of this clause, so as to achieve maximum results from its efforts to ensure equal employment opportunity. If the Contractor fails to comply with the requirements of Executive Order 11246, as amended, the implementing regulations, or this clause, the Deputy Assistant Secretary shall take action as prescribed in 41 CFR 60-4.8.

(n) The Contractor shall designate a responsible official to--

(1) Monitor all employment-related activity to ensure that the Contractor's equal employment policy is being carried out;

(2) Submit reports as may be required by the Government; and

(3) Keep records that shall at least include for each employee the name, address, telephone number, construction trade, union affiliation (if any), employee identification number, social security number, race, sex, status (e.g., mechanic, apprentice, trainee, helper, or laborer), dates of changes in status, hours worked per week in the indicated trade, rate of pay, and locations at which the work was performed. Records shall be maintained in an easily understandable and retrievable form; however, to the degree that existing records satisfy this requirement, separate records are not required to be maintained.

Nothing contained herein shall be construed as a limitation upon the application of other laws that establish different standards of compliance or upon the requirements for the hiring of local or other area residents (e.g., those under the Public Works Employment Act of 1977 and the Community Development Block Grant Program).

52.222-35 EQUAL OPPORTUNITY FOR SPECIAL DISABLED VETERANS, VETERANS OF THE VIETNAM ERA AND OTHER ELIGIBLE VETERANS (DEC 2001)

(a) Definitions. As used in this clause--

All employment openings means all positions except executive and top management, those positions that will be filled from within the Contractor's organization, and positions lasting 3 days or less. This term includes full-time employment, temporary employment of more than 3 days duration, and part-time employment.

Executive and top management means any employee--

- (1) Whose primary duty consists of the management of the enterprise in which the individual is employed or of a customarily recognized department or subdivision thereof;
- (2) Who customarily and regularly directs the work of two or more other employees;
- (3) Who has the authority to hire or fire other employees or whose suggestions and recommendations as to the hiring or firing and as to the advancement and promotion or any other change of status of other employees will be given particular weight;
- (4) Who customarily and regularly exercises discretionary powers; and
- (5) Who does not devote more than 20 percent or, in the case of an employee of a retail or service establishment, who does not devote more than 40 percent of total hours of work in the work week to activities that are not directly and closely related to the performance of the work described in paragraphs (1) through (4) of this definition. This paragraph (5) does not apply in the case of an employee who is in sole charge of an establishment or a physically separated branch establishment, or who owns at least a 20 percent interest in the enterprise in which the individual is employed.

Other eligible veteran means any other veteran who served on active duty during a war or in a campaign or expedition for which a campaign badge has been authorized.

Positions that will be filled from within the Contractor's organization means employment openings for which the Contractor will give no consideration to persons outside the Contractor's organization (including any affiliates, subsidiaries, and parent companies) and includes any openings the Contractor proposes to fill from regularly established "recall" lists. The exception does not apply to a particular opening once an employer decides to consider applicants outside of its organization.

Qualified special disabled veteran means a special disabled veteran who satisfies the requisite skill, experience, education, and other job-related requirements of the employment position such veteran holds or desires, and who, with or without reasonable accommodation, can perform the essential functions of such position.

Special disabled veteran means--

- (1) A veteran who is entitled to compensation (or who but for the receipt of military retired pay would be entitled to compensation) under laws administered by the Department of Veterans Affairs for a disability--
 - (i) Rated at 30 percent or more; or

(ii) Rated at 10 or 20 percent in the case of a veteran who has been determined under 38 U.S.C. 3106 to have a serious employment handicap (i.e., a significant impairment of the veteran's ability to prepare for, obtain, or retain employment consistent with the veteran's abilities, aptitudes, and interests); or

(2) A person who was discharged or released from active duty because of a service-connected disability.

Veteran of the Vietnam era means a person who--

(1) Served on active duty for a period of more than 180 days and was discharged or released from active duty with other than a dishonorable discharge, if any part of such active duty occurred--

(i) In the Republic of Vietnam between February 28, 1961, and May 7, 1975; or

(ii) Between August 5, 1964, and May 7, 1975, in all other cases; or

(2) Was discharged or released from active duty for a service-connected disability if any part of the active duty was performed--

(i) In the Republic of Vietnam between February 28, 1961, and May 7, 1975; or

(ii) Between August 5, 1964, and May 7, 1975, in all other cases.

(b) General. (1) The Contractor shall not discriminate against the individual because the individual is a special disabled veteran, a veteran of the Vietnam era, or other eligible veteran, regarding any position for which the employee or applicant for employment is qualified. The Contractor shall take affirmative action to employ, advance in employment, and otherwise treat qualified special disabled veterans, veterans of the Vietnam era, and other eligible veterans without discrimination based upon their disability or veterans' status in all employment practices such as--

(i) Recruitment, advertising, and job application procedures;

(ii) Hiring, upgrading, promotion, award of tenure, demotion, transfer, layoff, termination, right of return from layoff and rehiring;

(iii) Rate of pay or any other form of compensation and changes in compensation;

(iv) Job assignments, job classifications, organizational structures, position descriptions, lines of progression, and seniority lists;

(v) Leaves of absence, sick leave, or any other leave;

(vi) Fringe benefits available by virtue of employment, whether or not administered by the Contractor;

(vii) Selection and financial support for training, including apprenticeship, and on-the-job training under 38 U.S.C. 3687, professional meetings, conferences, and other related activities, and selection for leaves of absence to pursue training;

(viii) Activities sponsored by the Contractor including social or recreational programs; and

(ix) Any other term, condition, or privilege of employment.

(2) The Contractor shall comply with the rules, regulations, and relevant orders of the Secretary of Labor issued under the Vietnam Era Veterans' Readjustment Assistance Act of 1972 (the Act), as amended (38 U.S.C. 4211 and 4212).

(c) Listing openings. (1) The Contractor shall immediately list all employment openings that exist at the time of the execution of this contract and those which occur during the performance of this contract, including those not generated by this contract, and including those occurring at an establishment of the Contractor other than the one where the contract is being performed, but excluding those of independently operated corporate affiliates, at an appropriate local public employment service office of the State wherein the opening occurs. Listing employment openings with the U.S. Department of Labor's America's Job Bank shall satisfy the requirement to list jobs with the local employment service office.

(2) The Contractor shall make the listing of employment openings with the local employment service office at least concurrently with using any other recruitment source or effort and shall involve the normal obligations of placing a bona fide job order, including accepting referrals of veterans and nonveterans. This listing of employment openings does not require hiring any particular job applicant or hiring from any particular group of job applicants and is not intended to relieve the Contractor from any requirements of Executive orders or regulations concerning nondiscrimination in employment.

(3) Whenever the Contractor becomes contractually bound to the listing terms of this clause, it shall advise the State public employment agency in each State where it has establishments of the name and location of each hiring location in the State. As long as the Contractor is contractually bound to these terms and has so advised the State agency, it need not advise the State agency of subsequent contracts. The Contractor may advise the State agency when it is no longer bound by this contract clause.

(d) Applicability. This clause does not apply to the listing of employment openings that occur and are filled outside the 50 States, the District of Columbia, the Commonwealth of Puerto Rico, the Commonwealth of the Northern Mariana Islands, American Samoa, Guam, the Virgin Islands of the United States, and Wake Island.

(e) Postings. (1) The Contractor shall post employment notices in conspicuous places that are available to employees and applicants for employment.

(2) The employment notices shall--

(i) State the rights of applicants and employees as well as the Contractor's obligation under the law to take affirmative action to employ and advance in employment qualified employees and applicants who are special disabled veterans, veterans of the Vietnam era, and other eligible veterans; and

(ii) Be in a form prescribed by the Deputy Assistant Secretary for Federal Contract Compliance Programs, Department of Labor (Deputy Assistant Secretary of Labor), and provided by or through the Contracting Officer.

(3) The Contractor shall ensure that applicants or employees who are special disabled veterans are informed of the contents of the notice (e.g., the Contractor may have the notice read to a visually disabled veteran, or may lower the posted notice so that it can be read by a person in a wheelchair).

(4) The Contractor shall notify each labor union or representative of workers with which it has a collective bargaining agreement, or other contract understanding, that the Contractor is bound by the terms of the Act and is committed to take affirmative action to employ, and advance in employment, qualified special disabled veterans, veterans of the Vietnam era, and other eligible veterans.

(f) Noncompliance. If the Contractor does not comply with the requirements of this clause, the Government may take appropriate actions under the rules, regulations, and relevant orders of the Secretary of Labor issued pursuant to the Act.

(g) Subcontracts. The Contractor shall insert the terms of this clause in all subcontracts or purchase orders of \$25,000 or more unless exempted by rules, regulations, or orders of the Secretary of Labor. The Contractor shall act as specified by the Deputy Assistant Secretary of Labor to enforce the terms, including action for noncompliance.

52.222-36 AFFIRMATIVE ACTION FOR WORKERS WITH DISABILITIES (JUN 1998)

(a) General. (1) Regarding any position for which the employee or applicant for employment is qualified, the Contractor shall not discriminate against any employee or applicant because of physical or mental disability. The Contractor agrees to take affirmative action to employ, advance in employment, and otherwise treat qualified individuals with disabilities without discrimination based upon their physical or mental disability in all employment practices such as--

(i) Recruitment, advertising, and job application procedures;

(ii) Hiring, upgrading, promotion, award of tenure, demotion, transfer, layoff, termination, right of return from layoff, and rehiring;

(iii) Rates of pay or any other form of compensation and changes in compensation;

(iv) Job assignments, job classifications, organizational structures, position descriptions, lines of progression, and seniority lists;

- (v) Leaves of absence, sick leave, or any other leave;
 - (vi) Fringe benefits available by virtue of employment, whether or not administered by the Contractor;
 - (vii) Selection and financial support for training, including apprenticeships, professional meetings, conferences, and other related activities, and selection for leaves of absence to pursue training;
 - (viii) Activities sponsored by the Contractor, including social or recreational programs; and
 - (ix) Any other term, condition, or privilege of employment.
- (2) The Contractor agrees to comply with the rules, regulations, and relevant orders of the Secretary of Labor (Secretary) issued under the Rehabilitation Act of 1973 (29 U.S.C. 793) (the Act), as amended.
- (b) Postings. (1) The Contractor agrees to post employment notices stating--
- (i) The Contractor's obligation under the law to take affirmative action to employ and advance in employment qualified individuals with disabilities; and
 - (ii) The rights of applicants and employees.
- (2) These notices shall be posted in conspicuous places that are available to employees and applicants for employment. The Contractor shall ensure that applicants and employees with disabilities are informed of the contents of the notice (e.g., the Contractor may have the notice read to a visually disabled individual, or may lower the posted notice so that it might be read by a person in a wheelchair). The notices shall be in a form prescribed by the Deputy Assistant Secretary for Federal Contract Compliance of the U.S. Department of Labor (Deputy Assistant Secretary) and shall be provided by or through the Contracting Officer.
- (3) The Contractor shall notify each labor union or representative of workers with which it has a collective bargaining agreement or other contract understanding, that the Contractor is bound by the terms of Section 503 of the Act and is committed to take affirmative action to employ, and advance in employment, qualified individuals with physical or mental disabilities.
- (c) Noncompliance. If the Contractor does not comply with the requirements of this clause, appropriate actions may be taken under the rules, regulations, and relevant orders of the Secretary issued pursuant to the Act.
- (d) Subcontracts. The Contractor shall include the terms of this clause in every subcontract or purchase order in excess of \$10,000 unless exempted by rules, regulations, or orders of the Secretary. The Contractor shall act as specified by the Deputy Assistant Secretary to enforce the terms, including action for noncompliance.

52.222-37 EMPLOYMENT REPORTS ON SPECIAL DISABLED VETERANS, VETERANS OF THE VIETNAM ERA, AND OTHER ELIGIBLE VETERANS (DEC 2001)

(a) Unless the Contractor is a State or local government agency, the Contractor shall report at least annually, as required by the Secretary of Labor, on--

(1) The number of special disabled veterans, the number of veterans of the Vietnam era, and other eligible veterans in the workforce of the Contractor by job category and hiring location; and

(2) The total number of new employees hired during the period covered by the report, and of the total, the number of special disabled veterans, the number of veterans of the Vietnam era, and the number of other eligible veterans; and

(3) The maximum number and the minimum number of employees of the Contractor during the period covered by the report.

(b) The Contractor shall report the above items by completing the Form VETS-100, entitled "Federal Contractor Veterans" Employment Report (VETS-100 Report)".

(c) The Contractor shall submit VETS-100 Reports no later than September 30 of each year beginning September 30, 1988.

(d) The employment activity report required by paragraph (a)(2) of this clause shall reflect total hires during the most recent 12-month period as of the ending date selected for the employment profile report required by paragraph (a)(1) of this clause. Contractors may select an ending date--

(1) As of the end of any pay period between July 1 and August 31 of the year the report is due; or

(2) As of December 31, if the Contractor has prior written approval from the Equal Employment Opportunity Commission to do so for purposes of submitting the Employer Information Report EEO-1 (Standard Form 100).

(e) The Contractor shall base the count of veterans reported according to paragraph (a) of this clause on voluntary disclosure. Each Contractor subject to the reporting requirements at 38 U.S.C. 4212 shall invite all special disabled veterans, veterans of the Vietnam era, and other eligible veterans who wish to benefit under the affirmative action program at 38 U.S.C. 4212 to identify themselves to the Contractor. The invitation shall state that--

(1) The information is voluntarily provided;

(2) The information will be kept confidential;

(3) Disclosure or refusal to provide the information will not subject the applicant or employee to any adverse treatment; and

(4) The information will be used only in accordance with the regulations promulgated under 38 U.S.C. 4212.

(f) The Contractor shall insert the terms of this clause in all subcontracts or purchase orders of \$25,000 or more unless exempted by rules, regulations, or orders of the Secretary of Labor.

52.222-38 COMPLIANCE WITH VETERANS' EMPLOYMENT REPORTING REQUIREMENTS (DEC 2001)

By submission of its offer, the offeror represents that, if it is subject to the reporting requirements of 38 U.S.C. 4212(d) (i.e., if it has any contract containing Federal Acquisition Regulation clause 52.222-37, Employment Reports on Special Disabled Veterans, Veterans of the Vietnam Era, and Other Eligible Veterans), it has submitted the most recent VETS-100 Report required by that clause.

52.223-6 DRUG-FREE WORKPLACE (MAY 2001)

(a) Definitions. As used in this clause --

"Controlled substance" means a controlled substance in schedules I through V of section 202 of the Controlled Substances Act (21 U.S.C. 812) and as further defined in regulation at 21 CFR 1308.11 - 1308.15.

"Conviction" means a finding of guilt (including a plea of nolo contendere) or imposition of sentence, or both, by any judicial body charged with the responsibility to determine violations of the Federal or State criminal drug statutes.

"Criminal drug statute" means a Federal or non-Federal criminal statute involving the manufacture, distribution, dispensing, possession, or use of any controlled substance.

"Drug-free workplace" means the site(s) for the performance of work done by the Contractor in connection with a specific contract where employees of the Contractor are prohibited from engaging in the unlawful manufacture, distribution, dispensing, possession, or use of a controlled substance.

"Employee" means an employee of a Contractor directly engaged in the performance of work under a Government contract. "Directly engaged" is defined to include all direct cost employees and any other Contractor employee who has other than a minimal impact or involvement in contract performance.

"Individual" means an offeror/contractor that has no more than one employee including the offeror/contractor.

(b) The Contractor, if other than an individual, shall-- within 30 days after award (unless a longer period is agreed to in writing for contracts of 30 days or more performance duration), or as soon as possible for contracts of less than 30 days performance duration--

- (1) Publish a statement notifying its employees that the unlawful manufacture, distribution, dispensing, possession, or use of a controlled substance is prohibited in the Contractor's workplace and specifying the actions that will be taken against employees for violations of such prohibition;
 - (2) Establish an ongoing drug-free awareness program to inform such employees about--
 - (i) The dangers of drug abuse in the workplace;
 - (ii) The Contractor's policy of maintaining a drug-free workplace;
 - (iii) Any available drug counseling, rehabilitation, and employee assistance programs; and
 - (iv) The penalties that may be imposed upon employees for drug abuse violations occurring in the workplace;
 - (3) Provide all employees engaged in performance of the contract with a copy of the statement required by subparagraph (b)(1) of this clause;
 - (4) Notify such employees in writing in the statement required by subparagraph (b)(1) of this clause that, as a condition of continued employment on this contract, the employee will--
 - (i) Abide by the terms of the statement; and
 - (ii) Notify the employer in writing of the employee's conviction under a criminal drug statute for a violation occurring in the workplace no later than 5 days after such conviction.
 - (5) Notify the Contracting Officer in writing within 10 days after receiving notice under subdivision (b)(4)(ii) of this clause, from an employee or otherwise receiving actual notice of such conviction. The notice shall include the position title of the employee;
 - (6) Within 30 days after receiving notice under subdivision (b)(4)(ii) of this clause of a conviction, take one of the following actions with respect to any employee who is convicted of a drug abuse violation occurring in the workplace:
 - (i) Taking appropriate personnel action against such employee, up to and including termination; or
 - (ii) Require such employee to satisfactorily participate in a drug abuse assistance or rehabilitation program approved for such purposes by a Federal, State, or local health, law enforcement, or other appropriate agency; and
 - (7) Make a good faith effort to maintain a drug-free workplace through implementation of subparagraphs (b)(1) through (b)(6) of this clause.
- (c) The Contractor, if an individual, agrees by award of the contract or acceptance of a purchase order, not to engage in the unlawful manufacture, distribution, dispensing, possession, or use of a

controlled substance while performing this contract.

(d) In addition to other remedies available to the Government, the Contractor's failure to comply with the requirements of paragraph (b) or (c) of this clause may, pursuant to FAR 23.506, render the Contractor subject to suspension of contract payments, termination of the contract for default, and suspension or debarment.

52.223-14 TOXIC CHEMICAL RELEASE REPORTING (OCT 2000)

(a) Unless otherwise exempt, the Contractor, as owner or operator of a facility used in the performance of this contract, shall file by July 1 for the prior calendar year an annual Toxic Chemical Release Inventory Form (Form R) as described in sections 313(a) and (g) of the Emergency Planning and Community Right-to-Know Act of 1986 (EPCRA) (42 U.S.C. 11023(a) and (g)), and section 6607 of the Pollution Prevention Act of 1990 (PPA) (42 U.S.C. 13106). The Contractor shall file, for each facility subject to the Form R filing and reporting requirements, the annual Form R throughout the life of the contract.

(b) A Contractor owned or operated facility used in the performance of this contract is exempt from the requirement to file an annual Form R if--

(1) The facility does not manufacture, process, or otherwise use any toxic chemicals listed under section 313(c) of EPCRA, 42 U.S.C. 11023(c);

(2) The facility does not have 10 or more full-time employees as specified in section 313(b)(1)(A) of EPCRA, 42 U.S.C. 11023(b)(1)(A);

(3) The facility does not meet the reporting thresholds of toxic chemicals established under of EPCRA, 42 U.S.C. 11023(f) (including the alternate thresholds at 40 CFR 372.27, provided an appropriate certification form has been filed with EPA);

(4) The facility does not fall within Standard Industrial Classification Code (SIC) major groups 20 through 39 or their corresponding North American Industry Classification System (NAICS) sectors 31 through 33; or

(5) The facility is not located within any State of the United States, the District of Columbia, the Commonwealth of Puerto Rico, Guam, American Samoa, the United States Virgin Islands, the Northern Mariana Islands, or any other territory or possession over which the United States has jurisdiction.

(c) If the Contractor has certified to an exemption in accordance with one or more of the criteria in paragraph (b) of this clause, and after award of the contract circumstances change so that any of its owned or operated facilities used in the performance of this contract is no longer exempt--

(1) The Contractor shall notify the Contracting Officer; and

(2) The Contractor, as owner or operator of a facility used in the performance of this contract that is no longer exempt, shall (i) submit a Toxic Chemical Release Inventory Form (Form R) on or before July 1 for the prior calendar year during which the facility becomes eligible; and (ii) continue to file the annual Form R for the life of the contract for such facility.

(d) The Contracting Officer may terminate this contract or take other action as appropriate, if the Contractor fails to comply accurately and fully with the EPCRA and PPA toxic chemical release filing and reporting requirements.

(e) Except for acquisitions of commercial items, as defined in FAR Part 2, the Contractor shall--

(1) For competitive subcontracts expected to exceed \$100,000 (including all options), include a solicitation provision substantially the same as the provision at FAR 52.223-13, Certification of Toxic Chemical Release Reporting; and

(2) Include in any resultant subcontract exceeding \$100,000 (including all options), the substance of this clause, except this paragraph (e).

52.225-9 BUY AMERICAN ACT—CONSTRUCTION MATERIALS (MAY 2002)

(a) Definitions. As used in this clause--

Component means an article, material, or supply incorporated directly into a construction material.

Construction material means an article, material, or supply brought to the construction site by the Contractor or a subcontractor for incorporation into the building or work. The term also includes an item brought to the site preassembled from articles, materials, or supplies. However, emergency life safety systems, such as emergency lighting, fire alarm, and audio evacuation systems, that are discrete systems incorporated into a public building or work and that are produced as complete systems, are evaluated as a single and distinct construction material regardless of when or how the individual parts or components of those systems are delivered to the construction site. Materials purchased directly by the Government are supplies, not construction material.

Cost of components means--

(1) For components purchased by the Contractor, the acquisition cost, including transportation costs to the place of incorporation into the end product (whether or not such costs are paid to a domestic firm), and any applicable duty (whether or not a duty-free entry certificate is issued); or

(2) For components manufactured by the Contractor, all costs associated with the manufacture of the component, including transportation costs as described in paragraph (1) of this definition, plus allocable overhead costs, but excluding profit. Cost of components does not include any costs associated with the manufacture of the end product.

Domestic construction material means--

- (1) An unmanufactured construction material mined or produced in the United States; or
- (2) A construction material manufactured in the United States, if the cost of its components mined, produced, or manufactured in the United States exceeds 50 percent of the cost of all its components. Components of foreign origin of the same class or kind for which nonavailability determinations have been made are treated as domestic.

Foreign construction material means a construction material other than a domestic construction material.

United States means the 50 States and the District of Columbia, U.S. territories and possessions, Puerto Rico, the Northern Mariana Islands, and any other place subject to U.S. jurisdiction, but does not include leased bases.

(b) Domestic preference. (1) This clause implements the Buy American Act (41 U.S.C. 10a-10d) by providing a preference for domestic construction material. The Contractor shall use only domestic construction material in performing this contract, except as provided in paragraphs (b)(2) and (b)(3) of this clause.

(2) This requirement does not apply to the construction material or components listed by the Government as follows: NONE

(3) The Contracting Officer may add other foreign construction material to the list in paragraph (b)(2) of this clause if the Government determines that

(i) The cost of domestic construction material would be unreasonable. The cost of a particular domestic construction material subject to the requirements of the Buy American Act is unreasonable when the cost of such material exceeds the cost of foreign material by more than 6 percent;

(ii) The application of the restriction of the Buy American Act to a particular construction material would be impracticable or inconsistent with the public interest; or

(iii) The construction material is not mined, produced, or manufactured in the United States in sufficient and reasonably available commercial quantities of a satisfactory quality.

(c) Request for determination of inapplicability of the Buy American Act. (1)(i) Any Contractor request to use foreign construction material in accordance with paragraph (b)(3) of this clause shall include adequate information for Government evaluation of the request, including--

(A) A description of the foreign and domestic construction materials;

(B) Unit of measure;

(C) Quantity;

- (D) Price;
- (E) Time of delivery or availability;
- (F) Location of the construction project;
- (G) Name and address of the proposed supplier; and
- (H) A detailed justification of the reason for use of foreign construction materials cited in accordance with paragraph (b)(3) of this clause.
 - (ii) A request based on unreasonable cost shall include a reasonable survey of the market and a completed price comparison table in the format in paragraph (d) of this clause.
 - (iii) The price of construction material shall include all delivery costs to the construction site and any applicable duty (whether or not a duty-free certificate may be issued).
 - (iv) Any Contractor request for a determination submitted after contract award shall explain why the Contractor could not reasonably foresee the need for such determination and could not have requested the determination before contract award. If the Contractor does not submit a satisfactory explanation, the Contracting Officer need not make a determination.
- (2) If the Government determines after contract award that an exception to the Buy American Act applies and the Contracting Officer and the Contractor negotiate adequate consideration, the Contracting Officer will modify the contract to allow use of the foreign construction material. However, when the basis for the exception is the unreasonable price of a domestic construction material, adequate consideration is not less than the differential established in paragraph (b)(3)(i) of this clause.
- (3) Unless the Government determines that an exception to the Buy American Act applies, use of foreign construction material is noncompliant with the Buy American Act.
- (d) Data. To permit evaluation of requests under paragraph (c) of this clause based on unreasonable cost, the Contractor shall include the following information and any applicable supporting data based on the survey of suppliers:

Foreign and Domestic Construction Materials Price Comparison

Construction material description	Unit of measure	Quantity	Price (dollars) \1\
Item 1			
Foreign construction material....
Domestic construction material...
Item 2			
Foreign construction material....

Domestic construction material... ..

 Include all delivery costs to the construction site and any applicable duty (whether or not a duty-free entry certificate is issued).

List name, address, telephone number, and contact for suppliers surveyed. Attach copy of response; if oral, attach summary. Include other applicable supporting information.

52.225-13 RESTRICTIONS ON CERTAIN FOREIGN PURCHASES (JUL 2000)

(a) The Contractor shall not acquire, for use in the performance of this contract, any supplies or services originating from sources within, or that were located in or transported from or through, countries whose products are banned from importation into the United States under regulations of the Office of Foreign Assets Control, Department of the Treasury. Those countries are Cuba, Iran, Iraq, Libya, North Korea, Sudan, the territory of Afghanistan controlled by the Taliban, and Serbia (excluding the territory of Kosovo).

(b) The Contractor shall not acquire for use in the performance of this contract any supplies or services from entities controlled by the government of Iraq.

(c) The Contractor shall insert this clause, including this paragraph (c), in all subcontracts.

52.226-1 UTILIZATION OF INDIAN ORGANIZATIONS AND INDIAN-OWNED ECONOMIC ENTERPRISES (JUN 2000)

(a) Definitions. As used in this clause:

"Indian" means any person who is a member of any Indian tribe, band, group, pueblo or community that is recognized by the Federal Government as eligible for services from the Bureau of Indian Affairs (BIA) in accordance with 25 U.S.C. 1452(c) and any "Native" as defined in the Alaska Native Claims Settlement Act (43 U.S.C. 1601).

"Indian organization" means the governing body of any Indian tribe or entity established or recognized by the governing body of an Indian tribe for the purposes of 25 U.S.C., chapter 17.

"Indian-owned economic enterprise" means any Indian-owned (as determined by the Secretary of the Interior) commercial, industrial, or business activity established or organized for the purpose of profit, provided that Indian ownership constitute not less than 51 percent of the enterprise.

"Indian tribe" means any Indian tribe, band, group, pueblo or community, including native villages and native groups (including corporations organized by Kenai, Juneau, Sitka, and Kodiak) as defined in the Alaska Native Claims Settlement Act, that is recognized by the Federal Government as eligible for services from BIA in accordance with 25 U.S.C. 1542(c).

"Interested party" means a prime contractor or an actual or prospective offeror whose direct

economic interest would be affected by the award of a subcontract or by the failure to award a subcontract.

(b) The Contractor shall use its best efforts to give Indian organizations and Indian-owned economic enterprises (25 U.S.C. 1544) the maximum practicable opportunity to participate in the subcontracts it awards to the fullest extent consistent with efficient performance of its contract.

(1) The Contracting Officer and the Contractor, acting in good faith, may rely on the representation of an Indian organization or Indian-owned economic enterprise as to its eligibility, unless an interested party challenges its status or the Contracting Officer has independent reason to question that status. In the event of a challenge to the representation of a subcontractor, the Contracting Officer will refer the matter to the U.S. Department of the Interior, Bureau of Indian Affairs (BIA), Attn: Chief, Division of Contracting and Grants Administration, 1849 C Street, NW., MS 2626-MIB, Washington, DC 20240-4000.

The BIA will determine the eligibility and notify the Contracting Officer. No incentive payment will be made within 50 working days of subcontract award or while a challenge is pending. If a subcontractor is determined to be an ineligible participant, no incentive payment will be made under the Indian Incentive Program.

(2) The Contractor may request an adjustment under the Indian Incentive Program to the following:

(i) The estimated cost of a cost-type contract.

(ii) The target cost of a cost-plus-incentive-fee prime contract.

(iii) The target cost and ceiling price of a fixed-price incentive prime contract.

(iv) The price of a firm-fixed-price prime contract.

(3) The amount of the adjustment to the prime contract is 5 percent of the estimated cost, target cost, or firm-fixed-price included in the subcontract initially awarded to the Indian organization or Indian-owned economic enterprise.

(4) The Contractor has the burden of proving the amount claimed and must assert its request for an adjustment prior to completion of contract performance.

(c) The Contracting Officer, subject to the terms and conditions of the contract and the availability of funds, will authorize an incentive payment of 5 percent of the amount paid to the subcontractor. The Contracting Officer will seek funding in accordance with agency procedures.

52.227-1 AUTHORIZATION AND CONSENT (JUL 1995)

(a) The Government authorizes and consents to all use and manufacture, in performing this contract

or any subcontract at any tier, of any invention described in and covered by a United States patent (1) embodied in the structure or composition of any article the delivery of which is accepted by the Government under this contract or (2) used in machinery, tools, or methods whose use necessarily results from compliance by the Contractor or a subcontractor with (i) specifications or written provisions forming a part of this contract or (ii) specific written instructions given by the Contracting Officer directing the manner of performance. The entire liability to the Government for infringement of a patent of the United States shall be determined solely by the provisions of the indemnity clause, if any, included in this contract or any subcontract hereunder (including any lower-tier subcontract), and the Government assumes liability for all other infringement to the extent of the authorization and consent hereinabove granted.

(b) The Contractor agrees to include, and require inclusion of, this clause, suitably modified to identify the parties, in all subcontracts at any tier for supplies or services (including construction, architect-engineer services, and materials, supplies, models, samples, and design or testing services expected to exceed the simplified acquisition threshold (however, omission of this clause from any subcontract, including those at or below the simplified acquisition threshold, does not affect this authorization and consent.)

52.227-2 NOTICE AND ASSISTANCE REGARDING PATENT AND COPYRIGHT INFRINGEMENT (AUG 1996)

(a) The Contractor shall report to the Contracting Officer, promptly and in reasonable written detail, each notice or claim of patent or copyright infringement based on the performance of this contract of which the Contractor has knowledge.

(b) In the event of any claim or suit against the Government on account of any alleged patent or copyright infringement arising out of the performance of this contract or out of the use of any supplies furnished or work or services performed under this contract, the Contractor shall furnish to the Government, when requested by the Contracting Officer, all evidence and information in possession of the Contractor pertaining to such suit or claim. Such evidence and information shall be furnished at the expense of the Government except where the Contractor has agreed to indemnify the Government.

(c) The Contractor agrees to include, and require inclusion of, this clause in all subcontracts at any tier for supplies or services (including construction and architect-engineer subcontracts and those for material, supplies, models, samples, or design or testing services) expected to exceed the simplified acquisition threshold at (FAR) 2.101 to exceed the dollar amount set forth in 13.000 of the Federal Acquisition Regulation (FAR).

52.227-4 PATENT INDEMNITY--CONSTRUCTION CONTRACTS (APR 1984)

Except as otherwise provided, the Contractor agrees to indemnify the Government and its officers, agents, and employees against liability, including costs and expenses, for infringement upon any

United States patent (except a patent issued upon an application that is now or may hereafter be withheld from issue pursuant to a Secrecy Order under 35 U.S.C. 181) arising out of performing this contract or out of the use or disposal by or for the account of the Government of supplies furnished or work performed under this contract.

52.228-1 BID GUARANTEE (SEP 1996)

(a) Failure to furnish a bid guarantee in the proper form and amount, by the time set for opening of bids, may be cause for rejection of the bid.

(b) The bidder shall furnish a bid guarantee in the form of a firm commitment, *e.g.*, bid bond supported by good and sufficient surety or sureties acceptable to the Government, postal money order, certified check, cashier's check, irrevocable letter of credit, or, under Treasury Department regulations, certain bonds or notes of the United States. The Contracting Officer will return bid guarantees, other than bid bonds --

(1) To unsuccessful bidders as soon as practicable after the opening of bids; and

(2) To the successful bidder upon execution of contractual documents and bonds (including any necessary coinsurance or reinsurance agreements), as required by the bid as accepted.

(c) The amount of the bid guarantee shall be 20 percent of the bid price or \$ n/a, whichever is less.

(d) If the successful bidder, upon acceptance of its bid by the Government within the period specified for acceptance, fails to execute all contractual documents or furnish executed bond(s) within 10 days after receipt of the forms by the bidder, the Contracting Officer may terminate the contract for default.

(e) In the event the contract is terminated for default, the bidder is liable for any cost of acquiring the work that exceeds the amount of its bid, and the bid guarantee is available to offset the difference.

52.228-2 ADDITIONAL BOND SECURITY (OCT 1997)

The Contractor shall promptly furnish additional security required to protect the Government and persons supplying labor or materials under this contract if --

(a) Any surety upon any bond, or issuing financial institution for other security, furnished with this contract becomes unacceptable to the Government;

(b) Any surety fails to furnish reports on its financial condition as required by the Government;

(c) The contract price is increased so that the penal sum of any bond becomes inadequate in the opinion of the Contracting Officer; or

(d) An irrevocable letter of credit (ILC) used as security will expire before the end of the period of required security. If the Contractor does not furnish an acceptable extension or replacement ILC, or other acceptable substitute, at least 30 days before an ILC's scheduled expiration, the Contracting officer has the right to immediately draw on the ILC.

52.228-15 PERFORMANCE AND PAYMENT BONDS--CONSTRUCTION (JUL 2000)-

(a) Definitions. As used in this clause--

Original contract price means the award price of the contract; or, for requirements contracts, the price payable for the estimated total quantity; or, for indefinite-quantity contracts, the price payable for the specified minimum quantity. Original contract price does not include the price of any options, except those options exercised at the time of contract award.

(b) Amount of required bonds. Unless the resulting contract price is \$100,000 or less, the successful offeror shall furnish performance and payment bonds to the Contracting Officer as follows:

(1) Performance bonds (Standard Form 25). The penal amount of performance bonds at the time of contract award shall be 100 percent of the original contract price.

(2) Payment Bonds (Standard Form 25-A). The penal amount of payment bonds at the time of contract award shall be 100 percent of the original contract price.

(3) Additional bond protection. (i) The Government may require additional performance and payment bond protection if the contract price is increased. The increase in protection generally will equal 100 percent of the increase in contract price.

(ii) The Government may secure the additional protection by directing the Contractor to increase the penal amount of the existing bond or to obtain an additional bond.

(c) Furnishing executed bonds. The Contractor shall furnish all executed bonds, including any necessary reinsurance agreements, to the Contracting Officer, within the time period specified in the Bid Guarantee provision of the solicitation, or otherwise specified by the Contracting Officer, but in any event, before starting work.

(d) Surety or other security for bonds. The bonds shall be in the form of firm commitment, supported by corporate sureties whose names appear on the list contained in Treasury Department Circular 570, individual sureties, or by other acceptable security such as postal money order, certified check, cashier's check, irrevocable letter of credit, or, in accordance with Treasury Department regulations, certain bonds or notes of the United States. Treasury Circular 570 is published in the Federal Register or may be obtained from the U.S. Department of Treasury,

Financial Management Service, Surety Bond Branch, 401 14th Street, NW, 2nd Floor, West Wing, Washington, DC 20227.

(e) Notice of subcontractor waiver of protection (40 U.S.C. 270b(c)). Any waiver of the right to sue on the payment bond is void unless it is in writing, signed by the person whose right is waived, and executed after such person has first furnished labor or material for use in the performance of the contract.

52.229-3 FEDERAL, STATE, AND LOCAL TAXES (JAN 1991)

(a) "Contract date," as used in this clause, means the date set for bid opening or, if this is a negotiated contract or a modification, the effective date of this contract or modification.

"All applicable Federal, State, and local taxes and duties," as used in this clause, means all taxes and duties, in effect on the contract date, that the taxing authority is imposing and collecting on the transactions or property covered by this contract.

"After-imposed Federal tax," as used in this clause, means any new or increased Federal excise tax or duty, or tax that was exempted or excluded on the contract date but whose exemption was later revoked or reduced during the contract period, on the transactions or property covered by this contract that the Contractor is required to pay or bear as the result of legislative, judicial, or administrative action taking effect after the contract date. It does not include social security tax or other employment taxes.

"After-relieved Federal tax," as used in this clause, means any amount of Federal excise tax or duty, except social security or other employment taxes, that would otherwise have been payable on the transactions or property covered by this contract, but which the Contractor is not required to pay or bear, or for which the Contractor obtains a refund or drawback, as the result of legislative, judicial, or administrative action taking effect after the contract date.

(b) The contract price includes all applicable Federal, State, and local taxes and duties.

(c) The contract price shall be increased by the amount of any after-imposed Federal tax, provided the Contractor warrants in writing that no amount for such newly imposed Federal excise tax or duty or rate increase was included in the contract price, as a contingency reserve or otherwise.

(d) The contract price shall be decreased by the amount of any after-relieved Federal tax.

(e) The contract price shall be decreased by the amount of any Federal excise tax or duty, except social security or other employment taxes, that the Contractor is required to pay or bear, or does not obtain a refund of, through the Contractor's fault, negligence, or failure to follow instructions of the Contracting Officer.

(f) No adjustment shall be made in the contract price under this clause unless the amount of the adjustment exceeds \$250.

(g) The Contractor shall promptly notify the Contracting Officer of all matters relating to any Federal excise tax or duty that reasonably may be expected to result in either an increase or decrease in the contract price and shall take appropriate action as the Contracting Officer directs.

(h) The Government shall, without liability, furnish evidence appropriate to establish exemption from any Federal, State, or local tax when the Contractor requests such evidence and a reasonable basis exists to sustain the exemption.

52.229-5 TAXES--CONTRACTS PERFORMED IN U.S. POSSESSIONS OR PUERTO RICO (APR 1984)

The term "local taxes," as used in the Federal, State, and local taxes clause of this contract, includes taxes imposed by a possession of the United States or by Puerto Rico.

52.232-5 PAYMENTS UNDER FIXED-PRICE CONSTRUCTION CONTRACTS (MAY 1997)

(a) Payment of price. The Government shall pay the Contractor the contract price as provided in this contract.

(b) Progress payments. The Government shall make progress payments monthly as the work proceeds, or at more frequent intervals as determined by the Contracting Officer, on estimates of work accomplished which meets the standards of quality established under the contract, as approved by the Contracting Officer.

(1) The Contractor's request for progress payments shall include the following substantiation:

(i) An itemization of the amounts requested, related to the various elements of work required by the contract covered by the payment requested.

(ii) A listing of the amount included for work performed by each subcontractor under the contract.

(iii) A listing of the total amount of each subcontract under the contract.

(iv) A listing of the amounts previously paid to each such subcontractor under the contract.

(v) Additional supporting data in a form and detail required by the Contracting Officer.

(2) In the preparation of estimates, the Contracting Officer may authorize material delivered on the site and preparatory work done to be taken into consideration. Material delivered to the Contractor at locations other than the site also may be taken into consideration if--

(i) Consideration is specifically authorized by this contract; and

(ii) The Contractor furnishes satisfactory evidence that it has acquired title to such material and that the material will be used to perform this contract.

(c) Contractor certification. Along with each request for progress payments, the Contractor shall furnish the following certification, or payment shall not be made: (However, if the Contractor elects to delete paragraph (c)(4) from the certification, the certification is still acceptable.)

I hereby certify, to the best of my knowledge and belief, that--

(1) The amounts requested are only for performance in accordance with the specifications, terms, and conditions of the contract;

(2) Payments to subcontractors and suppliers have been made from previous payments received under the contract, and timely payments will be made from the proceeds of the payment covered by this certification, in accordance with subcontract agreements and the requirements of chapter 39 of Title 31, United States Code;

(3) This request for progress payments does not include any amounts which the prime contractor intends to withhold or retain from a subcontractor or supplier in accordance with the terms and conditions of the subcontract; and

(4) This certification is not to be construed as final acceptance of a subcontractor's performance.

(Name)

(Title)

(Date)

(d) Refund of unearned amounts. If the Contractor, after making a certified request for progress payments, discovers that a portion or all of such request constitutes a payment for performance by the Contractor that fails to conform to the specifications, terms, and conditions of this contract (hereinafter referred to as the "unearned amount"), the Contractor shall--

(1) Notify the Contracting Officer of such performance deficiency; and

(2) Be obligated to pay the Government an amount (computed by the Contracting Officer in the manner provided in paragraph (j) of this clause) equal to interest on the unearned amount from the 8th day after the date of receipt of the unearned amount until--

(i) The date the Contractor notifies the Contracting Officer that the performance deficiency has been corrected; or

(ii) The date the Contractor reduces the amount of any subsequent certified request for progress payments by an amount equal to the unearned amount.

(e) Retainage. If the Contracting Officer finds that satisfactory progress was achieved during any period for which a progress payment is to be made, the Contracting Officer shall authorize payment to be made in full. However, if satisfactory progress has not been made, the Contracting Officer may retain a maximum of 10 percent of the amount of the payment until satisfactory progress is achieved. When the work is substantially complete, the Contracting Officer may retain from previously withheld funds and future progress payments that amount the Contracting Officer considers adequate for protection of the Government and shall release to the Contractor all the remaining withheld funds. Also, on completion and acceptance of each separate building, public work, or other division of the contract, for which the price is stated separately in the contract, payment shall be made for the completed work without retention of a percentage.

(f) Title, liability, and reservation of rights. All material and work covered by progress payments made shall, at the time of payment, become the sole property of the Government, but this shall not be construed as--

(1) Relieving the Contractor from the sole responsibility for all material and work upon which payments have been made or the restoration of any damaged work; or

(2) Waiving the right of the Government to require the fulfillment of all of the terms of the contract.

(g) Reimbursement for bond premiums. In making these progress payments, the Government shall, upon request, reimburse the Contractor for the amount of premiums paid for performance and payment bonds (including coinsurance and reinsurance agreements, when applicable) after the Contractor has furnished evidence of full payment to the surety. The retainage provisions in paragraph (e) of this clause shall not apply to that portion of progress payments attributable to bond premiums.

(h) Final payment. The Government shall pay the amount due the Contractor under this contract after--

(1) Completion and acceptance of all work;

(2) Presentation of a properly executed voucher; and

(3) Presentation of release of all claims against the Government arising by virtue of this contract, other than claims, in stated amounts, that the Contractor has specifically excepted from the operation of the release. A release may also be required of the assignee if the Contractor's claim to amounts payable under this contract has been assigned under the Assignment of Claims Act of 1940 (31 U.S.C. 3727 and 41 U.S.C. 15).

(i) Limitation because of undefinitized work. Notwithstanding any provision of this contract, progress payments shall not exceed 80 percent on work accomplished on undefinitized contract actions. A "contract action" is any action resulting in a contract, as defined in FAR Subpart 2.1, including contract modifications for additional supplies or services, but not including contract modifications that are within the scope and under the terms of the contract, such as contract modifications issued pursuant to the Changes clause, or funding and other administrative changes.

(j) Interest computation on unearned amounts. In accordance with 31 U.S.C. 3903(c)(1), the amount payable under subparagraph (d)(2) of this clause shall be--

(1) Computed at the rate of average bond equivalent rates of 91-day Treasury bills auctioned at the most recent auction of such bills prior to the date the Contractor receives the unearned amount; and

(2) Deducted from the next available payment to the Contractor.

52.232-17 INTEREST (JUNE 1996)

(a) Except as otherwise provided in this contract under a Price Reduction for Defective Cost or Pricing Data clause or a Cost Accounting Standards clause, all amounts that become payable by the Contractor to the Government under this contract (net of any applicable tax credit under the Internal Revenue Code (26 U.S.C. 1481)) shall bear simple interest from the date due until paid unless paid within 30 days of becoming due. The interest rate shall be the interest rate established by the Secretary of the Treasury as provided in Section 12 of the Contract Disputes Act of 1978 (Public Law 95-563), which is applicable to the period in which the amount becomes due, as provided in paragraph (b) of this clause, and then at the rate applicable for each six-month period as fixed by the Secretary until the amount is paid. reproduce, prepare derivative works, distribute copies to the public, and (b) Amounts shall be due at the earliest of the following dates:

(1) The date fixed under this contract.

(2) The date of the first written demand for payment consistent with this contract, including any demand resulting from a default termination.

(3) The date the Government transmits to the Contractor a proposed supplemental agreement to confirm completed negotiations establishing the amount of debt.

(4) If this contract provides for revision of prices, the date of written notice to the Contractor stating the amount of refund payable in connection with a pricing proposal or a negotiated pricing agreement not confirmed by contract modification.

(c) The interest charge made under this clause may be reduced under the procedures prescribed in 32.614-2 of the Federal Acquisition Regulation in effect on the date of this contract.

52.232-23 ASSIGNMENT OF CLAIMS (JAN 1986) - ALTERNATE I (APR 1984)

(a) The Contractor, under the Assignment of Claims Act, as amended, 31 U.S.C. 3727, 41 U.S.C. 15 (hereafter referred to as "the Act"), may assign its rights to be paid amounts due or to become due as a result of the performance of this contract to a bank, trust company, or other financing institution, including any Federal lending agency. The assignee under such an assignment may thereafter further assign or reassign its right under the original assignment to any type of financing institution described in the preceding sentence. Unless otherwise stated in this contract, payments to an assignee of any amounts due or to become due under this contract shall not, to the extent specified in the Act, be subject to reduction or setoff.

(b) Any assignment or reassignment authorized under the Act and this clause shall cover all unpaid amounts payable under this contract, and shall not be made to more than one party, except that an assignment or reassignment may be made to one party as agent or trustee for two or more parties participating in the financing of this contract.

(c) The Contractor shall not furnish or disclose to any assignee under this contract any classified document (including this contract) or information related to work under this contract until the Contracting Officer authorizes such action in writing.

52.232-25 PROMPT PAYMENT (FEB 2002)

Notwithstanding any other payment clause in this contract, the Government will make invoice payments under the terms and conditions specified in this clause. The Government considers payment as being made on the day a check is dated or the date of an electronic funds transfer (EFT). Definitions of pertinent terms are set forth in sections 2.101, 32.001, and 32.902 of the Federal Acquisition Regulation. All days referred to in this clause are calendar days, unless otherwise specified. (However, see paragraph (a)(4) of this clause concerning payments due on Saturdays, Sundays, and legal holidays.)

(a) Invoice payments--(1) Due date. (i) Except as indicated in paragraphs (a)(2) and (c) of this clause, the due date for making invoice payments by the designated payment office is the later of the following two events:

(A) The 30th day after the designated billing office receives a proper invoice from the Contractor (except as provided in paragraph (a)(1)(ii) of this clause).

(B) The 30th day after Government acceptance of supplies delivered or services performed. For a final invoice, when the payment amount is subject to contract settlement actions, acceptance is deemed to occur on the effective date of the contract settlement.

(ii) If the designated billing office fails to annotate the invoice with the actual date of receipt at the time of receipt, the invoice payment due date is the 30th day after the date of the Contractor's invoice, provided the designated billing office receives a proper invoice and there is no disagreement over quantity, quality, or Contractor compliance with contract requirements.

(2) Certain food products and other payments. (i) Due dates on Contractor invoices for meat, meat food products, or fish; perishable agricultural commodities; and dairy products, edible fats or oils, and food products prepared from edible fats or oils are--

(A) For meat or meat food products, as defined in section 2(a)(3) of the Packers and Stockyard Act of 1921 (7 U.S.C. 182(3)), and as further defined in Pub. L. 98-181, including any edible fresh or frozen poultry meat, any perishable poultry meat food product, fresh eggs, and any perishable egg product, as close as possible to, but not later than, the 7th day after product delivery.

(B) For fresh or frozen fish, as defined in section 204(3) of the Fish and Seafood Promotion Act of 1986 (16 U.S.C. 4003(3)), as close as possible to, but not later than, the 7th day after product delivery.

(C) For perishable agricultural commodities, as defined in section 1(4) of the Perishable Agricultural Commodities Act of 1930 (7 U.S.C. 499a(4)), as close as possible to, but not later than, the 10th day after product delivery, unless another date is specified in the contract.

(D) For dairy products, as defined in section 111(e) of the Dairy Production Stabilization Act of 1983 (7 U.S.C. 4502(e)), edible fats or oils, and food products prepared from edible fats or oils, as close as possible to, but not later than, the 10th day after the date on which a proper invoice has been received. Liquid milk, cheese, certain processed cheese products, butter, yogurt, ice cream, mayonnaise, salad dressings, and other similar products, fall within this classification. Nothing in the Act limits this classification to refrigerated products. When questions arise regarding the proper classification of a specific product, prevailing industry practices will be followed in specifying a contract payment due date. The burden of proof that a classification of a specific product is, in fact, prevailing industry practice is upon the Contractor making the representation.

(ii) If the contract does not require submission of an invoice for payment (e.g., periodic lease payments), the due date will be as specified in the contract.

(3) Contractor's invoice. The Contractor shall prepare and submit invoices to the designated billing office specified in the contract. A proper invoice must include the items listed in paragraphs (a)(3)(i) through (a)(3)(x) of this clause. If the invoice does not comply with these requirements, the designated billing office will return it within 7 days after receipt (3 days for meat, meat food products, or fish; 5 days for perishable agricultural commodities, dairy products, edible fats or oils, and food products prepared from edible fats or oils), with the reasons why it is not a proper invoice. The Government will take into account untimely notification when computing any interest penalty owed the Contractor.

(i) Name and address of the Contractor.

(ii) Invoice date and invoice number. (The Contractor should date invoices as close as possible to the date of the mailing or transmission.)

(iii) Contract number or other authorization for supplies delivered or services performed (including order number and contract line item number).

(iv) Description, quantity, unit of measure, unit price, and extended price of supplies delivered or services performed.

(v) Shipping and payment terms (e.g., shipment number and date of shipment, discount for prompt payment terms). Bill of lading number and weight of shipment will be shown for shipments on Government bills of lading.

(vi) Name and address of Contractor official to whom payment is to be sent (must be the same as that in the contract or in a proper notice of assignment).

(vii) Name (where practicable), title, phone number, and mailing address of person to notify in the event of a defective invoice.

(viii) Taxpayer Identification Number (TIN). The Contractor shall include its TIN on the invoice only if required elsewhere in this contract.

(ix) Electronic funds transfer (EFT) banking information.

(A) The Contractor shall include EFT banking information on the invoice only if required elsewhere in this contract.

(B) If EFT banking information is not required to be on the invoice, in order for the invoice to be a proper invoice, the Contractor shall have submitted correct EFT banking information in accordance with the applicable solicitation provision (e.g., 52.232-38, Submission of Electronic Funds Transfer Information with Offer), contract clause (e.g., 52.232-33, Payment by Electronic Funds Transfer--Central Contractor Registration, or 52.232-34, Payment by Electronic Funds Transfer--Other Than Central Contractor Registration), or applicable agency procedures.

(C) EFT banking information is not required if the Government waived the requirement to pay by EFT.

(x) Any other information or documentation required by the contract (e.g., evidence of shipment).

(4) Interest penalty. The designated payment office will pay an interest penalty automatically, without request from the Contractor, if payment is not made by the due date and the conditions listed in paragraphs (a)(4)(i) through (a)(4)(iii) of this clause are met, if applicable. However, when the due date falls on a Saturday, Sunday, or legal holiday, the designated payment office may make payment on the following working day without incurring a late payment interest penalty.

(i) The designated billing office received a proper invoice.

(ii) The Government processed a receiving report or other Government documentation authorizing payment, and there was no disagreement over quantity, quality, or Contractor compliance with any contract term or condition.

(iii) In the case of a final invoice for any balance of funds due the Contractor for supplies delivered or services performed, the amount was not subject to further contract settlement actions between the Government and the Contractor.

(5) Computing penalty amount. The Government will compute the interest penalty in accordance with the Office of Management and Budget prompt payment regulations at 5 CFR part 1315.

(i) For the sole purpose of computing an interest penalty that might be due the Contractor, Government acceptance is deemed to occur constructively on the 7th day (unless otherwise specified in this contract) after the Contractor delivers the supplies or performs the services in accordance with the terms and conditions of the contract, unless there is a disagreement over quantity, quality, or Contractor compliance with a contract provision. If actual acceptance occurs within the constructive acceptance period, the Government will base the determination of an interest penalty on the actual date of acceptance. The constructive acceptance requirement does not, however, compel Government officials to accept supplies or services, perform contract administration functions, or make payment prior to fulfilling their responsibilities.

(ii) The prompt payment regulations at 5 CFR 1315.10(c) do not require the Government to pay interest penalties if payment delays are due to disagreement between the Government and the Contractor over the payment amount or other issues involving contract compliance, or on amounts temporarily withheld or retained in accordance with the terms of the contract. The Government and the Contractor shall resolve claims involving disputes and any interest that may be payable in accordance with the clause at FAR 52.233-1, Disputes.

(6) Discounts for prompt payment. The designated payment office will pay an interest penalty automatically, without request from the Contractor, if the Government takes a discount for prompt payment improperly. The Government will calculate the interest penalty in accordance with the prompt payment regulations at 5 CFR part 1315.

(7) Additional interest penalty. (i) The designated payment office will pay a penalty amount, calculated in accordance with the prompt payment regulations at 5 CFR part 1315 in addition to the interest penalty amount only if--

(A) The Government owes an interest penalty of \$1 or more;

(B) The designated payment office does not pay the interest penalty within 10 days after the date the invoice amount is paid; and

(C) The Contractor makes a written demand to the designated payment office for additional penalty payment, in accordance with paragraph (a)(7)(ii) of this clause, postmarked not later than 40 days after the invoice amount is paid.

(ii)(A) The Contractor shall support written demands for additional penalty payments with the following data. The Government will not request any additional data. The Contractor shall--

(1) Specifically assert that late payment interest is due under a specific invoice, and request payment of all overdue late payment interest penalty and such additional penalty as may be required;

(2) Attach a copy of the invoice on which the unpaid late payment interest is due; and

(3) State that payment of the principal has been received, including the date of receipt.

(B) If there is no postmark or the postmark is illegible--

(1) The designated payment office that receives the demand will annotate it with the date of receipt, provided the demand is received on or before the 40th day after payment was made; or

(2) If the designated payment office fails to make the required annotation, the Government will determine the demand's validity based on the date the Contractor has placed on the demand, provided such date is no later than the 40th day after payment was made.

(iii) The additional penalty does not apply to payments regulated by other Government regulations (e.g., payments under utility contracts subject to tariffs and regulation).

(b) Contract financing payment. If this contract provides for contract financing, the Government will make contract financing payments in accordance with the applicable contract financing clause.

(c) Fast payment procedure due dates. If this contract contains the clause at 52.213-1, Fast Payment Procedure, payments will be made within 15 days after the date of receipt of the invoice.

(d) Overpayments. If the Contractor becomes aware of a duplicate payment or that the Government has otherwise overpaid on an invoice payment, the Contractor shall immediately notify the Contracting Officer and request instructions for disposition of the overpayment.

52.232-27 PROMPT PAYMENT FOR CONSTRUCTION CONTRACTS (FEB 2002)

Notwithstanding any other payment terms in this contract, the Government will make invoice payments under the terms and conditions specified in this clause. The Government considers payment as being made on the day a check is dated or the date of an electronic funds transfer. Definitions of pertinent terms are set forth in sections 2.101, 32.001, and 32.902 of the Federal Acquisition Regulation. All days referred to in this clause are calendar days, unless otherwise specified. (However, see paragraph (a)(3) concerning payments due on Saturdays, Sundays, and legal holidays.)

(a) Invoice payments--(1) Types of invoice payments. For purposes of this clause, there are several types of invoice payments that may occur under this contract, as follows:

(i) Progress payments, if provided for elsewhere in this contract, based on Contracting Officer approval of the estimated amount and value of work or services performed, including payments for reaching milestones in any project.

(A) The due date for making such payments is 14 days after the designated billing office receives a proper payment request. If the designated billing office fails to annotate the payment request with the actual date of receipt at the time of receipt, the payment due date is the 14th day after the date of the Contractor's payment request, provided the designated billing office receives a proper payment request and there is no disagreement over quantity, quality, or Contractor compliance with contract requirements.

(B) The due date for payment of any amounts retained by the Contracting Officer in accordance with the clause at 52.232-5, Payments Under Fixed-Price Construction Contracts, is as specified in the contract or, if not specified, 30 days after approval by the Contracting Officer for release to the Contractor.

(ii) Final payments based on completion and acceptance of all work and presentation of release of all claims against the Government arising by virtue of the contract, and payments for partial deliveries that have been accepted by the Government (e.g., each separate building, public work, or other division of the contract for which the price is stated separately in the contract).

(A) The due date for making such payments is the later of the following two events:

(1) The 30th day after the designated billing office receives a proper invoice from the Contractor.

(2) The 30th day after Government acceptance of the work or services completed by the Contractor. For a final invoice when the payment amount is subject to contract settlement actions (e.g., release of claims), acceptance is deemed to occur on the effective date of the contract settlement.

(B) If the designated billing office fails to annotate the invoice with the date of actual receipt at the time of receipt, the invoice payment due date is the 30th day after the date of the Contractor's invoice, provided the designated billing office receives a proper invoice and there is no disagreement over quantity, quality, or Contractor compliance with contract requirements.

(2) Contractor's invoice. The Contractor shall prepare and submit invoices to the designated billing office specified in the contract. A proper invoice must include the items listed in paragraphs (a)(2)(i) through (a)(2)(xi) of this clause. If the invoice does not comply with these requirements, the designated billing office must return it within 7 days after receipt, with the reasons why it is not a proper invoice. When computing any interest penalty owed the Contractor, the Government will take into account if the Government notifies the Contractor of an improper invoice in an untimely manner.

(i) Name and address of the Contractor.

(ii) Invoice date and invoice number. (The Contractor should date invoices as close as possible to the date of mailing or transmission.)

(iii) Contract number or other authorization for work or services performed (including order number and contract line item number).

(iv) Description of work or services performed.

(v) Delivery and payment terms (e.g., discount for prompt payment terms).

(vi) Name and address of Contractor official to whom payment is to be sent (must be the same as that in the contract or in a proper notice of assignment).

(vii) Name (where practicable), title, phone number, and mailing address of person to notify in the event of a defective invoice.

(viii) For payments described in paragraph (a)(1)(i) of this clause, substantiation of the amounts requested and certification in accordance with the requirements of the clause at 52.232-5, Payments Under Fixed-Price Construction Contracts.

(ix) Taxpayer Identification Number (TIN). The Contractor shall include its TIN on the invoice only if required elsewhere in this contract.

(x) Electronic funds transfer (EFT) banking information.

(A) The Contractor shall include EFT banking information on the invoice only if required elsewhere in this contract.

(B) If EFT banking information is not required to be on the invoice, in order for the invoice to be a proper invoice, the Contractor shall have submitted correct EFT banking information in accordance with the applicable solicitation provision (e.g., 52.232-38, Submission of Electronic Funds Transfer Information with Offer), contract clause (e.g., 52.232-33, Payment by Electronic Funds Transfer--Central Contractor Registration, or 52.232-34, Payment by Electronic Funds Transfer--Other Than Central Contractor Registration), or applicable agency procedures.

(C) EFT banking information is not required if the Government waived the requirement to pay by EFT.

(xi) Any other information or documentation required by the contract.

(3) Interest penalty. The designated payment office will pay an interest penalty automatically, without request from the Contractor, if payment is not made by the due date and the conditions listed in paragraphs (a)(3)(i) through (a)(3)(iii) of this clause are met, if applicable. However, when the due date falls on a Saturday, Sunday, or legal holiday, the designated payment office may make payment on the following working day without incurring a late payment interest penalty.

- (i) The designated billing office received a proper invoice.
 - (ii) The Government processed a receiving report or other Government documentation authorizing payment and there was no disagreement over quantity, quality, Contractor compliance with any contract term or condition, or requested progress payment amount.
 - (iii) In the case of a final invoice for any balance of funds due the Contractor for work or services performed, the amount was not subject to further contract settlement actions between the Government and the Contractor.
- (4) Computing penalty amount. The Government will compute the interest penalty in accordance with the Office of Management and Budget prompt payment regulations at 5 CFR part 1315.
- (i) For the sole purpose of computing an interest penalty that might be due the Contractor for payments described in paragraph (a)(1)(ii) of this clause, Government acceptance or approval is deemed to occur constructively on the 7th day after the Contractor has completed the work or services in accordance with the terms and conditions of the contract. If actual acceptance or approval occurs within the constructive acceptance or approval period, the Government will base the determination of an interest penalty on the actual date of acceptance or approval. Constructive acceptance or constructive approval requirements do not apply if there is a disagreement over quantity, quality, or Contractor compliance with a contract provision. These requirements also do not compel Government officials to accept work or services, approve Contractor estimates, perform contract administration functions, or make payment prior to fulfilling their responsibilities.
 - (ii) The prompt payment regulations at 5 CFR 1315.10(c) do not require the Government to pay interest penalties if payment delays are due to disagreement between the Government and the Contractor over the payment amount or other issues involving contract compliance, or on amounts temporarily withheld or retained in accordance with the terms of the contract. The Government and the Contractor shall resolve claims involving disputes, and any interest that may be payable in accordance with the clause at FAR 52.233-1, Disputes.
- (5) Discounts for prompt payment. The designated payment office will pay an interest penalty automatically, without request from the Contractor, if the Government takes a discount for prompt payment improperly. The Government will calculate the interest penalty in accordance with the prompt payment regulations at 5 CFR part 1315.
- (6) Additional interest penalty. (i) The designated payment office will pay a penalty amount, calculated in accordance with the prompt payment regulations at 5 CFR part 1315 in addition to the interest penalty amount only if--
- (A) The Government owes an interest penalty of \$1 or more;
 - (B) The designated payment office does not pay the interest penalty within 10 days after the date the invoice amount is paid; and

(C) The Contractor makes a written demand to the designated payment office for additional penalty payment, in accordance with paragraph (a)(6)(ii) of this clause, postmarked not later than 40 days after the date the invoice amount is paid.

(ii)(A) The Contractor shall support written demands for additional penalty payments with the following data. The Government will not request any additional data. The Contractor shall--

(1) Specifically assert that late payment interest is due under a specific invoice, and request payment of all overdue late payment interest penalty and such additional penalty as may be required;

(2) Attach a copy of the invoice on which the unpaid late payment interest was due; and

(3) State that payment of the principal has been received, including the date of receipt.

(B) If there is no postmark or the postmark is illegible--

(1) The designated payment office that receives the demand will annotate it with the date of receipt provided the demand is received on or before the 40th day after payment was made; or

(2) If the designated payment office fails to make the required annotation, the Government will determine the demand's validity based on the date the Contractor has placed on the demand, provided such date is no later than the 40th day after payment was made.

(b) Contract financing payments. If this contract provides for contract financing, the Government will make contract financing payments in accordance with the applicable contract financing clause.

(c) Subcontract clause requirements. The Contractor shall include in each subcontract for property or services (including a material supplier) for the purpose of performing this contract the following:

(1) Prompt payment for subcontractors. A payment clause that obligates the Contractor to pay the subcontractor for satisfactory performance under its subcontract not later than 7 days from receipt of payment out of such amounts as are paid to the Contractor under this contract.

(2) Interest for subcontractors. An interest penalty clause that obligates the Contractor to pay to the subcontractor an interest penalty for each payment not made in accordance with the payment clause--

(i) For the period beginning on the day after the required payment date and ending on the date on which payment of the amount due is made; and

(ii) Computed at the rate of interest established by the Secretary of the Treasury, and published in the Federal Register, for interest payments under section 12 of the Contract Disputes Act of 1978 (41 U.S.C. 611) in effect at the time the Contractor accrues the obligation to pay an interest penalty.

(3) Subcontractor clause flowdown. A clause requiring each subcontractor to use:

(i) Include a payment clause and an interest penalty clause conforming to the standards set forth in paragraphs (c)(1) and (c)(2) of this clause in each of its subcontracts; and

(ii) Require each of its subcontractors to include such clauses in their subcontracts with each lower-tier subcontractor or supplier.

(d) Subcontract clause interpretation. The clauses required by paragraph (c) of this clause shall not be construed to impair the right of the Contractor or a subcontractor at any tier to negotiate, and to include in their subcontract, provisions that--

(1) Retainage permitted. Permit the Contractor or a subcontractor to retain (without cause) a specified percentage of each progress payment otherwise due to a subcontractor for satisfactory performance under the subcontract without incurring any obligation to pay a late payment interest penalty, in accordance with terms and conditions agreed to by the parties to the subcontract, giving such recognition as the parties deem appropriate to the ability of a subcontractor to furnish a performance bond and a payment bond;

(2) Withholding permitted. Permit the Contractor or subcontractor to make a determination that part or all of the subcontractor's request for payment may be withheld in accordance with the subcontract agreement; and

(3) Withholding requirements. Permit such withholding without incurring any obligation to pay a late payment penalty if--

(i) A notice conforming to the standards of paragraph (g) of this clause previously has been furnished to the subcontractor; and

(ii) The Contractor furnishes to the Contracting Officer a copy of any notice issued by a Contractor pursuant to paragraph (d)(3)(i) of this clause.

(e) Subcontractor withholding procedures. If a Contractor, after making a request for payment to the Government but before making a payment to a subcontractor for the subcontractor's performance covered by the payment request, discovers that all or a portion of the payment otherwise due such subcontractor is subject to withholding from the subcontractor in accordance with the subcontract agreement, then the Contractor shall--

(1) Subcontractor notice. Furnish to the subcontractor a notice conforming to the standards of paragraph (g) of this clause as soon as practicable upon ascertaining the cause giving rise to a withholding, but prior to the due date for subcontractor payment;

(2) Contracting Officer notice. Furnish to the Contracting Officer, as soon as practicable, a copy of the notice furnished to the subcontractor pursuant to paragraph (e)(1) of this clause;

(3) Subcontractor progress payment reduction. Reduce the subcontractor's progress payment by an amount not to exceed the amount specified in the notice of withholding furnished under paragraph (e)(1) of this clause;

(4) Subsequent subcontractor payment. Pay the subcontractor as soon as practicable after the correction of the identified subcontract performance deficiency, and--

(i) Make such payment within--

(A) Seven days after correction of the identified subcontract performance deficiency (unless the funds therefor must be recovered from the Government because of a reduction under paragraph (e)(5)(i) of this clause; or

(B) Seven days after the Contractor recovers such funds from the Government; or

(ii) Incur an obligation to pay a late payment interest penalty computed at the rate of interest established by the Secretary of the Treasury, and published in the Federal Register, for interest payments under section 12 of the Contracts Disputes Act of 1978 (41 U.S.C. 611) in effect at the time the Contractor accrues the obligation to pay an interest penalty;

(5) Notice to Contracting Officer. Notify the Contracting Officer upon--

(i) Reduction of the amount of any subsequent certified application for payment; or

(ii) Payment to the subcontractor of any withheld amounts of a progress payment, specifying--

(A) The amounts withheld under paragraph (e)(1) of this clause; and

(B) The dates that such withholding began and ended; and

(6) Interest to Government. Be obligated to pay to the Government an amount equal to interest on the withheld payments (computed in the manner provided in 31 U.S.C. 3903(c)(1)), from the 8th day after receipt of the withheld amounts from the Government until--

(i) The day the identified subcontractor performance deficiency is corrected; or

(ii) The date that any subsequent payment is reduced under paragraph (e)(5)(i) of this clause.

(f) Third-party deficiency reports--(1) Withholding from subcontractor. If a Contractor, after making payment to a first-tier subcontractor, receives from a supplier or subcontractor of the first-tier subcontractor (hereafter referred to as a "second-tier subcontractor") a written notice in accordance with section 2 of the Act of August 24, 1935 (40 U.S.C. 270b, Miller Act), asserting a deficiency in such first-tier subcontractor's performance under the contract for which the Contractor may be ultimately liable, and the Contractor determines that all or a portion of future payments otherwise due such first-tier subcontractor is subject to withholding in accordance with the

subcontract agreement, the Contractor may, without incurring an obligation to pay an interest penalty under paragraph (e)(6) of this clause--

(i) Furnish to the first-tier subcontractor a notice conforming to the standards of paragraph (g) of this clause as soon as practicable upon making such determination; and

(ii) Withhold from the first-tier subcontractor's next available progress payment or payments an amount not to exceed the amount specified in the notice of withholding furnished under paragraph (f)(1)(i) of this clause.

(2) Subsequent payment or interest charge. As soon as practicable, but not later than 7 days after receipt of satisfactory written notification that the identified subcontract performance deficiency has been corrected, the Contractor shall--

(i) Pay the amount withheld under paragraph (f)(1)(ii) of this clause to such first-tier subcontractor; or

(ii) Incur an obligation to pay a late payment interest penalty to such first-tier subcontractor computed at the rate of interest established by the Secretary of the Treasury, and published in the Federal Register, for interest payments under section 12 of the Contracts Disputes Act of 1978 (41 U.S.C. 611) in effect at the time the Contractor accrues the obligation to pay an interest penalty.

(g) Written notice of subcontractor withholding. The Contractor shall issue a written notice of any withholding to a subcontractor (with a copy furnished to the Contracting Officer), specifying--

(1) The amount to be withheld;

(2) The specific causes for the withholding under the terms of the subcontract; and

(3) The remedial actions to be taken by the subcontractor in order to receive payment of the amounts withheld.

(h) Subcontractor payment entitlement. The Contractor may not request payment from the Government of any amount withheld or retained in accordance with paragraph (d) of this clause until such time as the Contractor has determined and certified to the Contracting Officer that the subcontractor is entitled to the payment of such amount.

(i) Prime-subcontractor disputes. A dispute between the Contractor and subcontractor relating to the amount or entitlement of a subcontractor to a payment or a late payment interest penalty under a clause included in the subcontract pursuant to paragraph (c) of this clause does not constitute a dispute to which the Government is a party. The Government may not be interpleaded in any judicial or administrative proceeding involving such a dispute.

(j) Preservation of prime-subcontractor rights. Except as provided in paragraph (i) of this clause, this clause shall not limit or impair any contractual, administrative, or judicial remedies otherwise available to the Contractor or a subcontractor in the event of a dispute involving late payment or

nonpayment by the Contractor or deficient subcontract performance or nonperformance by a subcontractor.

(k) Non-recourse for prime contractor interest penalty. The Contractor's obligation to pay an interest penalty to a subcontractor pursuant to the clauses included in a subcontract under paragraph (c) of this clause shall not be construed to be an obligation of the Government for such interest penalty. A cost-reimbursement claim may not include any amount for reimbursement of such interest penalty.

(l) Overpayments. If the Contractor becomes aware of a duplicate payment or that the Government has otherwise overpaid on an invoice payment, the Contractor shall immediately notify the Contracting Officer and request instructions for disposition of the overpayment.

52.232-33 PAYMENT BY ELECTRONIC FUNDS TRANSFER—CENTRAL CONTRACTOR REGISTRATION (MAY 1999)

(a) Method of payment. (1) All payments by the Government under this contract shall be made by electronic funds transfer (EFT), except as provided in paragraph (a)(2) of this clause. As used in this clause, the term “EFT” refers to the funds transfer and may also include the payment information transfer.

(2) In the event the Government is unable to release one or more payments by EFT, the Contractor agrees to either--

(i) Accept payment by check or some other mutually agreeable method of payment; or

(ii) Request the Government to extend the payment due date until such time as the Government can make payment by EFT (but see paragraph (d) of this clause).

(b) Contractor's EFT information. The Government shall make payment to the Contractor using the EFT information contained in the Central Contractor Registration (CCR) database. In the event that the EFT information changes, the Contractor shall be responsible for providing the updated information to the CCR database.

(c) Mechanisms for EFT payment. The Government may make payment by EFT through either the Automated Clearing House (ACH) network, subject to the rules of the National Automated Clearing House Association, or the Fedwire Transfer System. The rules governing Federal payments through the ACH are contained in 31 CFR part 210.

(d) Suspension of payment. If the Contractor's EFT information in the CCR database is incorrect, then the Government need not make payment to the Contractor under this contract until correct EFT information is entered into the CCR database; and any invoice or contract financing request shall be deemed not to be a proper invoice for the purpose of prompt payment under this contract. The prompt payment terms of the contract regarding notice of an improper invoice and delays in accrual of interest penalties apply.

(e) Contractor EFT arrangements. If the Contractor has identified multiple payment receiving points (i.e., more than one remittance address and/or EFT information set) in the CCR database, and the Contractor has not notified the Government of the payment receiving point applicable to this contract, the Government shall make payment to the first payment receiving point (EFT information set or remittance address as applicable) listed in the CCR database.

(f) Liability for uncompleted or erroneous transfers. (1) If an uncompleted or erroneous transfer occurs because the Government used the Contractor's EFT information incorrectly, the Government remains responsible for--

(i) Making a correct payment;

(ii) Paying any prompt payment penalty due; and

(iii) Recovering any erroneously directed funds.

(2) If an uncompleted or erroneous transfer occurs because the Contractor's EFT information was incorrect, or was revised within 30 days of Government release of the EFT payment transaction instruction to the Federal Reserve System, and--

(i) If the funds are no longer under the control of the payment office, the Government is deemed to have made payment and the Contractor is responsible for recovery of any erroneously directed funds; or

(ii) If the funds remain under the control of the payment office, the Government shall not make payment, and the provisions of paragraph (d) of this clause shall apply.

(g) EFT and prompt payment. A payment shall be deemed to have been made in a timely manner in accordance with the prompt payment terms of this contract if, in the EFT payment transaction instruction released to the Federal Reserve System, the date specified for settlement of the payment is on or before the prompt payment due date, provided the specified payment date is a valid date under the rules of the Federal Reserve System.

(h) EFT and assignment of claims. If the Contractor assigns the proceeds of this contract as provided for in the assignment of claims terms of this contract, the Contractor shall require as a condition of any such assignment, that the assignee shall register in the CCR database and shall be paid by EFT in accordance with the terms of this clause. In all respects, the requirements of this clause shall apply to the assignee as if it were the Contractor. EFT information that shows the ultimate recipient of the transfer to be other than the Contractor, in the absence of a proper assignment of claims acceptable to the Government, is incorrect EFT information within the meaning of paragraph (d) of this clause.

(i) Liability for change of EFT information by financial agent. The Government is not liable for errors resulting from changes to EFT information made by the Contractor's financial agent.

(j) Payment information. The payment or disbursing office shall forward to the Contractor available payment information that is suitable for transmission as of the date of release of the EFT instruction to the Federal Reserve System. The Government may request the Contractor to designate a desired format and method(s) for delivery of payment information from a list of formats and methods the payment office is capable of executing. However, the Government does not guarantee that any particular format or method of delivery is available at any particular payment office and retains the latitude to use the format and delivery method most convenient to the Government. If the Government makes payment by check in accordance with paragraph (a) of this clause, the Government shall mail the payment information to the remittance address contained in the CCR database.

52.232-35 DESIGNATION OF OFFICE FOR GOVERNMENT RECEIPT OF ELECTRONIC FUNDS TRANSFER INFORMATION (MAY 1999)

(a) As provided in paragraph (b) of the clause at 52.232-34, Payment by Electronic Funds Transfer-- Other than Central Contractor Registration, the Government has designated the office cited in paragraph (c) of this clause as the office to receive the Contractor's electronic funds transfer (EFT) information, in lieu of the payment office of this contract.

(b) The Contractor shall send all EFT information, and any changes to EFT information to the office designated in paragraph (c) of this clause. The Contractor shall not send EFT information to the payment office, or any other office than that designated in paragraph (c). The Government need not use any EFT information sent to any office other than that designated in paragraph (c).

(c) Designated Office:

Name: USACE FINCEN

Mailing Address: 5722 Integrity Drive, Millington, TN 38054

Telephone Number: 901-874-8650

52.233-1 DISPUTES. (DEC 1998)

(a) This contract is subject to the Contract Disputes Act of 1978, as amended (41 U.S.C. 601-613).

(b) Except as provided in the Act, all disputes arising under or relating to this contract shall be resolved under this clause.

(c) "Claim," as used in this clause, means a written demand or written assertion by one of the contracting parties seeking, as a matter of right, the payment of money in a sum certain, the adjustment or interpretation of contract terms, or other relief arising under or relating to this contract. A claim arising under a contract, unlike a claim relating to that contract, is a claim that can be resolved under a contract clause that provides for the relief sought by the claimant. However, a written demand or written assertion by the Contractor seeking the payment of money exceeding \$100,000 is not a claim under the Act until certified as required by subparagraph (d)(2)

of this clause. A voucher, invoice, or other routine request for payment that is not in dispute when submitted is not a claim under the Act. The submission may be converted to a claim under the Act, by complying with the submission and certification requirements of this clause, if it is disputed either as to liability or amount or is not acted upon in a reasonable time.

(d)(1) A claim by the Contractor shall be made in writing and, unless otherwise stated in this contract, submitted within 6 years after accrual of the claim to the Contracting Officer for a written decision. A claim by the Government against the Contractor shall be subject to a written decision by the Contracting Officer.

(2)(i) The contractors shall provide the certification specified in subparagraph (d)(2)(iii) of this clause when submitting any claim -

(A) Exceeding \$100,000; or

(B) Regardless of the amount claimed, when using -

(1) Arbitration conducted pursuant to 5 U.S.C. 575-580; or

(2) Any other alternative means of dispute resolution (ADR) technique that the agency elects to handle in accordance with the Administrative Dispute Resolution Act (ADRA).

(ii) The certification requirement does not apply to issues in controversy that have not been submitted as all or part of a claim.

(iii) The certification shall state as follows: "I certify that the claim is made in good faith; that the supporting data are accurate and complete to the best of my knowledge and belief; that the amount requested accurately reflects the contract adjustment for which the Contractor believes the Government is liable; and that I am duly authorized to certify the claim on behalf of the Contractor.

(3) The certification may be executed by any person duly authorized to bind the Contractor with respect to the claim.

(e) For Contractor claims of \$100,000 or less, the Contracting Officer must, if requested in writing by the Contractor, render a decision within 60 days of the request. For Contractor-certified claims over \$100,000, the Contracting Officer must, within 60 days, decide the claim or notify the Contractor of the date by which the decision will be made.

(f) The Contracting Officer's decision shall be final unless the Contractor appeals or files a suit as provided in the Act.

(g) If the claim by the Contractor is submitted to the Contracting Officer or a claim by the Government is presented to the Contractor, the parties, by mutual consent, may agree to use alternative dispute resolution (ADR). If the Contractor refuses an offer for ADR, the Contractor shall inform the Contracting Officer, in writing, of the Contractor's specific reasons for rejecting the request.

(h) The Government shall pay interest on the amount found due and unpaid from (1) the date the Contracting Officer receives the claim (certified, if required); or (2) the date that payment otherwise would be due, if that date is later, until the date of payment. With regard to claims having defective certifications, as defined in (FAR) 48 CFR 33.201, interest shall be paid from the date that the Contracting Officer initially receives the claim. Simple interest on claims shall be paid at the rate, fixed by the Secretary of the Treasury as provided in the Act, which is applicable to the period during which the Contracting Officer receives the claim and then at the rate applicable for each 6-month period as fixed by the Treasury Secretary during the pendency of the claim.

(i) The Contractor shall proceed diligently with performance of this contract, pending final resolution of any request for relief, claim, appeal, or action arising under the contract, and comply with any decision of the Contracting Officer.

52.233-3 PROTEST AFTER AWARD (AUG. 1996)

(a) Upon receipt of a notice of protest (as defined in FAR 33.101) or a determination that a protest is likely (see FAR 33.102(d)), the Contracting Officer may, by written order to the Contractor, direct the Contractor to stop performance of the work called for by this contract. The order shall be specifically identified as a stop-work order issued under this clause. Upon receipt of the order, the Contractor shall immediately comply with its terms and take all reasonable steps to minimize the incurrence of costs allocable to the work covered by the order during the period of work stoppage. Upon receipt of the final decision in the protest, the Contracting Officer shall either--

(1) Cancel the stop-work order; or

(2) Terminate the work covered by the order as provided in the Default, or the Termination for Convenience of the Government, clause of this contract.

(b) If a stop-work order issued under this clause is canceled either before or after a final decision in the protest, the Contractor shall resume work. The Contracting Officer shall make an equitable adjustment in the delivery schedule or contract price, or both, and the contract shall be modified, in writing, accordingly, if--

(1) The stop-work order results in an increase in the time required for, or in the Contractor's cost properly allocable to, the performance of any part of this contract; and

(2) The Contractor asserts its right to an adjustment within 30 days after the end of the period of work stoppage; provided, that if the Contracting Officer decides the facts justify the action, the Contracting Officer may receive and act upon a proposal at any time before final payment under this contract.

(c) If a stop-work order is not canceled and the work covered by the order is terminated for the convenience of the Government, the Contracting Officer shall allow reasonable costs resulting from the stop-work order in arriving at the termination settlement.

(d) If a stop-work order is not canceled and the work covered by the order is terminated for default, the Contracting Officer shall allow, by equitable adjustment or otherwise, reasonable costs resulting from the stop-work order.

(e) The Government's rights to terminate this contract at any time are not affected by action taken under this clause.

(f) If, as the result of the Contractor's intentional or negligent misstatement, misrepresentation, or miscertification, a protest related to this contract is sustained, and the Government pays costs, as provided in FAR 33.102(b)(2) or 33.104(h)(1), the Government may require the Contractor to reimburse the Government the amount of such costs. In addition to any other remedy available, and pursuant to the requirements of Subpart 32.6, the Government may collect this debt by offsetting the amount against any payment due the Contractor under any contract between the Contractor and the Government.

52.236-2 DIFFERING SITE CONDITIONS (APR 1984)

(a) The Contractor shall promptly, and before the conditions are disturbed, give a written notice to the Contracting Officer of

(1) subsurface or latent physical conditions at the site which differ materially from those indicated in this contract, or

(2) unknown physical conditions at the site, of an unusual nature, which differ materially from those ordinarily encountered and generally recognized as inhering in work of the character provided for in the contract.

(b) The Contracting Officer shall investigate the site conditions promptly after receiving the notice. If the conditions do materially so differ and cause an increase or decrease in the Contractor's cost of, or the time required for, performing any part of the work under this contract, whether or not changed as a result of the conditions, an equitable adjustment shall be made under this clause and the contract modified in writing accordingly.

(c) No request by the Contractor for an equitable adjustment to the contract under this clause shall be allowed, unless the Contractor has given the written notice required; provided, that the time prescribed in (a) above for giving written notice may be extended by the Contracting Officer.

(d) No request by the Contractor for an equitable adjustment to the contract for differing site conditions shall be allowed if made after final payment under this contract.

52.236-3 SITE INVESTIGATION AND CONDITIONS AFFECTING THE WORK (APR 1984)

(a) The Contractor acknowledges that it has taken steps reasonably necessary to ascertain the nature

and location of the work, and that it has investigated and satisfied itself as to the general and local conditions which can affect the work or its cost, including but not limited to

- (1) conditions bearing upon transportation, disposal, handling, and storage of materials;
- (2) the availability of labor, water, electric power, and roads;
- (3) uncertainties of weather, river stages, tides, or similar physical conditions at the site;
- (4) the conformation and conditions of the ground; and (5) the character of equipment and facilities needed preliminary to and during work performance. The Contractor also acknowledges that it has satisfied itself as to the character, quality, and quantity of surface and subsurface materials or obstacles to be encountered insofar as this information is reasonably ascertainable from an inspection of the site, including all exploratory work done by the Government, as well as from the drawings and specifications made a part of this contract. Any failure of the Contractor to take the actions described and acknowledged in this paragraph will not relieve the Contractor from responsibility for estimating properly the difficulty and cost of successfully performing the work, or for proceeding to successfully perform the work without additional expense to the Government.

(b) The Government assumes no responsibility for any conclusions or interpretations made by the Contractor based on the information made available by the Government. Nor does the Government assume responsibility for any understanding reached or representation made concerning conditions which can affect the work by any of its officers or agents before the execution of this contract, unless that understanding or representation is expressly stated in this contract.

52.236-5 MATERIAL AND WORKMANSHIP (APR 1984)

(a) All equipment, material, and articles incorporated into the work covered by this contract shall be new and of the most suitable grade for the purpose intended, unless otherwise specifically provided in this contract. References in the specifications to equipment, material, articles, or patented processes by trade name, make, or catalog number, shall be regarded as establishing a standard of quality and shall not be construed as limiting competition. The Contractor may, at its option, use any equipment, material, article, or process that, in the judgment of the Contracting Officer, is equal to that named in the specifications, unless otherwise specifically provided in this contract.

(b) The Contractor shall obtain the Contracting Officer's approval of the machinery and mechanical and other equipment to be incorporated into the work. When requesting approval, the Contractor shall furnish to the Contracting Officer the name of the manufacturer, the model number, and other information concerning the performance, capacity, nature, and rating of the machinery and mechanical and other equipment. When required by this contract or by the Contracting Officer, the Contractor shall also obtain the Contracting Officer's approval of the material or articles which the Contractor contemplates incorporating into the work. When requesting approval, the Contractor shall provide full information concerning the material or articles. When directed to do so, the Contractor shall submit samples for approval at the Contractor's expense, with all shipping charges prepaid. Machinery, equipment, material, and articles that do not have the required approval shall

be installed or used at the risk of subsequent rejection.

(c) All work under this contract shall be performed in a skillful and workmanlike manner. The Contracting Officer may require, in writing, that the Contractor remove from the work any employee the Contracting Officer deems incompetent, careless, or otherwise objectionable.

52.236-6 SUPERINTENDENCE BY THE CONTRACTOR (APR 1984)

At all times during performance of this contract and until the work is completed and accepted, the Contractor shall directly superintend the work or assign and have on the worksite a competent superintendent who is satisfactory to the Contracting Officer and has authority to act for the Contractor.

52.236-7 PERMITS AND RESPONSIBILITIES (NOV 1991)

The Contractor shall, without additional expense to the Government, be responsible for obtaining any necessary licenses and permits, and for complying with any Federal, State, and municipal laws, codes, and regulations applicable to the performance of the work. The Contractor shall also be responsible for all damages to persons or property that occur as a result of the Contractor's fault or negligence. The Contractor shall also be responsible for all materials delivered and work performed until completion and acceptance of the entire work, except for any completed unit of work which may have been accepted under the contract.

52.236-8 OTHER CONTRACTS (APR 1984)

The Government may undertake or award other contracts for additional work at or near the site of the work under this contract. The Contractor shall fully cooperate with the other contractors and with Government employees and shall carefully adapt scheduling and performing the work under this contract to accommodate the additional work, heeding any direction that may be provided by the Contracting Officer. The Contractor shall not commit or permit any act that will interfere with the performance of work by any other contractor or by Government employees.

52.236-9 PROTECTION OF EXISTING VEGETATION, STRUCTURES, EQUIPMENT, UTILITIES, AND IMPROVEMENTS (APR 1984)

(a) The Contractor shall preserve and protect all structures, equipment, and vegetation (such as trees, shrubs, and grass) on or adjacent to the work site, which are not to be removed and which do not unreasonably interfere with the work required under this contract. The Contractor shall only remove trees when specifically authorized to do so, and shall avoid damaging vegetation that will remain in place. If any limbs or branches of trees are broken during contract performance, or by the careless operation of equipment, or by workmen, the Contractor shall trim those limbs or branches with a clean cut and paint the cut with a tree-pruning compound as directed by the Contracting

Officer.

(b) The Contractor shall protect from damage all existing improvements and utilities

(1) at or near the work site, and

(2) on adjacent property of a third party, the locations of which are made known to or should be known by the Contractor. The Contractor shall repair any damage to those facilities, including those that are the property of a third party, resulting from failure to comply with the requirements of this contract or failure to exercise reasonable care in performing the work. If the Contractor fails or refuses to repair the damage promptly, the Contracting Officer may have the necessary work performed and charge the cost to the Contractor.

52.236-10 OPERATIONS AND STORAGE AREAS (APR 1984)

(a) The Contractor shall confine all operations (including storage of materials) on Government premises to areas authorized or approved by the Contracting Officer. The Contractor shall hold and save the Government, its officers and agents, free and harmless from liability of any nature occasioned by the Contractor's performance.

(b) Temporary buildings (e.g., storage sheds, shops, offices) and utilities may be erected by the Contractor only with the approval of the Contracting Officer and shall be built with labor and materials furnished by the Contractor without expense to the Government. The temporary buildings and utilities shall remain the property of the Contractor and shall be removed by the Contractor at its expense upon completion of the work. With the written consent of the Contracting Officer, the buildings and utilities may be abandoned and need not be removed.

(c) The Contractor shall, under regulations prescribed by the Contracting Officer, use only established roadways, or use temporary roadways constructed by the Contractor when and as authorized by the Contracting Officer. When materials are transported in prosecuting the work, vehicles shall not be loaded beyond the loading capacity recommended by the manufacturer of the vehicle or prescribed by any Federal, State, or local law or regulation. When it is necessary to cross curbs or sidewalks, the Contractor shall protect them from damage. The Contractor shall repair or pay for the repair of any damaged curbs, sidewalks, or roads.

52.236-11 USE AND POSSESSION PRIOR TO COMPLETION (APR 1984)

(a) The Government shall have the right to take possession of or use any completed or partially completed part of the work. Before taking possession of or using any work, the Contracting Officer shall furnish the Contractor a list of items of work remaining to be performed or corrected on those portions of the work that the Government intends to take possession of or use. However, failure of the Contracting Officer to list any item of work shall not relieve the Contractor of responsibility for complying with the terms of the contract. The Government's possession or use shall not be deemed an acceptance of any work under the contract.

(b) While the Government has such possession or use, the Contractor shall be relieved of the responsibility for the loss of or damage to the work resulting from the Government's possession or use, notwithstanding the terms of the clause in this contract entitled "Permits and Responsibilities." If prior possession or use by the Government delays the progress of the work or causes additional expense to the Contractor, an equitable adjustment shall be made in the contract price or the time of completion, and the contract shall be modified in writing accordingly.

52.236-12 CLEANING UP (APR 1984)

The Contractor shall at all times keep the work area, including storage areas, free from accumulations of waste materials. Before completing the work, the Contractor shall remove from the work and premises any rubbish, tools, scaffolding, equipment, and materials that are not the property of the Government. Upon completing the work, the Contractor shall leave the work area in a clean, neat, and orderly condition satisfactory to the Contracting Officer.

52.236-13 ACCIDENT PREVENTION (NOV 1991)

(a) The Contractor shall provide and maintain work environments and procedures which will

(1) safeguard the public and Government personnel, property, materials, supplies, and equipment exposed to Contractor operations and activities;

(2) avoid interruptions of Government operations and delays in project completion dates; and

(3) control costs in the performance of this contract.

(b) For these purposes on contracts for construction or dismantling, demolition, or removal of improvements, the Contractor shall-

(1) Provide appropriate safety barricades, signs, and signal lights;

(2) Comply with the standards issued by the Secretary of Labor at 29 CFR Part 1926 and 29 CFR Part 1910; and

(3) Ensure that any additional measures the Contracting Officer determines to be reasonably necessary for the purposes are taken.

(c) If this contract is for construction or dismantling, demolition or removal of improvements with any Department of Defense agency or component, the Contractor shall comply with all pertinent provisions of the latest version of U.S. Army Corps of Engineers Safety and Health Requirements Manual, EM 385-1-1, in effect on the date of the solicitation.

(d) Whenever the Contracting Officer becomes aware of any noncompliance with these requirements or any condition which poses a serious or imminent danger to the health or safety of

the public or Government personnel, the Contracting Officer shall notify the Contractor orally, with written confirmation, and request immediate initiation of corrective action. This notice, when delivered to the Contractor or the Contractor's representative at the work site, shall be deemed sufficient notice of the noncompliance and that corrective action is required. After receiving the notice, the Contractor shall immediately take corrective action. If the Contractor fails or refuses to promptly take corrective action, the Contracting Officer may issue an order stopping all or part of the work until satisfactory corrective action has been taken. The Contractor shall not be entitled to any equitable adjustment of the contract price or extension of the performance schedule on any stop work order issued under this clause.

(e) The Contractor shall insert this clause, including this paragraph (e), with appropriate changes in the designation of the parties, in subcontracts.

52.236-15 SCHEDULES FOR CONSTRUCTION CONTRACTS (APR 1984)

(a) The Contractor shall, within five days after the work commences on the contract or another period of time determined by the Contracting Officer, prepare and submit to the Contracting Officer for approval three copies of a practicable schedule showing the order in which the Contractor proposes to perform the work, and the dates on which the Contractor contemplates starting and completing the several salient features of the work (including acquiring materials, plant, and equipment). The schedule shall be in the form of a progress chart of suitable scale to indicate appropriately the percentage of work scheduled for completion by any given date during the period. If the Contractor fails to submit a schedule within the time prescribed, the Contracting Officer may withhold approval of progress payments until the Contractor submits the required schedule.

(b) The Contractor shall enter the actual progress on the chart as directed by the Contracting Officer, and upon doing so shall immediately deliver three copies of the annotated schedule to the Contracting Officer. If, in the opinion of the Contracting Officer, the Contractor falls behind the approved schedule, the Contractor shall take steps necessary to improve its progress, including those that may be required by the Contracting Officer, without additional cost to the Government. In this circumstance, the Contracting Officer may require the Contractor to increase the number of shifts, overtime operations, days of work, and/or the amount of construction plant, and to submit for approval any supplementary schedule or schedules in chart form as the Contracting Officer deems necessary to demonstrate how the approved rate of progress will be regained.

(c) Failure of the Contractor to comply with the requirements of the Contracting Officer under this clause shall be grounds for a determination by the Contracting Officer that the Contractor is not prosecuting the work with sufficient diligence to ensure completion within the time specified in the contract. Upon making this determination, the Contracting Officer may terminate the Contractor's right to proceed with the work, or any separable part of it, in accordance with the default terms of this contract.

52.236-17 LAYOUT OF WORK (APR 1984)

The Contractor shall lay out its work from Government established base lines and bench marks indicated on the drawings, and shall be responsible for all measurements in connection with the layout. The Contractor shall furnish, at its own expense, all stakes, templates, platforms, equipment, tools, materials, and labor required to lay out any part of the work. The Contractor shall be responsible for executing the work to the lines and grades that may be established or indicated by the Contracting Officer. The Contractor shall also be responsible for maintaining and preserving all stakes and other marks established by the Contracting Officer until authorized to remove them. If such marks are destroyed by the Contractor or through its negligence before their removal is authorized, the Contracting Officer may replace them and deduct the expense of the replacement from any amounts due or to become due to the Contractor.

52.236-21 SPECIFICATIONS AND DRAWINGS FOR CONSTRUCTION (FEB 1997) -
ALTERNATE I (APR 1984

(a) The Contractor shall keep on the work site a copy of the drawings and specifications and shall at all times give the Contracting Officer access thereto. Anything mentioned in the specifications and not shown on the drawings, or shown on the drawings and not mentioned in the specifications, shall be of like effect as if shown or mentioned in both. In case of difference between drawings and specifications, the specifications shall govern. In case of discrepancy in the figures, in the drawings, or in the specifications, the matter shall be promptly submitted to the Contracting Officer, who shall promptly make a determination in writing. Any adjustment by the Contractor without such a determination shall be at its own risk and expense. The Contracting Officer shall furnish from time to time such detailed drawings and other information as considered necessary, unless otherwise provided.

(b) Wherever in the specifications or upon the drawings the words "directed", "required", "ordered", "designated", "prescribed", or words of like import are used, it shall be understood that the "direction", "requirement", "order", "designation", or "prescription", of the Contracting Officer is intended and similarly the words "approved", "acceptable", "satisfactory", or words of like import shall mean "approved by," or "acceptable to", or "satisfactory to" the Contracting Officer, unless otherwise expressly stated.

(c) Where "as shown," as indicated", "as detailed", or words of similar import are used, it shall be understood that the reference is made to the drawings accompanying this contract unless stated otherwise. The word "provided" as used herein shall be understood to mean "provide complete in place," that is "furnished and installed".

(d) Shop drawings means drawings, submitted to the Government by the Contractor, subcontractor, or any lower tier subcontractor pursuant to a construction contract, showing in detail (1) the proposed fabrication and assembly of structural elements, and (2) the installation (i.e., fit, and attachment details) of materials or equipment. It includes drawings, diagrams, layouts, schematics, descriptive literature, illustrations, schedules, performance and test data, and similar materials furnished by the contractor to explain in detail specific portions of the work required by the contract. The Government may duplicate, use, and disclose in any manner and for any purpose shop drawings delivered under this contract.

(e) If this contract requires shop drawings, the Contractor shall coordinate all such drawings, and review them for accuracy, completeness, and compliance with contract requirements and shall indicate its approval thereon as evidence of such coordination and review. Shop drawings submitted to the Contracting Officer without evidence of the Contractor's approval may be returned for resubmission. The Contracting Officer will indicate an approval or disapproval of the shop drawings and if not approved as submitted shall indicate the Government's reasons therefor. Any work done before such approval shall be at the Contractor's risk. Approval by the Contracting Officer shall not relieve the Contractor from responsibility for any errors or omissions in such drawings, nor from responsibility for complying with the requirements of this contract, except with respect to variations described and approved in accordance with (f) below.

(f) If shop drawings show variations from the contract requirements, the Contractor shall describe such variations in writing, separate from the drawings, at the time of submission. If the Contracting Officer approves any such variation, the Contracting Officer shall issue an appropriate contract modification, except that, if the variation is minor or does not involve a change in price or in time of performance, a modification need not be issued.

(g) The Contractor shall submit to the Contracting Officer for approval four copies (unless otherwise indicated) of all shop drawings as called for under the various headings of these specifications. Three sets (unless otherwise indicated) of all shop drawings, will be retained by the Contracting Officer and one set will be returned to the Contractor. Upon completing the work under this contract, the Contractor shall furnish a complete set of all shop drawings as finally approved. These drawings shall show all changes and revisions made up to the time the equipment is completed and accepted.

52.236-26 PRECONSTRUCTION CONFERENCE (FEB 1995)

If the Contracting Officer decides to conduct a preconstruction conference, the successful offeror will be notified and will be required to attend. The Contracting Officer's notification will include specific details regarding the date, time, and location of the conference, any need for attendance by subcontractors, and information regarding the items to be discussed.

52.242-13 BANKRUPTCY (JUL 1995)

In the event the Contractor enters into proceedings relating to bankruptcy, whether voluntary or involuntary, the Contractor agrees to furnish, by certified mail or electronic commerce method authorized by the contract, written notification of the bankruptcy to the Contracting Officer responsible for administering the contract. This notification shall be furnished within five days of the initiation of the proceedings relating to bankruptcy filing. This notification shall include the date on which the bankruptcy petition was filed, the identity of the court in which the bankruptcy petition was filed, and a listing of Government contract numbers and contracting offices for all Government contracts against which final payment has not been made. This obligation remains in effect until final payment under this contract.

52.242-14 SUSPENSION OF WORK (APR 1984)

(a) The Contracting Officer may order the Contractor, in writing, to suspend, delay, or interrupt all or any part of the work of this contract for the period of time that the Contracting Officer determines appropriate for the convenience of the Government.

(b) If the performance of all or any part of the work is, for an unreasonable period of time, suspended, delayed, or interrupted (1) by an act of the Contracting Officer in the administration of this contract, or (2) by the Contracting Officer's failure to act within the time specified in this contract (or within a reasonable time if not specified), an adjustment shall be made for any increase in the cost of performance of this contract (excluding profit) necessarily caused by the unreasonable suspension, delay, or interruption, and the contract modified in writing accordingly. However, no adjustment shall be made under this clause for any suspension, delay, or interruption to the extent that performance would have been so suspended, delayed, or interrupted by any other cause, including the fault or negligence of the Contractor, or for which an equitable adjustment is provided for or excluded under any other term or condition of this contract. (c) A claim under this clause shall not be allowed (1) for any costs incurred more than 20 days before the Contractor shall have notified the Contracting Officer in writing of the act or failure to act involved (but this requirement shall not apply as to a claim resulting from a suspension order), and (2) unless the claim, in an amount stated, is asserted in writing as soon as practicable after the termination of the suspension, delay, or interruption, but not later than the date of final payment under the contract.

52.243-4 CHANGES (AUG 1987)

(a) The Contracting Officer may, at any time, without notice to the sureties, if any, by written order designated or indicated to be a change order, make changes in the work within the general scope of the contract, including changes--

- (1) In the specifications (including drawings and designs);
- (2) In the method or manner of performance of the work;
- (3) In the Government-furnished facilities, equipment, materials, services, or site; or
- (4) Directing acceleration in the performance of the work.

(b) Any other written or oral order (which, as used in this paragraph (b), includes direction, instruction, interpretation, or determination) from the Contracting Officer that causes a change shall be treated as a change order under this clause; provided, that the Contractor gives the Contracting Officer written notice stating

- (1) the date, circumstances, and source of the order and

(2) that the Contractor regards the order as a change order.

(c) Except as provided in this clause, no order, statement, or conduct of the Contracting Officer shall be treated as a change under this clause or entitle the Contractor to an equitable adjustment.

(d) If any change under this clause causes an increase or decrease in the Contractor's cost of, or the time required for, the performance of any part of the work under this contract, whether or not changed by any such order, the Contracting Officer shall make an equitable adjustment and modify the contract in writing. However, except for an adjustment based on defective specifications, no adjustment for any change under paragraph (b) of this clause shall be made for any costs incurred more than 20 days before the Contractor gives written notice as required. In the case of defective specifications for which the Government is responsible, the equitable adjustment shall include any increased cost reasonably incurred by the Contractor in attempting to comply with the defective specifications.

(e) The Contractor must assert its right to an adjustment under this clause within 30 days after

(1) receipt of a written change order under paragraph (a) of this clause or (2) the furnishing of a written notice under paragraph (b) of this clause, by submitting to the Contracting Officer a written statement describing the general nature and amount of the proposal, unless this period is extended by the Government. The statement of proposal for adjustment may be included in the notice under paragraph (b) above.

(f) No proposal by the Contractor for an equitable adjustment shall be allowed if asserted after final payment under this contract.

52.244-6 SUBCONTRACTS FOR COMMERCIAL ITEMS (MAY 2002)

(a) Definitions. As used this clause--

"Commercial item", has the meaning contained in the clause at 52.202-1, Definitions.

"Subcontract", includes a transfer of commercial items between divisions, subsidiaries, or affiliates of the Contractor or subcontractor at any tier.

(b) To the maximum extent practicable, the Contractor shall incorporate, and require its subcontractors at all tiers to incorporate, commercial items or nondevelopmental items as components of items to be supplied under this contract.

(c)(1) The Contractor shall insert the following clauses in subcontracts for commercial items:

(i) 52.219-8, Utilization of Small Business Concerns (OCT 2000) (15 U.S.C. 637(d)(2) and (3)), in all subcontracts that offer further subcontracting opportunities. If the subcontract (except subcontracts to small business concerns) exceeds \$500,000 (\$1,000,000 for construction of any

public facility), the subcontractor must include 52.219-8 in lower tier subcontracts that offer subcontracting opportunities.

(ii) 52.222-26, Equal Opportunity (APR 2002) (E.O. 11246).

(iii) 52.222-35, Equal Opportunity for Special Disabled Veterans, Veterans of the Vietnam Era and Other Eligible Veterans (DEC 2001) (38 U.S.C. 4212(a)).

(iv) 52.222-36, Affirmative Action for Workers with Disabilities (JUN 1998) (29 U.S.C. 793).

(v) 52.247-64, Preference for Privately Owned U.S.-Flag Commercial Vessels (JUN 2000) (46 U.S.C. Appx 1241) (flowdown not required for subcontracts awarded beginning May 1, 1996).

(2) While not required, the Contractor may flow down to subcontracts for commercial items a minimal number of additional clauses necessary to satisfy its contractual obligations.

(d) The Contractor shall include the terms of this clause, including this paragraph (d), in subcontracts awarded under this contract.

52.246-12 INSPECTION OF CONSTRUCTION (AUG 1996)

(a) Definition. "Work" includes, but is not limited to, materials, workmanship, and manufacture and fabrication of components.

(b) The Contractor shall maintain an adequate inspection system and perform such inspections as will ensure that the work performed under the contract conforms to contract requirements. The Contractor shall maintain complete inspection records and make them available to the Government. All work shall be conducted under the general direction of the Contracting Officer and is subject to Government inspection and test at all places and at all reasonable times before acceptance to ensure strict compliance with the terms of the contract.

(c) Government inspections and tests are for the sole benefit of the Government and do not--

(1) Relieve the Contractor of responsibility for providing adequate quality control measures;

(2) Relieve the Contractor of responsibility for damage to or loss of the material before acceptance;

(3) Constitute or imply acceptance; or

(4) Affect the continuing rights of the Government after acceptance of the completed work under paragraph (i) of this section.

(d) The presence or absence of a Government inspector does not relieve the Contractor from any contract requirement, nor is the inspector authorized to change any term or condition of the specification without the Contracting Officer's written authorization.

(e) The Contractor shall promptly furnish, at no increase in contract price, all facilities, labor, and material reasonably needed for performing such safe and convenient inspections and tests as may be required by the Contracting Officer. The Government may charge to the Contractor any additional cost of inspection or test when work is not ready at the time specified by the Contractor for inspection or test, or when prior rejection makes reinspection or retest necessary. The Government shall perform all inspections and tests in a manner that will not unnecessarily delay the work. Special, full size, and performance tests shall be performed as described in the contract.

(f) The Contractor shall, without charge, replace or correct work found by the Government not to conform to contract requirements, unless in the public interest the Government consents to accept the work with an appropriate adjustment in contract price. The Contractor shall promptly segregate and remove rejected material from the premises.

(g) If the Contractor does not promptly replace or correct rejected work, the Government may (1) by contract or otherwise, replace or correct the work and charge the cost to the Contractor or (2) terminate for default the Contractor's right to proceed.

(h) If, before acceptance of the entire work, the Government decides to examine already completed work by removing it or tearing it out, the Contractor, on request, shall promptly furnish all necessary facilities, labor, and material. If the work is found to be defective or nonconforming in any material respect due to the fault of the Contractor or its subcontractors, the Contractor shall defray the expenses of the examination and of satisfactory reconstruction. However, if the work is found to meet contract requirements, the Contracting Officer shall make an equitable adjustment for the additional services involved in the examination and reconstruction, including, if completion of the work was thereby delayed, an extension of time.

(i) Unless otherwise specified in the contract, the Government shall accept, as promptly as practicable after completion and inspection, all work required by the contract or that portion of the work the Contracting Officer determines can be accepted separately. Acceptance shall be final and conclusive except for latent defects, fraud, gross mistakes amounting to fraud, or the Government's rights under any warranty or guarantee.

52.246-21 WARRANTY OF CONSTRUCTION (MAR 1994)

(a) In addition to any other warranties in this contract, the Contractor warrants, except as provided in paragraph (i) of this clause, that work performed under this contract conforms to the contract requirements and is free of any defect in equipment, material, or design furnished, or workmanship performed by the Contractor or any subcontractor or supplier at any tier.

(b) This warranty shall continue for a period of 1 year from the date of final acceptance of the work. If the Government takes possession of any part of the work before final acceptance, this warranty shall continue for a period of 1 year from the date the Government takes possession.

(c) The Contractor shall remedy at the Contractor's expense any failure to conform, or any defect. In addition, the Contractor shall remedy at the Contractor's expense any damage to Government-owned or controlled real or personal property, when that damage is the result of--

(1) The Contractor's failure to conform to contract requirements; or

(2) Any defect of equipment, material, workmanship, or design furnished.

(d) The Contractor shall restore any work damaged in fulfilling the terms and conditions of this clause. The Contractor's warranty with respect to work repaired or replaced will run for 1 year from the date of repair or replacement.

(e) The Contracting Officer shall notify the Contractor, in writing, within a reasonable time after the discovery of any failure, defect, or damage.

(f) If the Contractor fails to remedy any failure, defect, or damage within a reasonable time after receipt of notice, the Government shall have the right to replace, repair, or otherwise remedy the failure, defect, or damage at the Contractor's expense.

(g) With respect to all warranties, express or implied, from subcontractors, manufacturers, or suppliers for work performed and materials furnished under this contract, the Contractor shall--

(1) Obtain all warranties that would be given in normal commercial practice;

(2) Require all warranties to be executed, in writing, for the benefit of the Government, if directed by the Contracting Officer; and

(3) Enforce all warranties for the benefit of the Government, if directed by the Contracting Officer.

(h) In the event the Contractor's warranty under paragraph (b) of this clause has expired, the Government may bring suit at its expense to enforce a subcontractor's, manufacturer's, or supplier's warranty.

(i) Unless a defect is caused by the negligence of the Contractor or subcontractor or supplier at any tier, the Contractor shall not be liable for the repair of any defects of material or design furnished by the Government nor for the repair of any damage that results from any defect in Government-furnished material or design.

(j) This warranty shall not limit the Government's rights under the Inspection and Acceptance clause of this contract with respect to latent defects, gross mistakes, or fraud.

52.248-3 VALUE ENGINEERING--CONSTRUCTION (FEB 2000)

(a) General. The Contractor is encouraged to develop, prepare, and submit value engineering change proposals (VECP's) voluntarily. The Contractor shall share in any instant contract savings realized from accepted VECP's, in accordance with paragraph (f) below.

(b) Definitions. "Collateral costs," as used in this clause, means agency costs of operation, maintenance, logistic support, or Government-furnished property.

"Collateral savings," as used in this clause, means those measurable net reductions resulting from a VECP in the agency's overall projected collateral costs, exclusive of acquisition savings, whether or not the acquisition cost changes.

"Contractor's development and implementation costs," as used in this clause, means those costs the Contractor incurs on a VECP specifically in developing, testing, preparing, and submitting the VECP, as well as those costs the Contractor incurs to make the contractual changes required by Government acceptance of a VECP.

"Government costs," as used in this clause, means those agency costs that result directly from developing and implementing the VECP, such as any net increases in the cost of testing, operations, maintenance, and logistic support. The term does not include the normal administrative costs of processing the VECP.

"Instant contract savings," as used in this clause, means the estimated reduction in Contractor cost of performance resulting from acceptance of the VECP, minus allowable Contractor's development and implementation costs, including subcontractors' development and implementation costs (see paragraph (h) below).

"Value engineering change proposal (VECP)" means a proposal that--

- (1) Requires a change to this, the instant contract, to implement; and
- (2) Results in reducing the contract price or estimated cost without impairing essential functions or characteristics; provided, that it does not involve a change--
 - (i) In deliverable end item quantities only; or
 - (ii) To the contract type only.

(c) VECP preparation. As a minimum, the Contractor shall include in each VECP the information described in subparagraphs (1) through (7) below. If the proposed change is affected by contractually required configuration management or similar procedures, the instructions in those procedures relating to format, identification, and priority assignment shall govern VECP preparation. The VECP shall include the following:

- (1) A description of the difference between the existing contract requirement and that proposed, the comparative advantages and disadvantages of each, a justification when an item's function or characteristics are being altered, and the effect of the change on the end item's performance.
- (2) A list and analysis of the contract requirements that must be changed if the VECP is accepted, including any suggested specification revisions.

(3) A separate, detailed cost estimate for

(i) the affected portions of the existing contract requirement and

(ii) the VECP. The cost reduction associated with the VECP shall take into account the Contractor's allowable development and implementation costs, including any amount attributable to subcontracts under paragraph (h) below.

(4) A description and estimate of costs the Government may incur in implementing the VECP, such as test and evaluation and operating and support costs.

(5) A prediction of any effects the proposed change would have on collateral costs to the agency.

(6) A statement of the time by which a contract modification accepting the VECP must be issued in order to achieve the maximum cost reduction, noting any effect on the contract completion time or delivery schedule.

(7) Identification of any previous submissions of the VECP, including the dates submitted, the agencies and contract numbers involved, and previous Government actions, if known.

(d) Submission. The Contractor shall submit VECP's to the Resident Engineer at the worksite, with a copy to the Contracting Officer.

(e) Government action.

(1) The Contracting Officer will notify the Contractor of the status of the VECP within 45 calendar days after the contracting office receives it. If additional time is required, the Contracting Officer will notify the Contractor within the 45-day period and provide the reason for the delay and the expected date of the decision. The Government will process VECP's expeditiously; however, it shall not be liable for any delay in acting upon a VECP.

If the VECP is not accepted, the Contracting Officer will notify the Contractor in writing, explaining the reasons for rejection. The Contractor may withdraw any VECP, in whole or in part, at any time before it is accepted by the Government. The Contracting Officer may require that the Contractor provide written notification before undertaking significant expenditures for VECP effort.

Any VECP may be accepted, in whole or in part, by the Contracting Officer's award of a modification to this contract citing this clause. The Contracting Officer may accept the VECP, even though an agreement on price reduction has not been reached, by issuing the Contractor a notice to proceed with the change. Until a notice to proceed is issued or a contract modification applies a VECP to this contract, the Contractor shall perform in accordance with the existing contract. The decision to accept or reject all or part of any VECP is a unilateral decision made solely at the discretion of the Contracting Officer.

(f) Sharing.

(1) Rates. The Government's share of savings is determined by subtracting Government costs from instant contract savings and multiplying the result by

(i) 45 percent for fixed-price contracts or

(ii) 75 percent for cost-reimbursement contracts.

(2) Payment. Payment of any share due the Contractor for use of a VECP on this contract shall be authorized by a modification to this contract to--

(i) Accept the VECP;

(ii) Reduce the contract price or estimated cost by the amount of instant contract savings; and

(iii) Provide the Contractor's share of savings by adding the amount calculated to the contract price or fee.

(g) Collateral savings. If a VECP is accepted, the Contracting Officer will increase the instant contract amount by 20 percent of any projected collateral savings determined to be realized in a typical year of use after subtracting any Government costs not previously offset. However, the Contractor's share of collateral savings will not exceed the contract's firm-fixed-price or estimated cost, at the time the VECP is accepted, or \$100,000, whichever is greater. The Contracting Officer is the sole determiner of the amount of collateral savings.

(h) Subcontracts. The Contractor shall include an appropriate value engineering clause in any subcontract of \$50,000 or more and may include one in subcontracts of lesser value. In computing any adjustment in this contract's price under paragraph (f) above, the Contractor's allowable development and implementation costs shall include any subcontractor's allowable development and implementation costs clearly resulting from a VECP accepted by the Government under this contract, but shall exclude any value engineering incentive payments to a subcontractor. The Contractor may choose any arrangement for subcontractor value engineering incentive payments; provided, that these payments shall not reduce the Government's share of the savings resulting from the VECP.

(i) Data. The Contractor may restrict the Government's right to use any part of a VECP or the supporting data by marking the following legend on the affected parts:

"These data, furnished under the Value Engineering-- Construction clause of contract , shall not be disclosed outside the Government or duplicated, used, or disclosed, in whole or in part, for any purpose other than to evaluate a value engineering change proposal submitted under the clause. This restriction does not limit the Government's right to use information contained in these data if it has been obtained or is otherwise available from the Contractor or from another source without limitations." If a VECP is accepted, the Contractor hereby grants the Government unlimited rights in the VECP and supporting data, except that, with respect to data qualifying and submitted as limited rights technical data, the Government shall have the rights specified in the

contract modification implementing the VECP and shall appropriately mark the data. (The terms "unlimited rights" and "limited rights" are defined in Part 27 of the Federal Acquisition Regulation.)

52.249-2 TERMINATION FOR CONVENIENCE OF THE GOVERNMENT (FIXED-PRICE)
(SEP 1996) - ALTERNATE I (SEP 1996)

(a) The Government may terminate performance of work under this contract in whole or, from time to time, in part if the Contracting Officer determines that a termination is in the Government's interest. The Contracting Officer shall terminate by delivering to the Contractor a Notice of Termination specifying the extent of termination and the effective date.

(b) After receipt of a Notice of Termination, and except as directed by the Contracting Officer, the Contractor shall immediately proceed with the following obligations, regardless of any delay in determining or adjusting any amounts due under this clause:

(1) Stop work as specified in the notice.

(2) Place no further subcontracts or orders (referred to as subcontracts in this clause) for materials, services, or facilities, except as necessary to complete the continued portion of the contract.

(3) Terminate all subcontracts to the extent they relate to the work terminated.

(4) Assign to the Government, as directed by the Contracting Officer, all right, title, and interest of the Contractor under the subcontracts terminated, in which case the Government shall have the right to settle or to pay any termination settlement proposal arising out of those terminations.

(5) With approval or ratification to the extent required by the Contracting Officer, settle all outstanding liabilities and termination settlement proposals arising from the termination of subcontracts; the approval or ratification will be final for purposes of this clause.

(6) As directed by the Contracting Officer, transfer title and deliver to the Government (i) the fabricated or unfabricated parts, work in process, completed work, supplies, and other material produced or acquired for the work terminated, and (ii) the completed or partially completed plans, drawings, information, and other property that, if the contract had been completed, would be required to be furnished to the Government.

(7) Complete performance of the work not terminated.

(8) Take any action that may be necessary, or that the Contracting Officer may direct, for the protection and preservation of the property related to this contract that is in the possession of the Contractor and in which the Government has or may acquire an interest.

(9) Use its best efforts to sell, as directed or authorized by the Contracting Officer, any property of the types referred to in subparagraph (b)(6) of this clause; provided, however, that the Contractor (i) is not required to extend credit to any purchaser and (ii) may acquire the property under the conditions prescribed by, and at prices approved by, the Contracting Officer. The proceeds of any transfer or disposition will be applied to reduce any payments to be made by the Government under this contract, credited to the price or cost of the work, or paid in any other manner directed by the Contracting Officer.

(c) The Contractor shall submit complete termination inventory schedules no later than 120 days from the effective date of termination, unless extended in writing by the Contracting Officer upon written request of the Contractor within this 120-day period.

(d) After expiration of the plant clearance period as defined in Subpart 45.6 of the Federal Acquisition Regulation, the Contractor may submit to the Contracting Officer a list, certified as to quantity and quality, of termination inventory not previously disposed of, excluding items authorized for disposition by the Contracting Officer. The Contractor may request the Government to remove those items or enter into an agreement for their storage. Within 15 days, the Government will accept title to those items and remove them or enter into a storage agreement. The Contracting Officer may verify the list upon removal of the items, or if stored, within 45 days from submission of the list, and shall correct the list, as necessary, before final settlement.

(e) After termination, the Contractor shall submit a final termination settlement proposal to the Contracting Officer in the form and with the certification prescribed by the Contracting Officer. The Contractor shall submit the proposal promptly, but no later than 1 year from the effective date of termination, unless extended in writing by the Contracting Officer upon written request of the Contractor within this 1-year period. However, if the Contracting Officer determines that the facts justify it, a termination settlement proposal may be received and acted on after 1 year or any extension. If the Contractor fails to submit the proposal within the time allowed, the Contracting Officer may determine, on the basis of information available, the amount, if any, due the Contractor because of the termination and shall pay the amount determined.

(f) Subject to paragraph (e) of this clause, the Contractor and the Contracting Officer may agree upon the whole or any part of the amount to be paid or remaining to be paid because of the termination. The amount may include a reasonable allowance for profit on work done. However, the agreed amount, whether under this paragraph (g) or paragraph (g) of this clause, exclusive of costs shown in subparagraph (g)(3) of this clause, may not exceed the total contract price as reduced by (1) the amount of payments previously made and (2) the contract price of work not terminated. The contract shall be modified, and the Contractor paid the agreed amount. Paragraph (g) of this clause shall not limit, restrict, or affect the amount that may be agreed upon to be paid under this paragraph.

(g) If the Contractor and Contracting Officer fail to agree on the whole amount to be paid the Contractor because of the termination of work, the Contracting Officer shall pay the Contractor the amounts determined as follows, but without duplication of any amounts agreed upon under paragraph (f) of this clause:

(1) For contract work performed before the effective date of termination, the total (without duplication of any items) of--

(i) The cost of this work;

(ii) The cost of settling and paying termination settlement proposals under terminated subcontracts that are properly chargeable to the terminated portion of the contract if not included in subdivision (g)(1)(i) of this clause; and

(iii) A sum, as profit on subdivision (g)(1)(i) of this clause, determined by the Contracting Officer under 49.202 of the Federal Acquisition Regulation, in effect on the date of this contract, to be fair and reasonable; however, if it appears that the Contractor would have sustained a loss on the entire contract had it been completed, the Contracting Officer shall allow no profit under this subdivision (iii) and shall reduce the settlement to reflect the indicated rate of loss.

(2) The reasonable costs of settlement of the work terminated, including--

(i) Accounting, legal, clerical, and other expenses reasonably necessary for the preparation of termination settlement proposals and supporting data;

(ii) The termination and settlement of subcontracts (excluding the amounts of such settlements); and

(iii) Storage, transportation, and other costs incurred, reasonably necessary for the preservation, protection, or disposition of the termination inventory.

(h) Except for normal spoilage, and except to the extent that the Government expressly assumed the risk of loss, the Contracting Officer shall exclude from the amounts payable to the Contractor under paragraph (g) of this clause, the fair value, as determined by the Contracting Officer, of property that is destroyed, lost, stolen, or damaged so as to become undeliverable to the Government or to a buyer.

(i) The cost principles and procedures of Part 31 of the Federal Acquisition Regulation, in effect on the date of this contract, shall govern all costs claimed, agreed to, or determined under this clause.

(j) The Contractor shall have the right of appeal, under the Disputes clause, from any determination made by the Contracting Officer under paragraph (e), (g), or (l) of this clause, except that if the Contractor failed to submit the termination settlement proposal or request for equitable adjustment within the time provided in paragraph (e) or (l), respectively, and failed to request a time extension, there is no right of appeal.

(k) In arriving at the amount due the Contractor under this clause, there shall be deducted--

(1) All unliquidated advance or other payments to the Contractor under the terminated portion of this contract;

(2) Any claim which the Government has against the Contractor under this contract; and

(3) The agreed price for, or the proceeds of sale of, materials, supplies, or other things acquired by the Contractor or sold under the provisions of this clause and not recovered by or credited to the Government.

(l) If the termination is partial, the Contractor may file a proposal with the Contracting Officer for an equitable adjustment of the price(s) of the continued portion of the contract. The Contracting Officer shall make any equitable adjustment agreed upon. Any proposal by the Contractor for an equitable adjustment under this clause shall be requested within 90 days from the effective date of termination unless extended in writing by the Contracting Officer.

(m)(1) The Government may, under the terms and conditions it prescribes, make partial payments and payments against costs incurred by the Contractor for the terminated portion of the contract, if the Contracting Officer believes the total of these payments will not exceed the amount to which the Contractor will be entitled.

(2) If the total payments exceed the amount finally determined to be due, the Contractor shall repay the excess to the Government upon demand, together with interest computed at the rate established by the Secretary of the Treasury under 50 U.S.C. App. 1215(b)(2). Interest shall be computed for the period from the date the excess payment is received by the Contractor to the date the excess is repaid. Interest shall not be charged on any excess payment due to a reduction in the Contractor's termination settlement proposal because of retention or other disposition of termination inventory until 10 days after the date of the retention or disposition, or a later date determined by the Contracting Officer because of the circumstances.

(n) Unless otherwise provided in this contract or by statute, the Contractor shall maintain all records and documents relating to the terminated portion of this contract for 3 years after final settlement. This includes all books and other evidence bearing on the Contractor's costs and expenses under this contract. The Contractor shall make these records and documents available to the Government, at the Contractor's office, at all reasonable times, without any direct charge. If approved by the Contracting Officer, photographs, microphotographs, or other authentic reproductions may be maintained instead of original records and documents.

52.249-10 DEFAULT (FIXED-PRICE CONSTRUCTION) (APR 1984)

(a) If the Contractor refuses or fails to prosecute the work or any separable part, with the diligence that will insure its completion within the time specified in this contract including any extension, or fails to complete the work within this time, the Government may, by written notice to the Contractor, terminate the right to proceed with the work (or the separable part of the work) that has been delayed. In this event, the Government may take over the work and complete it by contract or otherwise, and may take possession of and use any materials, appliances, and plant on the work site necessary for completing the work. The Contractor and its sureties shall be liable for any damage to the Government resulting from the Contractor's refusal or failure to complete the work within the specified time, whether or not the Contractor's right to proceed with the work is terminated. This liability includes any increased costs incurred by the Government in completing the work.

(b) The Contractor's right to proceed shall not be terminated nor the Contractor charged with damages under this clause, if--

(1) The delay in completing the work arises from unforeseeable causes beyond the control and

without the fault or negligence of the Contractor. Examples of such causes include

- (i) acts of God or of the public enemy,
- (ii) acts of the Government in either its sovereign or contractual capacity,
- (iii) acts of another Contractor in the performance of a contract with the Government,
- (iv) fires,
- (v) floods,
- (vi) epidemics,
- (vii) quarantine restrictions,
- (viii) strikes,
- (ix) freight embargoes,
- (x) unusually severe weather, or delays of subcontractors or suppliers at any tier arising from unforeseeable causes beyond the control and without the fault or negligence of both the Contractor and the subcontractors or suppliers; and

(2) The Contractor, within 10 days from the beginning of any delay (unless extended by the Contracting Officer), notifies the Contracting Officer in writing of the causes of delay. The Contracting Officer shall ascertain the facts and the extent of delay. If, in the judgment of the Contracting Officer, the findings of fact warrant such action, the time for completing the work shall be extended. The findings of the Contracting Officer shall be final and conclusive on the parties, but subject to appeal under the Disputes clause.

(c) If, after termination of the Contractor's right to proceed, it is determined that the Contractor was not in default, or that the delay was excusable, the rights and obligations of the parties will be the same as if the termination had been issued for the convenience of the Government.

The rights and remedies of the Government in this clause are in addition to any other rights and remedies provided by law or under this contract.

52.253-1 COMPUTER GENERATED FORMS (JAN 1991)

(a) Any data required to be submitted on a Standard or Optional Form prescribed by the Federal Acquisition Regulation (FAR) may be submitted on a computer generated version of the form, provided there is no change to the name, content, or sequence of the data elements on the form, and provided the form carries the Standard or Optional Form number and edition date.

(b) Unless prohibited by agency regulations, any data required to be submitted on an agency unique form prescribed by an agency supplement to the FAR may be submitted on a computer generated version of the form provided there is no change to the name, content, or sequence of the data elements on the form and provided the form carries the agency form number and edition date.

(c) If the Contractor submits a computer generated version of a form that is different than the required form, then the rights and obligations of the parties will be determined based on the content of the required form.

252.203-7001 PROHIBITION ON PERSONS CONVICTED OF FRAUD OR OTHER DEFENSE-CONTRACT-RELATED FELONIES (MAR 1999)

(a) Definitions. As used in this clause—

(1) “Arising out of a contract with the DoD” means any act in connection with—

(i) Attempting to obtain;

(ii) Obtaining, or

(iii) Performing a contract or first-tier subcontract of any agency, department, or component of the Department of Defense (DoD).

(2) “Conviction of fraud or any other felony” means any conviction for fraud or a felony in violation of state or Federal criminal statutes, whether entered on a verdict or plea, including a plea of *nolo contendere*, for which sentence has been imposed.

(3) “Date of conviction” means the date judgment was entered against the individual.

(b) Any individual who is convicted after September 29, 1988, of fraud or any other felony arising out of a contract with the DoD is prohibited from serving--

(1) In a management or supervisory capacity on any DoD contract or first-tier subcontract;

(2) On the board of directors of any DoD contractor or first-tier subcontractor;

(3) As a consultant, agent, or representative for any DoD contractor or first-tier subcontractor; or

(4) In any other capacity with the authority to influence, advise, or control the decisions of any DoD contractor or subcontractor with regard to any DoD contract or first-tier subcontract.

(c) Unless waived, the prohibition in paragraph (b) of this clause applies for not less than 5 years from the date of conviction.

(d) 10 U.S.C. 2408 provides that a defense contractor or first-tier subcontractor shall be subject to a criminal penalty of not more than \$500,000 if convicted of knowingly—

(1) Employing a person under a prohibition specified in paragraph (b) of this clause; or

(2) Allowing such a person to serve on the board of directors of the contractor or first-tier subcontractor.

(e) In addition to the criminal penalties contained in 10 U.S.C. 2408, the Government may consider other available remedies, such as—

- (1) Suspension or debarment;
- (2) Cancellation of the contract at no cost to the Government; or
- (3) Termination of the contract for default.

(f) The Contractor may submit written requests for waiver of the prohibition in paragraph (b) of this clause to the Contracting Officer. Requests shall clearly identify—

- (1) The person involved;
- (2) The nature of the conviction and resultant sentence or punishment imposed;
- (3) The reasons for the requested waiver; and
- (4) An explanation of why a waiver is in the interest of national security.

(g) The Contractor agrees to include the substance of this clause, appropriately modified to reflect the identity and relationship of the parties, in all first-tier subcontracts exceeding the simplified acquisition threshold in Part 2 of the Federal Acquisition Regulation, except those for commercial items or components.

(h) Pursuant to 10 U.S.C. 2408(c), defense contractors and subcontractors may obtain information as to whether a particular person has been convicted of fraud or any other felony arising out of a contract with the DoD by contacting The Office of Justice Programs, The Denial of Federal Benefits Office, U.S. Department of Justice, telephone (202) 616-3507.

252.204-7003 CONTROL OF GOVERNMENT PERSONNEL WORK PRODUCT (APR 1992)

The Contractor's procedures for protecting against unauthorized disclosure of information shall not require Department of Defense employees or members of the Armed Forces to relinquish control of their work products, whether classified or not, to the contractor.

252.204-7004 REQUIRED CENTRAL CONTRACTOR REGISTRATION.(NOV 2001)

(a) Definitions.

As used in this clause--

(1) Central Contractor Registration (CCR) database means the primary DoD repository for contractor information required for the conduct of business with DoD.

(2) Data Universal Numbering System (DUNS) number means the 9-digit number assigned by Dun and Bradstreet Information Services to identify unique business entities.

(3) Data Universal Numbering System +4 (DUNS+4) number means the DUNS number assigned by Dun and Bradstreet plus a 4-digit suffix that may be assigned by a parent (controlling) business concern. This 4-digit suffix may be assigned at the discretion of the parent business concern for such purposes as identifying subunits or affiliates of the parent business concern.

(4) Registered in the CCR database means that all mandatory information, including the DUNS number or the DUNS+4 number, if applicable, and the corresponding Commercial and Government Entity (CAGE) code, is in the CCR database; the DUNS number and the CAGE code have been validated; and all edits have been successfully completed.

(b)(1) By submission of an offer, the offeror acknowledges the requirement that a prospective awardee must be registered in the CCR database prior to award, during performance, and through final payment of any contract resulting from this solicitation, except for awards to foreign vendors for work to be performed outside the United States.

(2) The offeror shall provide its DUNS or, if applicable, its DUNS+4 number with its offer, which will be used by the Contracting Officer to verify that the offeror is registered in the CCR database.

(3) Lack of registration in the CCR database will make an offeror ineligible for award.

(4) DoD has established a goal of registering an applicant in the CCR database within 48 hours after receipt of a complete and accurate application via the Internet. However, registration of an applicant submitting an application through a method other than the Internet may take up to 30 days. Therefore, offerors that are not registered should consider applying for registration immediately upon receipt of this solicitation.

(c) The Contractor is responsible for the accuracy and completeness of the data within the CCR, and for any liability resulting from the Government's reliance on inaccurate or incomplete data. To remain registered in the CCR database after the initial registration, the Contractor is required to confirm on an annual basis that its information in the CCR database is accurate and complete.

(d) Offerors and contractors may obtain information on registration and annual confirmation requirements by calling 1-888-227-2423, or via the Internet at <http://www.ccr.gov>.

252.209-7004 SUBCONTRACTING WITH FIRMS THAT ARE OWNED OR CONTROLLED BY THE GOVERNMENT OF A TERRORIST COUNTRY (MAR 1998)

(a) Unless the Government determines that there is a compelling reason to do so, the Contractor shall not enter into any subcontract in excess of \$25,000 with a firm, or subsidiary of a firm, that is identified, on the List of Parties Excluded from Federal Procurement and Nonprocurement Programs, as being ineligible for the award of Defense contracts or subcontracts because it is owned or controlled by the government of a terrorist country.

(b) A corporate officer or a designee of the Contractor shall notify the Contracting Officer, in writing, before entering into a subcontract with a party that is identified, on the List of Parties Excluded from Federal Procurement and Nonprocurement Programs, as being ineligible for the award of Defense contracts or subcontracts because it is owned or controlled by the government of a terrorist country. The notice must include the name of the proposed subcontractor notwithstanding its inclusion on the List of Parties Excluded From Federal Procurement and Nonprocurement Programs.

252.225-7012 PREFERENCE FOR CERTAIN DOMESTIC COMMODITIES (APR 2002)

(a) Definitions. As used in this clause--

(1) Component means any item supplied to the Government as part of an end product or of another component.

(2) End product means supplies delivered under a line item of this contract.

(b) The Contractor shall deliver under this contract only such of the following items, either as end products or components, that have been grown, reprocessed, reused, or produced in the United States, its possessions, or Puerto Rico:

(1) Food.

(2) Clothing.

(3) Tents, tarpaulins, or covers.

(4) Cotton and other natural fiber products.

(5) Woven silk or woven silk blends.

(6) Spun silk yarn for cartridge cloth.

(7) Synthetic fabric, and coated synthetic fabric, including all textile fibers and yarns that are for use in such fabrics.

(8) Canvas products.

(9) Wool (whether in the form of fiber or yarn or contained in fabrics, materials, or manufactured articles).

(10) Any item of individual equipment (Federal Supply Class 8465) manufactured from or containing fibers, yarns, fabrics, or materials listed in this paragraph (b).

(c) This clause does not apply--

(1) To items listed in section 25.104(a) of the Federal Acquisition Regulation (FAR), or other items for which the Government has determined that a satisfactory quality and sufficient quantity cannot be acquired as and when needed at U.S. market prices;

(2) To end products incidentally incorporating cotton, other natural fibers, or wool, for which the estimated value of the cotton, other natural fibers, or wool--

(i) Is not more than 10 percent of the total price of the end product; and (ii) Does not exceed the simplified acquisition threshold in FAR part 2;

(3) To foods that have been manufactured or processed in the United States, its possessions, or Puerto Rico, regardless of where the foods (and any component if applicable) were grown or produced;

(4) To chemical warfare protective clothing produced in the countries listed in subsection 225.872-1 of the Defense FAR Supplement; or

(5) To fibers and yarns that are for use in synthetic fabric or coated synthetic fabric (but does apply to the synthetic or coated synthetic fabric itself), if--

(i) The fabric is to be used as a component of an end product that is not a textile product. Examples of textile products, made in whole or in part of fabric, include--

(A) Draperies, floor coverings, furnishings, and bedding (Federal Supply Group 72, Household and Commercial Furnishings and Appliances);

(B) Items made in whole or in part of fabric in Federal Supply Group 83, Textile/leather/furs/apparel/findings/ tents/flags, or Federal Supply Group 84, Clothing, Individual Equipment and Insignia;

(C) Upholstered seats (whether for household, office, or other use); and

(D) Parachutes (Federal Supply Class 1670); or

(ii) The fibers and yarns are para-aramid fibers and yarns manufactured in the Netherlands.

252.225-7031 SECONDARY ARAB BOYCOTT OF ISRAEL (JUN 1992)

(a) Definitions. As used in this clause--

(1) "Foreign person" means any person other than a United States person as defined in Section 16(2) of the Export Administration Act of 1979 (50 U.S.C. App. Sec 2415).

(2) "United States person" is defined in Section 16(2) of the Export Administration Act of 1979 and means any United States resident or national (other than an individual resident outside the United States and employed by other than a United States person), any domestic concern (including any permanent domestic establishment of any foreign concern), and any foreign subsidiary or affiliate (including any permanent foreign establishment) of any domestic concern which is controlled in fact by such domestic concerns, as determined under regulations of the President.

(b) Certification. By submitting this offer, the Offeror, if a foreign person, company or entity, certifies that it--

(1) Does not comply with the Secondary Arab Boycott of Israel; and

(2) Is not taking or knowingly agreeing to take any action, with respect to the Secondary Boycott of Israel by Arab countries, which 50 U.S.C. App. Sec 2407(a) prohibits a United States person from taking.

252.226-7001 Utilization of Indian Organizations and Indian-Owned Economic Enterprises-DoD Contracts (Sep 2001)

(a) Definitions. As used in this clause--

“Indian” means any person who is a member of any Indian tribe, band, group, pueblo, or community that is recognized by the Federal Government as eligible for services from the Bureau of Indian Affairs (BIA) in accordance with 25 U.S.C. 1452(c) and any “Native” as defined in the Alaska Native Claims Settlement Act (43 U.S.C. 1601).

“Indian organization” means the governing body of any Indian tribe or entity established or recognized by the governing body of an Indian tribe for the purposes of 25 U.S.C. Chapter 17.

“Indian-owned economic enterprise” means any Indian-owned (as determined by the Secretary of the Interior) commercial, industrial, or business activity established or organized for the purpose of profit, provided that Indian ownership constitutes not less than 51 percent of the enterprise.

“Indian tribe” means any Indian tribe, band, group, pueblo, or community, including native villages and native groups (including corporations organized by Kenai, Juneau, Sitka, and Kodiak) as defined in the Alaska Native Claims Settlement Act, that is recognized by the Federal Government as eligible for services from BIA in accordance with 25 U.S.C. 1452 (c).

“Interested party” means a contractor or an actual or prospective offeror whose direct economic interest would be affected by the award of a subcontract or by the failure to award a subcontract.

(b) The Contract shall use its best efforts to give Indian organizations and Indian-owned economic enterprises the maximum practicable opportunity to participate in the subcontracts it awards, to the fullest extent consistent with efficient performance of the contract.

(c) The Contracting Officer and the Contractor, acting in good faith, may rely on the representation of an Indian organization or Indian-owned economic enterprise as to its eligibility, unless and interested party challenges its status or the Contracting Officer has independent reason to question that status.

(d) In the event of a challenge to the representation of a subcontractor, the Contracting Officer will refer the matter to the U.S. Department of the Interior, Bureau of Indian Affairs, Attn: Chief, Division of Contracting and Grants Administration, 1849 C Street NW, MS-2626-MIB, Washington, DC 20240-4000. The BIA will determine the eligibility and will notify the Contracting Officer. No incentive payment will be made--

- (1) Within 59 working days of subcontract award;
- (2) While a challenge is pending; or
- (3) If a subcontractor is determined to be an ineligible participant.

(e)(1) The Contractor, on its own behalf or on behalf of a subcontractor at any tier, may request an adjustment under the Indian Incentive Program to the following:

- (i) The estimated cost of cost-type contract.
- (ii) The target cost of a cost-plus-incentive-fee contract.
- (iii) The target cost and ceiling price of a fixed-price incentive contract.
- (iv) The price of a firm-fixed-price contract.

(2) The amount of the adjustment that may be made to the contract is 5 percent of the estimated cost, target cost, or firm-fixed price included in the subcontract initially awarded to the Indian organization or Indian-owned economic enterprise.

(3) The Contractor has the burden of proving the amount claimed and must assert its request for an adjustment prior to completion of contract performance.

(4) The Contracting Officer, subject to the terms and conditions of the contract and the availability of funds, will authorize an incentive payment of 5 percent of the amount paid to the subcontractor.

(5) If the Contractor requests and receives an adjustment on behalf of a subcontractor, the Contractor is obligated to pay the subcontractor the adjustment.

(f) The Contractor shall insert the substance of this clause, including this paragraph (f), in all subcontracts that--

- (1) Are for other than commercial items; and

(2) Are expected to exceed the simplified acquisition threshold in Part 2 of the Federal Acquisition Regulation.

252.227-7033 RIGHTS IN SHOP DRAWINGS (APR 1966)

(a) Shop drawings for construction means drawings, submitted to the Government by the Construction Contractor, subcontractor or any lower-tier subcontractor pursuant to a construction contract, showing in detail (i) the proposed fabrication and assembly of structural elements and (ii) the installation (i.e., form, fit, and attachment details) of materials or equipment. The Government may duplicate, use, and disclose in any manner and for any purpose shop drawings delivered under this contract.

(b) This clause, including this paragraph (b), shall be included in all subcontracts hereunder at any tier.

252.236-7000 MODIFICATION PROPOSALS - PRICE BREAKDOWN. (DEC 1991)

(a) The Contractor shall furnish a price breakdown, itemized as required and within the time specified by the Contracting Officer, with any proposal for a contract modification.

(b) The price breakdown --

(1) Must include sufficient detail to permit an analysis of profit, and of all costs for --

(i) Material;

(ii) Labor;

(iii) Equipment;

(iv) Subcontracts; and

(v) Overhead; and

(2) Must cover all work involved in the modification, whether the work was deleted, added, or changed.

(c) The Contractor shall provide similar price breakdowns to support any amounts claimed for subcontracts.

(d) The Contractor's proposal shall include a justification for any time extension proposed.

252.236-7004 PAYMENT FOR MOBILIZATION AND DEMOBILIZATION. (DEC 1991)

(a) The Government will pay all costs for the mobilization and demobilization of all of the Contractor's plant and equipment at the contract lump sum price for this item.

(1) 60 percent of the lump sum price upon completion of the contractor's mobilization at the work site.

(2) The remaining 40 percent upon completion of demobilization.

(b) The Contracting Officer may require the Contractor to furnish cost data to justify this portion of the bid if the Contracting Officer believes that the percentages in paragraphs (a) (1) and (2) of this clause do not bear a reasonable relation to the cost of the work in this contract.

(1) Failure to justify such price to the satisfaction of the Contracting Officer will result in payment, as determined by the Contracting Officer, of --

(i) Actual mobilization costs at completion of mobilization;

(ii) Actual demobilization costs at completion of demobilization; and

(iii) The remainder of this item in the final payment under this contract.

(2) The Contracting Officer's determination of the actual costs in paragraph (b)(1) of this clause is not subject to appeal.

252.243-7001 PRICING OF CONTRACT MODIFICATIONS (DEC 1991)

When costs are a factor in any price adjustment under this contract, the contract cost principles and procedures in FAR part 31 and DFARS part 231, in effect on the date of this contract, apply.

252.243-7002 REQUESTS FOR EQUITABLE ADJUSTMENT (MAR 1998)

(a) The amount of any request for equitable adjustment to contract terms shall accurately reflect the contract adjustment for which the Contractor believes the Government is liable. The request shall include only costs for performing the change, and shall not include any costs that already have been reimbursed or that have been separately claimed. All indirect costs included in the request shall be properly allocable to the change in accordance with applicable acquisition regulations.

(b) In accordance with 10 U.S.C. 2410(a), any request for equitable adjustment to contract terms that exceeds the simplified acquisition threshold shall bear, at the time of submission, the following certificate executed by an individual authorized to certify the request on behalf of the Contractor:

I certify that the request is made in good faith, and that the supporting data are accurate and complete to the best of my knowledge and belief.

(Official's Name)

(Title)

(c) The certification in paragraph (b) of this clause requires full disclosure of all relevant facts, including--

(1) Cost or pricing data if required in accordance with subsection 15.403-4 of the Federal Acquisition Regulation (FAR); and

(2) Information other than cost or pricing data, in accordance with subsection 15.403-3 of the FAR, including actual cost data and data to support any estimated costs, even if cost or pricing data are not required.

(d) The certification requirement in paragraph (b) of this clause does not apply to----

(1) Requests for routine contract payments; for example, requests for payment for accepted supplies and services, routine vouchers under a cost-reimbursement type contract, or progress payment invoices; or

(2) Final adjustment under an incentive provision of the contract.

252.244-7000 SUBCONTRACTS FOR COMMERCIAL ITEMS AND COMMERCIAL COMPONENTS (DOD) (MAR 2000)

In addition to the clauses listed in paragraph (c) of the Subcontracts for Commercial Items and Commercial Components clause of this contract (Federal Acquisition Regulation 52.244-6), the Contractor shall include the terms of the following clauses, if applicable, in subcontracts for commercial items or commercial components, awarded at any tier under this contract:

252.225-7014 Preference for Domestic Specialty Metals, Alternate I (10 U.S.C. 2241 note).

252.247-7023 Transportation of Supplies by Sea (10 U.S.C. 2631).

252.247-7024 Notification of Transportation of Supplies by Sea (10 U.S.C. 2631).

252.247-7023 TRANSPORTATION OF SUPPLIES BY SEA (MAR 2000)

(a) Definitions. As used in this clause --

(1) "Components" means articles, materials, and supplies incorporated directly into end products at any level of manufacture, fabrication, or assembly by the Contractor or any subcontractor.

(2) "Department of Defense" (DoD) means the Army, Navy, Air Force, Marine Corps, and defense agencies.

(3) "Foreign flag vessel" means any vessel that is not a U.S.-flag vessel.

(4) "Ocean transportation" means any transportation aboard a ship, vessel, boat, barge, or ferry through international waters.

(5) "Subcontractor" means a supplier, materialman, distributor, or vendor at any level below the prime contractor whose contractual obligation to perform results from, or is conditioned upon, award of the prime contract and who is performing any part of the work or other requirement of the prime contract.

(6) "Supplies" means all property, except land and interests in land, that is clearly identifiable for eventual use by or owned by the DoD at the time of transportation by sea.

(i) An item is clearly identifiable for eventual use by the DoD if, for example, the contract documentation contains a reference to a DoD contract number or a military destination.

(ii) "Supplies" includes (but is not limited to) public works; buildings and facilities; ships; floating equipment and vessels of every character, type, and description, with parts, subassemblies, accessories, and equipment; machine tools; material; equipment; stores of all kinds; end items; construction materials; and components of the foregoing.

(7) "U.S.-flag vessel" means a vessel of the United States or belonging to the United States, including any vessel registered or having national status under the laws of the United States.

(b)(1) The Contractor shall use U.S.-flag vessels when transporting any supplies by sea under this contract.

(2) A subcontractor transporting supplies by sea under this contract shall use U.S.-flag vessels if—

(i) This contract is a construction contract; or

(ii) The supplies being transported are--

(A) Noncommercial items; or

(B) Commercial items that--

(1) The Contractor is reselling or distributing to the Government without adding value (generally, the Contractor does not add value to items that it contracts for f.o.b. destination shipment);

(2) Are shipped in direct support of U.S. military contingency operations, exercises, or forces deployed in humanitarian or peacekeeping operations; or

(3) Are commissary or exchange cargoes transported outside of the Defense Transportation System in accordance with 10 U.S.C. 2643.

(c) The Contractor and its subcontractors may request that the Contracting Officer authorize shipment in foreign-flag vessels, or designate available U.S.-flag vessels, if the Contractor or a subcontractor believes that --

(1) U.S.-flag vessels are not available for timely shipment;

(2) The freight charges are inordinately excessive or unreasonable; or

(3) Freight charges are higher than charges to private persons for transportation of like goods.

(d) The Contractor must submit any request for use of other than U.S.-flag vessels in writing to the Contracting Officer at least 45 days prior to the sailing date necessary to meet its delivery schedules. The Contracting Officer will process requests submitted after such date(s) as expeditiously as possible, but the Contracting Officer's failure to grant approvals to meet the shipper's sailing date will not of itself constitute a compensable delay under this or any other clause of this contract. Requests shall contain at a minimum --

(1) Type, weight, and cube of cargo;

(2) Required shipping date;

(3) Special handling and discharge requirements;

(4) Loading and discharge points;

(5) Name of shipper and consignee;

(6) Prime contract number; and

(7) A documented description of efforts made to secure U.S.-flag vessels, including points of contact (with names and telephone numbers) with at least two U.S.-flag carriers contacted. Copies of telephone notes, telegraphic and facsimile message or letters will be sufficient for this purpose.

(e) The Contractor shall, within 30 days after each shipment covered by this clause, provide the Contracting Officer and the Division of National Cargo, Office of Market Development, Maritime Administration, U.S. Department of Transportation, Washington, DC 20590, one copy of the rated on board vessel operating carrier's ocean bill of lading, which shall contain the following information --

(1) Prime contract number;

- (2) Name of vessel;
- (3) Vessel flag of registry;
- (4) Date of loading;
- (5) Port of loading;
- (6) Port of final discharge;
- (7) Description of commodity;
- (8) Gross weight in pounds and cubic feet if available;
- (9) Total ocean freight in U.S. dollars; and
- (10) Name of the steamship company.

(f) The Contractor agrees to provide with its final invoice under this contract a representation that to the best of its knowledge and belief --

- (1) No ocean transportation was used in the performance of this contract;
- (2) Ocean transportation was used and only U.S.-flag vessels were used for all ocean shipments under the contract;
- (3) Ocean transportation was used, and the Contractor had the written consent of the Contracting Officer for all non-U.S.-flag ocean transportation; or
- (4) Ocean transportation was used and some or all of the shipments were made on non-U.S.-flag vessels without the written consent of the Contracting Officer. The Contractor shall describe these shipments in the following format:

ITEM DESCRIPTION	CONTRACT LINE ITEMS	QUANTITY
_____	_____	_____
_____	_____	_____
_____	_____	_____
TOTAL	_____	_____

(g) If the final invoice does not include the required representation, the Government will reject and return it to the Contractor as an improper invoice for the purposes of the Prompt Payment clause of this contract. In the event there has been unauthorized use of non-U.S.-flag vessels in the performance of this contract, the Contracting Officer is entitled to equitably adjust the contract,

based on the unauthorized use.

(h) The Contractor shall include this clause, including this paragraph (h), in all subcontractors under this contract that--

- (1) Exceed the simplified acquisition threshold in Part 2 of the Federal Acquisition Regulation; and
- (2) Are for a type of supplies described in paragraph (b)(3) of this clause.

252.247-7024 NOTIFICATION OF TRANSPORTATION OF SUPPLIES BY SEA (MAR 2000)

(a) The Contractor has indicated by the response to the solicitation provision, Representation of Extent of Transportation by Sea, that it did not anticipate transporting by sea any supplies. If, however, after the award of this contract, the Contractor learns that supplies, as defined in the Transportation of Supplies by Sea clause of this contract, will be transported by sea, the Contractor --

- (1) Shall notify the Contracting Officer of that fact; and
- (2) Hereby agrees to comply with all the terms and conditions of the Transportation of Supplies by Sea clause of this contract.

(b) The Contractor shall include this clause; including this paragraph (b), revised as necessary to reflect the relationship of the contracting parties--

- (1) In all subcontracts under this contract, if this contract is a construction contract; or
- (2) If this contract is not a construction contract, in all subcontracts under this contract that are for--
 - (i) Noncommercial items; or
 - (ii) Commercial items that--

(A) The Contractor is reselling or distributing to the Government without adding value (generally, the Contractor does not add value to items that it subcontracts for f.o.b. destination shipment);

(B) Are shipped in direct support of U.S. military contingency operations, exercises, or forces deployed in humanitarian or peacekeeping operations; or

(C) Are commissary or exchange cargoes transported outside of the Defense Transportation System in accordance with 10 U.S.C. 2643.

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

TABLE OF CONTENTS
SPECIAL CONTRACT REQUIREMENTS

00800	SPECIAL CLAUSES
00805	CONTRACT ADMINISTRATION
00815	WAGE RATES
00835	REGIONS FOR THE CONSTRUCTION EQUIPMENT OWNERSHIP AND OPERATIONS EXPENSE SCHEDULE
00845	SURVEY CONTROL DESCRIPTION SHEETS

This page was intentionally left blank for duplex printing.

SECTION 00800
SPECIAL CLAUSES

INDEX

PARA	TITLE
SC-1	COMMENCEMENT, PROSECUTION AND COMPLETION OF WORK
SC-2	LIQUIDATED DAMAGES - CONSTRUCTION
SC-3	CONTRACT DRAWINGS, MAPS AND SPECIFICATIONS
SC-4	PHYSICAL DATA
SC-5	LAYOUT OF WORK
SC-6	DAMAGE TO WORK
SC-7	PERFORMANCE OF WORK BY THE CONTRACTOR
SC-8	ENVIRONMENTAL LITIGATION
SC-9	QUANTITY SURVEYS
SC-10	EQUIPMENT OWNERSHIP AND OPERATING EXPENSE SCHEDULE
SC-11	CERTIFICATES OF COMPLIANCE
SC-12	PERFORMANCE EVALUATION OF CONTRACTOR
SC-13	TIME EXTENSIONS FOR UNUSUALLY SEVERE WEATHER
SC-14	INSURANCE REQUIREMENTS

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SPECIAL CLAUSES

SC-1 COMMENCEMENT, PROSECUTION, AND COMPLETION OF WORK (APR 1984)

The Contractor shall be required to (a) commence work under this contract within XX calendar days after the Contractor receives the notice to proceed, (b) prosecute the work diligently, and (c) complete the entire work ready for use not later than 120 calendar days after the date the Contractor receives the notice to proceed. The time stated for completion shall include final cleanup of the premises. (FAR 52.211-10)

SC-2 LIQUIDATED DAMAGES - CONSTRUCTION (SEP 2000)

(a) If the Contractor fails to complete the work within the time specified in the contract, the Contractor shall pay liquidated damages to the Government in the amount of \$500.00 for each calendar day of delay until the work is completed or accepted.

(b) If the Government terminates the Contractor's right to proceed, liquidated damages will continue to accrue until the work is completed. These liquidated damages are in addition to excess costs of repurchase under the Termination clause. (FAR 52.211-12)

SC-3 CONTRACT DRAWINGS, MAPS AND SPECIFICATIONS

a. Upon obtaining the plans and specifications, the Contractor shall:

- (1) Immediately check the specifications and all drawings;
- (2) Compare the specifications and all drawings and verify the figures before laying out the work;
- (3) Promptly notify the Contracting Officer of any discrepancies; and
- (4) Be responsible for any errors which might have been avoided by complying with this paragraph (b).

b. Large scale drawings shall, in general, govern small scale drawings. Figures marked on drawings shall, in general, be followed in preference to scale measurements.

c. Omissions from the drawings or specifications or the misdescription of details of work which are manifestly necessary to carry out the intent of the drawings and specifications, or which are customarily performed, shall not relieve the contractor from performing such omitted or misdescribed details of the work, but shall be performed as if fully and correctly set forth and described in the drawings and specifications.

d. The work shall conform to the specifications and the contract drawings identified on the following, all of which are available in the office of the District Engineer, U.S. Army Engineer District, Philadelphia, Room 643, Wanamaker Building, 100 Penn Square East, Philadelphia, PA 19107. Drawings are titled: [Insert project title here] and have the following drawing numbers, subtitles, and dates. (DFARS 252.236-7001)

Drawing No.	Subtitle	Date	Latest Revision Date
58723	Vicinity Map, Location Map, List of	23 July 2002	None

Drawing No.	Subtitle	Date	Latest Revision Date
	Drawings, List of Abbreviations		
58724	Overall Site Plan	23 July 2002	None
58725	Site Plan - Existing Conditions Test Pit Locations	23 July 2002	None
58726	Site Plan - Proposed Conditions	23 July 2002	None
58727	Profiles and Details	23 July 2002	None
58728	Test Pit and Logs	23 July 2002	None

d. The work shall conform to the specifications and the contract drawings identified on the following, all of which are available in the office of the District Engineer, U.S. Army Engineer District, Philadelphia, Room 643, Wanamaker Building, 100 Penn Square East, Philadelphia, PA 19107. Drawings are titled: "[Insert project title here]" and have the drawing numbers, subtitles, and dates as indicated on Contract Drawing No. [XXXXX], General Plan and List of Drawings.

SC-4 PHYSICAL DATA (APR 1984)

Data and information furnished or referred to below is for the Contractor's information. The Government shall not be responsible for any interpretation of or conclusion drawn from the data or information by the Contractor. (FAR 52.236-4)

a. The indications of physical conditions on the drawings and in the specifications are the result of site investigations by conducted during the period 01 November 1999 to 03 April 2000.

b. Weather Conditions. The climate of the area is referred to as "continental" by climatologists, characterized by cold winters and moderately hot summers. Complete weather records and reports may be obtained from the local U.S. Weather Bureau Office nearest to the work site. The Contractor shall satisfy himself as to the hazards likely to arise from weather conditions during the construction period.

c. Transportation Facilities. The Francis E. Walter Dam is located on the Lehigh River in White Haven, Pennsylvania. The project is accessible by highway. The main access to the project is located off of Pennsylvania State Route 940, approximately 1 mile east of the Pocono Interchange (Exit 35) on the Northeast Extension of the Pennsylvania Turnpike. The Contractor shall be responsible for all investigations of load carrying capacities of bridges and roadways.

d. Water Release Information. The Contractor will need to coordinate with personel in the Corps Hydrology and Hydraulics Brach for both planned and unscheduled releases from the dam. The POC at the Philadelphia District Office is Frank Cook at 215-656-6680. The on-site dam tenders shall also be coordinated with concerning releases. Water release from the dam may raise water levels in the work area as much as four feet.

e. Survey Controls. Survey control description sheets are included as Section 00845 of this contract.

f. Magnitude of the Contract Work. The estimated value of the contract work is between \$100,000 and \$250,000.

g. Hours of Work. Unless otherwise specified, the Contractor shall be permitted to perform the contract work between the hours of 7:45 am and

4:30 pm, Monday through Friday. Federal holidays (New Year's Day, Martin Luther King Jr's Birthday, Presidents Day, Memorial Day, Independence Day, Labor Day, Columbus Day, Veterans Day, Thanksgiving Day, and Christmas Day) that fall within the work week will not be considered as work days. Prior to performing any work during hours other than those specified, the Contractor shall submit an overtime request to the Contracting Officer for review and approval. Overtime requests shall be submitted not less than 24 hours prior to the time the Contractor desires to perform the overtime work. The Contractor shall provide at least a 24 hour advanced notification to establish when on-site work will commence and prior to restarting on-site work following any stoppage of work lasting longer than five normal workdays. Notification shall be provided by phone, or person, or in writing, and shall be given directly to the Contracting Officer.

SC-5 LAYOUT OF WORK (APR 1965 OCE)

The Contractor shall lay out its work from Government-established survey controls, the description of which are provided in Section 00845 of this document, and shall be responsible for all measurements in connection therewith. The Contractor shall furnish, at its own expense, such stakes, templates, platforms, equipment, range markers and labor as may be required in laying out any part of the work from the triangulation stations and bench marks established by the Government. The Contractor shall be responsible for executing the work to such lines and grades as may be established or indicated by the Contracting Officer. It shall be the responsibility of the Contractor to maintain and preserve all stakes and other marks established by the Contracting Officer until authorized to remove them. If such marks are destroyed by the Contractor or through its negligence prior to their authorized removal, they may be replaced by the Contracting Officer at his discretion. The expense of replacement will be deducted from any amounts due or to become due to the Contractor. (CENAP)

SC-6 DAMAGE TO WORK

The responsibility for damage to any part of the permanent work shall be as set forth in the clause of the contract entitled "Permits and Responsibilities". However, if, in the judgement of the Contracting Officer, any part of the permanent work performed by the Contractor is damaged by flood or hurricane, which damage is not due to the failure of the Contractor to take reasonable precautions or to exercise sound engineering and construction practices in the conduct of the work, the Contractor shall make the repairs as ordered by the Contracting Officer and full compensation for such repairs will be made at the applicable contract unit or lump sum prices as fixed and established in the contract. If, in the opinion of the Contracting Officer, there are no contract unit or lump sum prices applicable to any part of such work, an equitable adjustment pursuant to Contract Clause entitled "Changes," will be made as full compensation for the repairs of that part of the permanent work for which there are no applicable contract unit or lump sum prices. Except as herein provided, damages to all work (including temporary construction), utilities, materials, equipment and plant shall be repaired to the satisfaction of the Contracting Officer at the Contractor's expense regardless of the cause of such damage. (CENAP)

SC-7 PERFORMANCE OF WORK BY THE CONTRACTOR (APR 1984)

The Contractor shall perform on the site, and with its own organization, work equivalent to at least twenty (20) percent of the total amount of work to be performed under the contract. This percentage may be reduced by a

supplemental agreement to this contract if, during performing the work, the Contractor requests a reduction and the Contracting Officer determines that the reduction would be to the advantage of the Government. (FAR 52.236-1)

SC-8 ENVIRONMENTAL LITIGATION (1974 NOV OCE)

a. If the performance of all or any part of the work is suspended, delayed, or interrupted due to an order of a court of competent jurisdiction as a result of environmental litigation, as defined below, the Contracting Officer, at the request of the Contractor, shall determine whether the order is due in any part to the acts or omissions of the Contractor or a Subcontractor at any tier not required by the terms of the contract. If it is determined that the order is not due in any part to acts or omissions of the Contractor or a Subcontractor at any tier other than as required by the terms of this contract, such suspension, delay, or interruption shall be considered as if ordered by the Contracting Officer in the administration of this contract under the terms of the SUSPENSION OF WORK clause of this contract. The period of such suspension, delay, or interruption shall be considered unreasonable, and an adjustment shall be made for any increase in the cost of performance of this contract (excluding profit) as provided in that clause, subject to all the provisions thereof.

b. The term "environmental litigation", as used herein, means a lawsuit alleging that the work will have an adverse effect on the environment or that the Government has not duly considered, either substantively or procedurally, the effect of the work on the environment. (CENAP)

SC-9 QUANTITY SURVEYS (APR 1984)

a. Quantity surveys shall be conducted, and the data derived from these surveys shall be used in computing the quantities of work performed and the actual construction completed and in place.

b. The Contractor shall conduct the original and final surveys and make the computations based on them. The Contractor shall conduct the surveys for any periods for which progress payments are requested and shall make the computations based on these surveys. All surveys conducted by the Contractor shall be conducted under the direction of a representative of the Contracting Officer, unless the Contracting Officer waives this requirement in a specific instance.

c. Promptly upon completing a survey, the Contractor shall furnish the originals of all field notes and all other records relating to the survey or to the layout of the work to the Contracting Officer, who shall use them as necessary to determine the amount of progress payments. The Contractor shall retain copies of all such material furnished to the Contracting Officer. (FAR 52.236-16)

SC-10 EQUIPMENT OWNERSHIP AND OPERATING EXPENSE SCHEDULE (MAR 1995)

a. This clause does not apply to terminations. See 52.249-5000, Basis for Settlement of Proposals, and FAR Part 49.

b. Allowable cost for construction and marine plant and equipment in sound workable condition owned or controlled and furnished by the Contractor or sub-contractor at any tier shall be based on actual cost data for each piece of equipment or groups of similar serial or series for which the Government can determine both ownership and operating costs from the Contractor's accounting records. When both ownership and operating costs

cannot be determined for any piece of equipment from the Contractor's accounting records, costs for the equipment shall be based upon the applicable provisions of EP 1110-1-8, "Construction Equipment Ownership and Operating Expense Schedule," Region I. Working conditions shall be considered to be average for determining equipment rates using the schedule unless specified otherwise by the Contracting Officer. For equipment not included in the schedule, rates for comparable pieces of equipment may be used or a rate may be developed using the formula provided in the schedule. For forward pricing, the schedule in effect at the time of negotiations shall apply. For retrospective pricing, the schedule in effect as of the time work was performed shall apply.

c. Equipment rental costs are allowable, subject to the provisions of FAR 31.205(d)(ii) and FAR 31.205-36. Rates for equipment rented from an organization under common control, lease-purchase arrangements, and sale-leaseback arrangements, will be determined using the schedule, except that actual rates will be used for equipment leased from an organization under common control that has an established practice of leasing the same or similar equipment to unaffiliated lessees.

d. When actual equipment costs are proposed and the total amount of the pricing action exceeds the small purchase threshold, the contracting officer shall request the contractor to submit either certified cost or pricing data, or partial/limited data, as appropriate. This data shall be submitted on Standard Form 1411, "Contract Pricing Proposal Cover Sheet." (EFARS 52.231-5000)

Note #1: The small purchase threshold is \$100,000.

Note #2: By submitting cost or pricing data, the Contractor grants to the Contracting Officer or an authorizing representative the right to examine those books, records, documents and other supporting data that will permit evaluation of the proposed equipment costs. This right shall extend for two years after expiration of contract performance. After price agreement the Contractor shall certify that the equipment costs or pricing data submitted are accurate, complete and current.

SC-11 CERTIFICATES OF COMPLIANCE

Any certificates required for demonstrating proof of compliance of materials with specifications requirements shall be executed in triplicate copies. Each certificate shall be signed by an official authorized to certify on behalf of the manufacturing company and shall contain the name and address of the Contractor, the project name and location, and the quantity and date or dates of shipment or delivery to which the certificates apply. Copies of laboratory test reports submitted with certificates shall contain the name and address of the testing laboratory and the date or dates of the tests to which the report applies. Certification shall not be construed as relieving the Contractor from furnishing satisfactory material, if, after tests are performed on selected samples, the material is found not to meet the specific requirements. (CENAP)

SC-12 PERFORMANCE EVALUATION OF CONTRACTOR

a. As a minimum, the Contractor's performance will be evaluated upon final acceptance of the work. However, interim evaluation may be prepared at any time during contract performance when determined to be in the best interest of the Government.

b. The format for the evaluation will be DD 2626, and the Contractor will be rated either outstanding, above average, satisfactory, marginal, or unsatisfactory in the areas of Contractor Quality Control, Timely Performance, Effectiveness of Management, Compliance with Labor Standards, and Compliance with Safety Standards. The Contractor will be advised of any unsatisfactory rating, either in an individual element or in the overall rating, prior to completing the evaluation, and all Contractor comments will be made a part of the official record. Performance Evaluation Reports will be available to all DOD Contracting offices for their future use in determining Contractor responsibility, in compliance with DFARS 236.201(c)(1). (CENAP)

SC-13 TIME EXTENSIONS FOR UNUSUALLY SEVERE WEATHER (OCT 1989)

a. This clause specifies the procedure for determination of time extensions for unusually severe weather in accordance with the Contract Clause entitled: "Default (Fixed-Price Construction)". In order for the Contracting Officer to award a time extension under this clause, the following conditions must be satisfied:

(1) The weather experienced at the project site during the contract period must be found to be unusually severe, that is, more severe than the adverse weather anticipated for the project location during any given month.

(2) The unusually severe weather must actually cause a delay to the completion of the project. The delay must be beyond the control and without the fault or negligence of the Contractor.

b. The following schedule of monthly anticipated adverse weather delays is based on National Oceanic and Atmospheric Administration (NOAA) or similar data for the project location and will constitute the base line for monthly weather time evaluations. The Contractor's progress schedule must reflect these anticipated adverse weather delays in all weather dependent activities. For the purpose of this contract, unusually severe weather is defined as daily precipitation equal to or exceeding 0.5 inches and/or maximum daily temperature not exceeding 32 degrees F.

MONTHLY ANTICIPATED ADVERSE WEATHER DELAY
WORK DAYS BASED ON (5) DAY WORK WEEK

JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
7	4	2	3	3	2	2	2	2	2	2	4

c. Upon acknowledgment of the Notice to Proceed (NTP) and continuing throughout the contract, the Contractor shall record on the daily CQC report, the occurrence of adverse weather and resultant impact to normal scheduled work. Actual adverse weather days must prevent work on critical activities for 50 percent or more of the Contractor's scheduled work day. The number of actual adverse weather delay days shall include days impacted by actual adverse weather (even if adverse weather occurred in previous month), be calculated chronologically from the first to the last day of each month, and be recorded as full days. If the number of actual adverse weather delay days exceeds the number of days anticipated in paragraph b. above, the Contracting Officer will convert any qualifying delays to calendar days, giving full consideration for equivalent fair weather work days, and issue a modification in accordance with the contract clause entitled: "Default (Fixed Price Construction)". (ER 415-1-15)

SC-14 INSURANCE REQUIREMENTS

Evidence of the following insurance shall be provided to the Contracting Officer prior to commencement of work and shall be maintained throughout the period of performance:

- a. General Liability Insurance (Comprehensive form of policy): Bodily Injury Liability - \$500,000 per occurrence.
- b. Automobile Liability Insurance (Comprehensive form of policy): Bodily Injury Liability - \$200,000 per person and \$500,000 per accident. Property Damage Liability - \$20,000 per accident.
- c. Workmen's Compensation and Employer's Liability Insurance: Compliance with applicable workmen's compensation and occupational disease statutes is required. Employer's liability coverage in the minimum amount of \$100,000 is also required."

-- End of Special Clauses --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SECTION 00805

CONTRACT ADMINISTRATION DATA

00805-1 ACCOUNTING AND APPROPRIATION DATA:

To Be Shown on Award

00805-2 CONTRACT ADMINISTRATION:

U.S. Army Engineer District, Philadelphia
Attn: CENAP-CT-C
Wanamaker Building
100 Penn Square East
Philadelphia, Pennsylvania 19107-3390

00805-3 PAYMENT BY:

U.S. Army Corps of Engineer Finance Center
5722 Integrity Drive
Millington, TX 38054-5005

805-4 BILLING ADDRESS:

Invoice shall be forwarded as follows:

U.S. Army Engineer District, Philadelphia
Attn: CENAP-EC-CS
Wanamaker Building
100 Penn Square East
Philadelphia, PA 19107-3390

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

General Decision Number PA020014

General Decision Number PA020014 Superseded General Decision No.
 PA010014

State: Pennsylvania

Construction Type:

HEAVY

HIGHWAY

County(ies):

ADAMS	LEBANON	SCHUYLKILL
BERKS	LEHIGH	SNYDER
BRADFORD	LUZERNE	SULLIVAN
CARBON	LYCOMING	SUSQUEHANNA
COLUMBIA	MONROE	TIOGA
CUMBERLAND	MONTOUR	UNION
DAUPHIN	NORTHAMPTON	WAYNE
JUNIATA	NORTHUMBERLAND	WYOMING
LACKAWANNA	PERRY	YORK
LANCASTER	PIKE	

HEAVY AND HIGHWAY CONSTRUCTION PROJECTS (Excluding Sewer Groutin
 Projects and Excluding Sewage and Water Treatment Plant Projects

Modification Number Publication Date

0	03/01/2002
1	05/03/2002
2	06/28/2002
3	07/12/2002

COUNTY(ies):

ADAMS	LEBANON	SCHUYLKILL
BERKS	LEHIGH	SNYDER
BRADFORD	LUZERNE	SULLIVAN
CARBON	LYCOMING	SUSQUEHANNA
COLUMBIA	MONROE	TIOGA
CUMBERLAND	MONTOUR	UNION
DAUPHIN	NORTHAMPTON	WAYNE
JUNIATA	NORTHUMBERLAND	WYOMING
LACKAWANNA	PERRY	YORK
LANCASTER	PIKE	

BOIL0013C 01/01/2002

	Rates	Fringes
BOILERMAKERS	30.60	13.91

 CARP0076K 05/01/2002

	Rates	Fringes
COLUMBIA, MONTOUR, NORTHUMBERLAND, SCHUYLKILL, SNYDER, UNION, the lower part of Luzerne county, Carbon County, Banks, Lusanna, Lehigh, Packer, Kidder townships, and part of Penn Forest township north of Route 903		

MILLWRIGHTS	23.33	8.73
-------------	-------	------

 CARP0121A 05/01/2002

	Rates	Fringes
EXCEPT CARBON, LEHIGH AND NORTHAMPTON COUNTIES CARPENTERS/PILED RIVERMEN	21.07	6.10

CARP0191G 05/01/2001		
	Rates	Fringes
YORK COUNTY		
ZONE 1: (All projects within a radius of ten miles of Center Square)		
MILLWRIGHTS	19.69	7.13
ZONE 2: (All projects within a radius of ten to twenty miles from Center Square)		
MILLWRIGHTS	19.89	7.13
zone 3: (All projects beyond a radius of twenty miles from Center Square)		
MILLWRIGHTS	20.29	7.13

CARP0261B 05/01/2001		
	Rates	Fringes
LACKAWANNA, MONROE, PIKE, SUSQUEHANNA, WAYNE, AND WYOMING (East of the Susquehanna River) COUNTIES		
CARPENTERS	20.74	7.05
MILLWRIGHTS	21.30	7.05

CARP0287J 05/01/2002		
	Rates	Fringes
ADAMS, CUMBERLAND, DAUPHIN, JUNIATA, LANCASTER, LEBANON, PERRY, NEW CUMBERLAND ARMY DEPOT AND HARRISBURG YORK STATE AIRPORT IN YORK COUNTY		
MILLWRIGHTS	22.78	9.23

CARP0492B 05/01/2002		
	Rates	Fringes
BERKS COUNTY		
MILLWRIGHTS	24.09	7.42

CARP0600I 07/01/2001		
	Rates	Fringes
CARBON, LEHIGH AND NORTHAMPTON COUNTIES		
CARPENTERS/PILED RIVERMEN	24.68	10.33

CARP1906B 07/01/2000		
	Rates	Fringes
CARBON, LEHIGH AND NORTHAMPTON COUNTIES		
MILLWRIGHTS	24.00	11.06

ELEC0126C 06/04/2000		
	Rates	Fringes
ADAMS, CUMBERLAND, DAUPHIN, LANCASTER, LEBANON, JUNIATA, PERRY AND YORK COUNTIES		
LINE CONSTRUCTION:		
Linemen	23.68	16%+2.80
Winch Truck Operators	16.58	16%+2.80
Truck Drivers	15.39	16%+2.80
Groundmen	14.21	16%+2.80
BERKS AND LEHIGH NORTHAMPTON COUNTIES		
LINE CONSTRUCTION:		
Linemen	24.78	16%+2.80
Winch Truck Operators	17.35	16%+2.80
Truck Driver	16.11	16%+2.80
Groundmen	14.87	16%+2.80

 ELEC1319A 06/02/2002

	Rates	Fringes
BRADFORD, CARBON, COLUMBIA, LACKAWANNA, LUZERNE, LYCOMING, MONROE, MONTOUR, NORTHUMBERLAND, PIKE, SCHUYLKILL, SNYDER, SULLIVAN, SUSQUEHANNA, TIOGA, UNION, WAYNE, AND WYOMING COUNTIES LINE CONSTRUCTION:		
Lineman	27.54	6%+6.55
Winch Truck Operators	19.55	6%+6.55
Groundmen	17.35	6%+6.55
Truck Drivers	19.20	6%+6.55

 ELEC2011A 05/01/1988

	Rates	Fringes
ADAMS, BERKS, CUMBERLAND, DAUPHIN, JUNIATA, LANCASTER, LEBANON, LEHIGH, NORTHAMPTON, AND PERRY COUNTIES LINE CONSTRUCTION (RAILROAD ONLY)		
GROUP 1	12.34	6%+.06+A
GROUP 2	12.34	6%+.60+A
GROUP 3	10.78	6%+.60+A

FOOTNOTE:

A. PAID HOLIDAYS: New Year's Day, Memorial Day, Independence Day, Labor Day, Election Day, Thanksgiving Day and Christmas Day, provided the employee works the day before and after the holiday.

LINE CONSTRUCTION CLASSIFICATIONS

GROUP 1: Linemen

GROUP 2: Hoisting equipment - when erecting complete towers, erecting framed structures, erecting steel transmission poles, erecting railroad pole extensions and crossbeams and when operating personnel lift baskets. Tension pulling equipment under energized conditions - parallel with other energized circuits or above energized circuits on same structure not to include crossovers. Bundled conductor stringing including static conductors on bundled conductor lines. Excavating augers 36" inches in diameter or larger, 5/8 cubic yard, backhoe and larger, trencher over four feet in depth, bulldozer D-6 (caterpillar) or larger, and blade on finish grade work.

GROUP 3: Operators of all other equipment.

 * ENGI0542C 05/01/2002

	Rates	Fringes
POWER EQUIPMENT OPERATORS: HIGHWAY CONSTRUCTION AND WATER LINES CONSTRUCTION (OFF PLANT SITE)		
GROUP 1	19.92	11.83
GROUP 2	18.97	11.01
GROUP 3	18.42	10.91
GROUP 4	17.98	10.77
GROUP 5	17.47	10.62
GROUP 6	20.16	11.90

POWER EQUIPMENT OPERATORS CLASSIFICATIONS

GROUP 1 - Pile drivers, all types of cranes, all types of backhoes, draglines, keystones, all types of shovels, derricks, trench shovels, trenching machines, paver (blacktop and concrete), gradalls, all front end loaders, tandem scrapers,

pippin types backhoes, boat captains, batch plant with mixer, drill self contained (drill-master type), CMI Autograde, milling machine, vemeer saw, conveyor loader (euclid type) scraper and tournapulls, bulldozers and tractors, concrete pumps, motor patrols, mechanic welders, log skidder, side boom, bobcat type (with attachments), boring machines including directional boring machines, chipper with boom, hydro ax, machines similar to the above including remote control equipment.

GROUP 2 - Spreaders, asphalt plant engineers, rollers (high grade finishing), machine similar to above, including remote control equipment.

GROUP 3 - Welding machine, well points, compressors, pump heaters, farm tractors, form line graders, ditch witch type trencher, road finishing machines, concrete breaking machines, rollers, miscellaneous equipment operator, seaman pulverizing mixer, power broom, seeding spreader, tireman - (for power equipment) conveyors, loaders other than EUC type, conveyors, driller second class, machines similar to the above including remote control equipment.

GROUP 4 - Fireman and grease truck

GROUP 5 - Oilers and deck hands

GROUP 6 - All machines with booms (including jibs, masts, leads, etc.) 100 ft. and over.

TOXIC/HAZKARDOUS WAST REMOVAL Add 20 per cent to basic hourly rate for all classifications

 ENGI0542V 05/01/2001

	Rates	Fringes
HEAVY CONSTRUCTION:		
POWER EQUIPMENT OPERATORS:		
GROUP 1	21.50	29.5%+5.47+A
GROUP 2	21.22	29.5%+5 46+A
GROUP 3	18.68	29.5%+4.97+A
GROUP 4	17.55	29.5%+4.97+A
GROUP 5	17.09	29.5%+4.97+A
GROUP 6	16.21	29.5%+4.97+A

FOOTNOTE:

A: PAID HOLIDAYS: New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day, and Christmas Day, the the employee works the day before and the day after the holiday.

TOXIC/HAZKARDOUS WASTE REMOVAL Add 20 per cent to basic hourly rate for all classifications

POWER EQUIPMENT OPERATORS CLASSIFICATIONS

GROUP 1: Machines doing hook work, any machine handling machinery, cable spinning machines, helicopters, machines similar to the above, including remote control equipment.

GROUP 2: All types of cranes (except cranes doing hook work), backhoes, cableways, draglines, keystones, shovels, derricks, trench shovels, trenching machines, hoist with two towers, pavers 21E and over, overhead cranes, building hoists (double drum) gradalls, mucking machines in tunnels, front end loaders, tandem scrapers, pippin type backhoes, boat captains, batch plant operators concrete drills, self-contained rotary drills, fork lifts, 20ft, lift and over, scrapers, tournapulls, spreaders, bulldozers and tractors, rollers (high grade finishing), mechanic-welder, motor patrols, concrete pumps, grease truck,

bob cat type (all attachments), boring machines including directional boring machines, hydro ax, side boom, vermeer saw, chipper with boom, machines similar to the above including remote control equipment

GROUP 3: Conveyors, building hoist (single drum), high or low pressure boilers, drill operators, well drillers, asphalt plant engineers, ditch witch type trencher, second class driller, forklift truck under 20ft. lift, stump grinder tireman grinder, tireman (for power equipment), machines similar to above including remote control equipment.

GROUP 4: Welding machines, well points, compressors, pumps, heaters, farm tractors, form line graders, road finishing machines, concrete breaking machines, rollers, seaman pulverizing mixer, power boom, seeding spreader, chipper without boom, machines similar to the above including remote control equipment.

GROUP 5: Fireman.

GROUP 6: Oilers and deck hands (personnel boats).

IRON0036B 07/01/2001

	Rates	Fringes
CARBON, LEHIGH (Except Fogelsville), NORTHAMPTON AND MONROE (Except Tobyhanna Army Depot)		
IRONWORKERS:		
Projects Under 25 Million Dollars	24.59	13.23
Projects Over 25 Million Dollars	25.09	13.23

IRON0404H 07/01/2001

	Rates	Fringes
ADAMS, CUMBERLAND, DAUPHIN, LEBANON (Western 3/4), LANCASTER (Western part), LYCOMING, MONTOUR, NORTHUMBERLAND, JUNIATA, PERRY, SCHUYLKILL (Western tip to include the twps. of Fearnot, Good Spring, Hegins, Jolett, Klingerstown, Muir, Pittman Haas, Rough and Ready, Sacramento, Spring Glen, Suedberg, Tower City, and Valley View), SNYDER, UNION, AND YORK COUNTIES		
IRONWORKERS:		
Structural, Ornamental	21.50	11.62
Reinforcing	18.75	11.62

IRON0420F 07/01/2001

	Rates	Fringes
BERKS, LANCASTER (Eastern Part), LEBANON (Eastern 1/4), LEHIGH (Fogelsville), AND SCHUYLKILL (Remainder) COUNTIES		
IRONWORKERS:		
STRUCTURAL, ORNAMENTAL, AND REINFORCING:		
Projects \$100,000,000 and greater, (all work)	22.75	12.70
Projects less than \$100,000,000	22.25	12.70

IRON0489B 07/01/2001

	Rates	Fringes
BRADFORD, COLUMBIA, LACKAWANNA, LUZERNE, MONROE (Tobyhanna Depot only), PIKE, SULLIVAN, TIOGA, SUSQUEHANNA, WAYNE, WYOMING, CARBON (Northern tip - McAdoo), LYCOMING (Southern tip - Hughsville)		
IRONWORKERS:		
Structural and Ornamental	23.15	13.95
Reinforcing	22.90	13.95

LABO0158A 05/01/2002

	Rates	Fringes
LABORERS:		
GROUP 1	17.25	6.41
GROUP 2	17.45	6.41
GROUP 3	17.80	6.41
GROUP 4	18.03	6.41
GROUP 5	18.09	6.41
GROUP 6	18.47	6.41
GROUP 7	12.84	6.41
GROUP 8	17.89	6.41
GROUP 9	18.18	6.41
GROUP 10	18.66	6.41
GROUP 11	20.46	6.41

LABORERS CLASSIFICATIONS

- GROUP 1: Asphalt, tampers, concrete pitmen, puddlers & rubbers, Highway guardrail, right of way and property line fence, Highway slab renforcng placers, laborers, landscape, planters, seeders and arborists, magazine tenders, railroad trackmen, & signalmen, leaser beam men (pipe laying, paving machine)
- GROUP 2: Pnuematic and Electric tool operator jackhammers, paving breakers, concrete saws, whacker vibrators, sheet hammers, steward, chain saws, pipelayers, asphalt rake, lute or screed men, concrete block layers
- GROUP 3: Caisson-open air below 8 feet, cofferdam open air below 8 feet where excavations for circular caissons and cofferdams 8 ft and below level of natural grade adjacent to starting point, form setters (road) wagon drill diamond point drill, gunite nozzle operators
- GROUP 4: Blasters
- GROUP 5: Reinforcing steel placers, bonding, aligning and securing and burning and welding in conjunction with reinforcing steel
- GROUP 6: Concrete surfaces
- GROUP 7: Flaggers
- FREE AIR TUNNELS AND ROCK SHAFTS:
- GROUP 8: Outside laborers in conjunction tunnels & rock shafts
- GROUP 9: Chuck Tenders, Muckers, Nippers, Miners
- GROUP 10: Miners, Drillers, Blasters, Pneumatic Shield Operators Lining, Spotting & Timers Workmen, Reinforcing Steel placers, Bonding, Aligning and Securing Welders and Concrete Surfaces.
- GROUP 11: Hazardous/Toxic handler

PAIN0057Y 06/01/2000

	Rates	Fringes
JUNIATA COUNTY		
PAINTERS:		
Brush (Commercial & Roller	20.22	7.37
Industrial Brush & Roller	22.22	7.37
Spray	22.72	7.37

PAIN0411G 05/01/2001

	Rates	Fringes
DAUPHIN, CUMBERLAND, PERRY, ADAMS, LANCASTER AND YORK COUNTIES		
PAINTERS:		

Invitation for Bids
DACW61-02-B-0029

Brush	20.80	4.65
Spray, Sandblast	21.80	4.65
Bridge	23.63	4.65

PAIN1021E 06/01/2001

	Rates	Fringes
CARBON, LEHIGH, NORTHAMPTON, AND MONROE COUNTIES		
PAINTERS:		
Brush, Roller	21.20	7.60
Spray, Sandblast	22.20	7.60
Bridge	22.07	7.60

PAIN1021F 06/01/2001

	Rates	Fringes
BERKS, BRADFORD, COLUMBIA, LACKWANNA, LEBANON, LUZERNE, LYCOMING, MONTOUR, NORTHUMBERLAND, PIKE, SCHUYLKILL, SNYDER, SULLIVAN, SUSQUEHANNA, TIOGA, UNION, WAYNE, WYOMING COUNTIES		
PAINTERS:		
Brush and roller	21.00	7.35
Spray, Sandblast	22.00	7.35
Bridge; Brush, Roller	21.95	7.35
Bridge; Spray	22.95	7.35

PLAS0052F 05/03/1999

	Rates	Fringes
MONROE COUNTY; (EXCEPT TOBYHANNA DEPOT)		
CEMENT MASONS	20.32	8.20

PLAS0055B 05/01/2000

	Rates	Fringes
COLUMBIA COUNTY:		
CEMENT MASONS	21.75	5.95

PLAS05920 05/01/2002

	Rates	Fringes
BERKS (Except Northeastern part), LEBANON (Eastern part) LANCASTER (Northeastern part). In Berks County through East Greenville, Huffs Church, Fredericksville, Dryville, Lyon Station, Kutztown, Krumsville and Stoney Run to Lehigh County Line, Thence along Lehigh County Line to Schuylkill County Line to Lebanon County Line, along Lebanon County Line to Route 501 North to Myerstown, Then South through Myerstown to PA Turnpike in Lancaster County, East on Turnpike to Morgantown in Berks County)		
CEMENT MASONS	21.00	6.34
BERKS (Northeastern part lying North of a line starting from the Southern boundary line of Lehigh County continuing through Huffs Church, Fredericksville, Dryville, Lyon Station, Kutztown, Krumsville, and Stoney run in Berks County to the Lehigh County line), CARBON, LEHIGH, NORTHAMPTON (Northwest part including the towns of Walnutport, Bath, and Northampton) COUNTIES		
CEMENT MASONS	21.00	9.53
The following portions of LANCASTER, YORK, ADAMS AND CUMBERLAND COUNTIES (Within the following Boundary Lines: starting at the Maryland State Line, North on the Lancaster-Chester County Line to Berks County Line. North to the PA Turnpike, West on the Turnpike to Route 501. North on Route 501 to Lancaster-Dauphine		

County Line, then West to the Susquehanna River, cross the river to Route 920 and continue to Goldsboro, Lewisberry and Rossville to Dillsburg, thence to Route 15 to Heidlersburg, thence on Route 234 to Junction of Route 334, up Route 334 to Route 34 to junction of road immediately South of Hunters' Run; Then to Pine Grove Furnace, Continue on Route 233 to Mont Alto; Thence on Route 997 to road immediately South of Fayetteville; Thence through New Franklin to Marion; Thence to St. Thomas, then on Route eo through Fort Loudon to Franklin County Line at Tuscarora Mts. Then South on the Franklin-Fulton County Line to Maryland State Line)

CEMENT MASONS	19.75	8.40
BRADFORD, LACKAWANNA, LUZERNE, LYCOMING, ,MONROE (Tobyhanna), SCHUYLKILL, SULLIVAN, TIOGA, UNION AND WYOMING COUNTIES		
CEMENT MASONS	22.53	4.70
CUMBERLAND, DAUPHIN, FRANKLIN, FULTON, JUNIATA, MONTOUR, NORTHUMBERLAND, PERRY, SNYDER; and parts of ADAMS, LEBANON AND YORK COUNTIES		
CEMENT MASONS	20.50	6.85

PLAS9592E 05/01/2000		
	Rates	Fringes
MONROE COUNTY (TOBYHANNA ARMY DEPOT)		
CEMENT MASONS	21.88	4.05

TEAM0229F 05/01/2000		
	Rates	Fringes
ADAMS, BERKS, CARBON, COLUMBIA, CUMBERLAND, DAUPHIN, JUNIATA, LACKAWANA, LANCASTER, LEBANON, LEHIGH, LUZERNE, LYCOMING, MONROE, MONTOUR, NORTHAMPTON, NORTHUMBERLAND, PERRY, PIKE, SCHUYKILL, SNYDER, SULLIVAN, SUSQUEHANNA, UNION, WAYNE, WYOMING, AND YORK COUNTIES		
TRUCK DRIVERS		
GROUP 1	22.33	
GROUP 2	22.40	
GROUP 3	22.89	
BRADFORD AND TIOGA COUNTIES		
TRUCK DRIVERS		
GROUP 1	13.50	8.33
GROUP 2	13.57	8.33
GROUP 3	14.06	8.33

TRUCK DRIVERS CLASSIFICATIONS
 GROUP 1 - Stake body truck (single axle, dumpster)
 GROUP 2 - Dump trucks, tandem and batch trucks, semi-trailers, agitator mixer trucks, Ready-mix and dumpcrete type vehicles, asphalt distributors when used for transportation, stake body truck (tandem)
 GROUP 3 - Euclid-type, off highway equipment-back or belly dump trucks and double-hitched equipment, straddle (ross) carrier, low-bed trailers

WELDERS - Receive rate prescribed for craft performing operation to which welding is incidental.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses

(29 CFR 5.5(a)(1)(ii)).

In the listing above, the "SU" designation means that rates listed under that identifier do not reflect collectively bargained wage and fringe benefit rates. Other designations indicate unions whose rates have been determined to be prevailing.

WAGE DETERMINATION APPEALS PROCESS

1.) Has there been an initial decision in the matter? This can be:

- * an existing published wage determination
- * a survey underlying a wage determination
- * a Wage and Hour Division letter setting forth a position on a wage determination matter
- * a conformance (additional classification and rate) ruling

On survey related matters, initial contact, including requests for summaries of surveys, should be with the Wage and Hour Regional Office for the area in which the survey was conducted because those Regional Offices have responsibility for the Davis-Bacon survey program. If the response from this initial contact is not satisfactory, then the process described in 2.) and 3.) should be followed.

With regard to any other matter not yet ripe for the formal process described here, initial contact should be with the Branch of Construction Wage Determinations. Write to:

Branch of Construction Wage Determinations
Wage and Hour Division
U. S. Department of Labor
200 Constitution Avenue, N. W.
Washington, D. C. 20210

2.) If the answer to the question in 1.) is yes, then an interested party (those affected by the action) can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Write to:

Wage and Hour Administrator
U.S. Department of Labor
200 Constitution Avenue, N. W.
Washington, D. C. 20210

The request should be accompanied by a full statement of the interested party's position and by any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3.) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board
U. S. Department of Labor
200 Constitution Avenue, N. W.
Washington, D. C. 20210

4.) All decisions by the Administrative Review Board are final.

END OF GENERAL DECISION

This page was intentionally left blank for duplex printing.


THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

Digital 1959 Form

Country	USA	Type of Mark	Standard Disk	Station	53.01
State	Pennsylvania	Stamp	53.01	Elevation	1496.06 FT
Municipality	Luzerne County	Agency	USACE	Datum	NAVD 88
PID		Established by	USACE	Order	
Latitude	41°07'02.11" N	Longitude	75°43'40.32" W	Datum	NAD 83
Northing	352848.33594 SFT	Easting	2525619.17514 SFT	Grid and Zone	PA NORTH

Description

THE STATION IS LOCATED AT THE FRANCIS E. WALTER RESERVOIR IN LUZERNE COUNTY, PENNSYLVANIA. TO REACH THE STATION FROM THE INTERSECTION OF ROUTE 940 AND THE EXIT RAMPS OF THE PENNSYLVANIA TURNPIKE AND I-80 PROCEED EAST NORTHEAST ON ROUTE 940E 1.1 MILES TO A "T" WITH A MACADAM ROAD. TURN LEFT AND PROCEED NORTH NORTHWEST ON MACADAM ROAD 2.55 MILES TO A GATE. CONTINUE ON MACADAM ROAD 1.0 MILES TO ANOTHER GATE. CONTINUE ON MACADAM ROAD 0.22 MILES TO A "T" WITH A GRAVEL ACCESS ROAD. TURN LEFT AND PROCEED SOUTH ON THE GRAVEL ROAD 70 FEET TO THE STATION ON THE RIGHT. THE STATION IS A STANDARD CORPS OF ENGINEERS BRASS DISC IN A 6" DIAMETER CONCRETE MONUMENT 0.2 FEET ABOVE SURFACE STAMPED 53.01 1947. THE STATION IS 17.18 FEET SOUTH SOUTHWEST OF "A-1", 60.8 FEET WEST SOUTHWEST OF A 10" OAK TREE, AND 30.14 FEET SOUTH SOUTHWEST OF A POWER POLE (#PPC55703 N35286).




Digital 1959 Form

Country	USA	Type of Mark	Standard Disk	Station	A-1
State	Pennsylvania	Stamp	A-1	Elevation	1496.47 FT
Municipality	Luzerne County	Agency	USACE	Datum	NAVD 88
PID		Established by	USACE	Order	
Latitude	41°07'02.28" N	Longitude	75°43'40.26" W	Datum	NAD 83
Northing	352865.64369 SFT	Easting	2525623.36448 SFT	Grid and Zone	PA NORTH

Description

THE STATION IS LOCATED AT THE FRANCIS E. WALTER RESERVOIR IN LUZERNE COUNTY, PENNSYLVANIA. TO REACH THE STATION FROM THE INTERSECTION OF ROUTE 940 AND THE EXIT RAMPS OF THE PENNSYLVANIA TURNPIKE AND I-80 PROCEED EAST NORTHEAST ON ROUTE 940E 1.1 MILES TO A "T" WITH A MACADAM ROAD. TURN LEFT AND PROCEED NORTH NORTHWEST ON MACADAM ROAD 2.55 MILES TO A GATE. CONTINUE ON MACADAM ROAD 1.0 MILES TO ANOTHER GATE. CONTINUE ON MACADAM ROAD 0.22 MILES TO A "T" WITH A GRAVEL ACCESS ROAD. TURN LEFT AND PROCEED SOUTH ON THE GRAVEL ROAD 70 FEET TO THE STATION ON THE RIGHT. THE STATION IS A STANDARD CORPS OF ENGINEERS BRASS DISC IN A 4"x4" CONCRETE MONUMENT 0.2 FEET ABOVE SURFACE STAMPED A-1 1971. THE STATION IS 40.2 FEET SOUTH SOUTHWEST OF A 10" OAK TREE, 51 FEET WEST OF A 10" OAK TREE, AND 25.3 FEET SOUTHEAST OF A POWER POLE (#PPC55703 N35296).




Digital 1959 Form

Country	USA	Type of Mark	Standard Disk	Station	A-2
State	Pennsylvania	Stamp	A-2	Elevation	1477.61 FT
Municipality	Carbon County	Agency	USACE	Datum	NAVD 88
PID		Established by	USACE	Order	
Latitude	41°06'37.43" N	Longitude	75°43'09.91" W	Datum	NAD 83
Northing	350405.67896 SFT	Easting	2528004.60473 SFT	Grid and Zone	PA NORTH

Description

THE STATION IS LOCATED AT THE FRANCIS E. WALTER RESERVOIR IN CARBON COUNTY, PENNSYLVANIA. TO REACH THE STATION FROM THE INTERSECTION OF ROUTE 940 AND THE EXIT RAMP OF THE PENNSYLVANIA TURNPIKE AND I-80 PROCEED EAST NORTHEAST ON ROUTE 940E 1.1 MILES TO A "T" WITH A MACADAM ROAD. TURN LEFT AND PROCEED NORTH NORTHWEST ON MACADAM ROAD 2.55 MILES TO A GATE. CONTINUE ON MACADAM ROAD 1.0 MILES TO ANOTHER GATE. CONTINUE ON MACADAM ROAD 106 FEET TO A "T" WITH A GRAVEL ROAD. TURN LEFT AND PROCEED SOUTH SOUTHWEST ON GRAVEL ACCESS ROAD 0.07 MILES TO A GATE. PASS THROUGH GATE AND CONTINUE ON THE GRAVEL ROAD 0.1 MILES TO ITS INTERSECTION WITH THE TOP OF DAM. CONTINUE SOUTHEAST ON TOP OF DAM 0.3 MILES TO A TURNAROUND AREA AND THE STATION IS STRAIGHT AHEAD. THE STATION IS A STANDARD CORPS OF ENGINEERS BRASS DISC SET IN A ROCK OUTCROP FLUSH WITH SURFACE STAMPED A-2. THE STATION IS 62.9 FEET EAST OF THE SOUTHWESTERMOST GUARDRAIL POST ON THE SOUTH SIDE OF AN ACCESS ROAD, 40.67 FEET NORTH OF A CORPS OF ENGINEERS MONUMENT (NOT STAMPED), AND 20 FEET SOUTHEAST OF THE EDGE OF THE GRAVEL TURNAROUND.




Digital 1959 Form

Country	USA	Type of Mark	Standard Disk	Station	OUT-1
State	Pennsylvania	Stamp	OUT-1	Elevation	1256.85 FT
Municipality	Luzerne County	Agency	USACE	Datum	NAVD 88
PID		Established by	FWA, INC	Order	
Latitude	41°06'35.80" N	Longitude	75°43'30.40" W	Datum	NAD 83
Northing	350204.03932 SFT	Easting	2526440.46993 SFT	Grid and Zone	PA NORTH

Description

THE STATION IS LOCATED AT THE FRANCIS E. WALTER RESERVOIR IN LUZERNE COUNTY, PENNSYLVANIA. TO REACH THE STATION FROM THE INTERSECTION OF ROUTE 940 AND THE EXIT RAMP OF THE PENNSYLVANIA TURNPIKE AND I-80 PROCEED EAST NORTHEAST ON ROUTE 940E 1.1 MILES TO A "T" WITH A MACADAM ROAD. TURN LEFT AND PROCEED NORTH NORTHWEST ON MACADAM ROAD 2.55 MILES TO A GATE. CONTINUE ON MACADAM ROAD 1.0 MILES TO ANOTHER GATE. CONTINUE ON MACADAM ROAD 106 FEET TO A "T" WITH A GRAVEL ROAD. TURN LEFT AND PROCEED SOUTH SOUTHWEST ON GRAVEL ACCESS ROAD 0.07 MILES TO A GATE. PASS THROUGH GATE AND CONTINUE ON THE GRAVEL ROAD 0.1 MILES TO ITS INTERSECTION WITH THE TOP OF DAM. TURN RIGHT AND TAKE LEFT ACCESS ROAD OFF OF DAM 0.11 MILES TO A FORK IN THE GRAVEL ACCESS ROAD. TAKE THE LEFT FORK HEADING WEST SOUTHWEST 0.24 MILES TO A "T" WITH A GRAVEL ACCESS ROAD LEFT. CONTINUE STRAIGHT AND PROCEED SOUTHWEST 0.33 MILES TO WHERE THE ACCESS ROAD TURNS INTO A FOOTPATH AND THE STATION IS ON THE RIGHT. STATION IS A STANDARD CORPS OF ENGINEERS ALUMINUM DISC SET IN CONCRETE 0.1 FEET ABOVE SURFACE STAMPED OUT-1. THE STATION IS 3.3 FEET WEST NORTHWEST OF A WIRE FENCE LINE, 7.7 FEET SOUTH SOUTHWEST OF A WOOD POST FOR DANGER SIGN, AND 69 FEET EAST NORTHEAST OF A WOOD POST FOR DANTER SIGN.




Digital 1959 Form

Country	USA	Type of Mark	Standard Disk	Station	OUT-2
State	Pennsylvania	Stamp	OUT-2	Elevation	1296.29 ft
Municipality	Luzerne County	Agency	USACE	Datum	NAVD 88
PID		Established by	FWA, INC	Order	
Latitude	41°06'40.35" N	Longitude	75°43'23.89" W	Datum	NAD 83
Northing	350676.06041 SFT	Easting	2526927.87480 SFT	Grid and Zone	PA NORTH

Description

THE STATION IS LOCATED AT THE FRANCIS E. WALTER RESERVOIR IN CARBON COUNTY, PENNSYLVANIA. TO REACH THE STATION FROM THE INTERSECTION OF ROUTE 940 AND THE EXIT RAMP OF THE PENNSYLVANIA TURNPIKE AND I-80 PROCEED EAST NORTHEAST ON ROUTE 940E 1.1 MILES TO A "T" WITH A MACADAM ROAD. TURN LEFT AND PROCEED NORTH NORTHWEST ON MACADAM ROAD 2.55 MILES TO A GATE. CONTINUE ON MACADAM ROAD 1.0 MILES TO ANOTHER GATE. CONTINUE ON MACADAM ROAD 106 FEET TO A "T" WITH A GRAVEL ROAD. TURN LEFT AND PROCEED SOUTH SOUTHWEST ON GRAVEL ACCESS ROAD 0.07 MILES TO A GATE. PASS THROUGH GATE AND CONTINUE ON THE GRAVEL ROAD 0.1 MILES TO ITS INTERSECTION WITH THE TOP OF DAM. TURN RIGHT AND TAKE LEFT ACCESS ROAD OFF OF DAM 0.11 MILES TO A FORK IN THE GRAVEL ACCESS ROAD. TAKE THE LEFT FORK HEADING WEST SOUTHWEST 0.24 MILES TO A "T" WITH A GRAVEL ACCESS ROAD LEFT. TURN LEFT AND PROCEED SOUTH SOUTHEAST 0.05 MILES TO STATION ON RIGHT. THE STATION IS A STANDARD CORPS OF ENGINEERS ALUMINUM DISC SET IN CONCRETE FLUSH WITH SURFACE STAMPED OUT-2. THE STATION IS 8.3 FEET NORTHEAST OF A 4' CHAINLINK FENCE, 11.6 FEET NORTH OF THE CORNER FENCE POST, AND 7.5 FEET WEST OF THE GRAVEL ACCESS ROAD.




Digital 1959 Form

Country	USA	Type of Mark	Standard Disk	Station	WALL
State	Pennsylvania	Stamp	WALL	Elevation	1435.76 FT
Municipality	Luzerne County	Agency	USACE	Datum	NAVD 88
PID		Established by	FWA, INC	Order	
Latitude	41°06'57.99" N	Longitude	75°43'27.81" W	Datum	NAD 83
Northing	352453.84840 SFT	Easting	2526586.15126 SFT	Grid and Zone	PA NORTH

Description

THE STATION IS LOCATED AT THE FRANCIS E. WALTER RESERVOIR IN LUZERNE COUNTY, PENNSYLVANIA. TO REACH THE STATION FROM THE INTERSECTION OF ROUTE 940 AND THE EXIT RAMP OF THE PENNSYLVANIA TURNPIKE AND I-80 PROCEED EAST NORTHEAST ON ROUTE 940E 1.1 MILES TO A "T" WITH A MACADAM ROAD. TURN LEFT AND PROCEED NORTH NORTHWEST ON MACADAM ROAD 2.55 MILES TO A GATE. CONTINUE ON MACADAM ROAD 1.0 MILES TO ANOTHER GATE. CONTINUE ON MACADAM ROAD 106 FEET TO A "T" WITH A GRAVEL ROAD. CONTINUE ON MACADAM ROAD 50 FEET TO A PULL-OFF AREA ON THE LEFT. TURN LEFT INTO PULL-OFF AREA AND THE STATION IS STRAIGHT AHEAD. THE STATION IS A STANDARD CORPS OF ENGINEERS ALUMINUM DISC SET IN CONCRETE FLUSH WITH SURFACE STAMPED WALL. THE STATION IS 100 FEET WEST OF THE EDGE OF THE GRAVEL PULL-OFF AREA, 152.8 FEET NORTHWEST OF A WOOD SIGN, AND 123.9 FEET NORTH OF A CONCRETE HEADWALL.



SEEPAGE WEIR 3A MODIFICATION
F.E. WALTER DAM
LEHIGH RIVER, PENNSYLVANIA

PROJECT TABLE OF CONTENTS

DIVISION 01 - GENERAL REQUIREMENTS

01010 SUMMARY OF WORK
01060 SAFETY
01320 CONSTRUCTION PHOTOGRAPHY
01325 PROJECT SCHEDULE
01330 SUBMITTAL PROCEDURES
01355 ENVIRONMENTAL PROTECTION
01420 SOURCES FOR REFERENCE PUBLICATIONS
01450 CONTRACTOR QUALITY CONTROL
01500 TEMPORARY CONSTRUCTION
01720 SURVEY REQUIREMENTS
01780 AS-BUILT DRAWINGS

DIVISION 02 - SITE WORK

02230 SITE CLEARING
02271 RIPRAP
02300 EARTHWORK
02378 GEOSYNTHETICS
02921 SEEDING

DIVISION 03 - CONCRETE

03101 FORMWORK FOR CONCRETE
03201 STEEL BARS FOR CONCRETE REINFORCEMENT
03307 CONCRETE FOR MINOR STRUCTURES

DIVISION 10 - SPECIALTIES

10050 METAL WEIR AND ACCESSORIES

-- End of Project Table of Contents --

This page was intentionally left blank for duplex printing.

SECTION 01010

SUMMARY OF WORK

PART 1 GENERAL

1.1 SUMMARY OF WORK

The work covered by this Contract generally consists of furnishing all plant, labor, materials, equipment and appliances in performing all operations necessary for the relocation of the F.E. Walter Dam Seepage Weir 3A. All work shall be performed within the Limit of Disturbance indicated on the Contract Drawings. Laydown areas available for use by the Contractor during construction are indicated on the Contract Drawings.

1.2 MAJOR ITEMS OF WORK

All work shall be performed in accordance with the Contract Drawings and these Specifications. The major items of work to be performed under this Contract generally include, but are not limited to the following:

- a. Coordination of all construction activities with the U.S. Army Corps of Engineers.
- b. Development and implementation of a sediment and erosion control plan for the project.
- c. Improvement of access to the project site as necessary to complete the proposed construction.
- d. Diversion of the existing surface and seepage flow in the vicinity of the new weir during construction activities.
- e. Removal and disposal of the existing Weir 3A.
- f. Construction of a cut-off trench, lined with a composite clay/geotextile liner, upgradient of the embankment.
- g. Construction of an approximately 185 foot long earthen embankment.
- h. Construction of an adjustable weir plate on a concrete mounting frame at the top of the new earthen embankment.
- i. Placement of geotextile and stone riprap on the slopes of the new earthen embankment.

1.3 SITE CONDITIONS

1.3.1 Site Access

Access road is accessible by on road, high clearance vehicles to survey marker OUT-2. Beyond this point the access road is accessible by 4-wheel drive or tracked vehicles. It is anticipated that access road improvements may be required from this point to the waste berm area.

1.3.2 Site Photographs

Plates 1 through 4 of this Section contains photographs of the project area. The location and orientation of these photographs are indicated on the Contract Drawings.

1.3.3 Subsurface Conditions

Test pit logs, indicating the subsurface conditions and the depths at which boulders and massive rock were encountered in the vicinity of the proposed work are included on the Contract Drawings. Piezometer installation logs for two existing piezometers located in the vicinity of the proposed work, which provide additional information regarding the subsurface conditions and the depths at which boulders and massive rock were encountered, are included as Plates 5 and 6 of this Section. The corresponding test pit and piezometer locations are indicated on the Contract Drawings. These data represent the best subsurface information available in the vicinity of the proposed construction; however, variations may exist in the subsurface between test pit and piezometer locations.

1.3.4 Protection of Existing Piezometers

Existing piezometers located in the vicinity of the proposed work are indicated on the Contract Drawings. No land disturbing activities shall be performed within ten feet of the existing piezometers. Piezometers damaged or destroyed by the Contractor shall be replaced, to the satisfaction of the Contracting Officer, at the sole expense of the Contractor, prior to completion of the project.

PART 2 PRODUCTS (Not Applicable)

PART 3 EXECUTION (Not Applicable)
-- End of Section --



Photo #1



Photo #2



Photo #3



Photo #4

PLATE 1 SITE PHOTOGRAPHS Lehigh River Basin Lehigh River, PA Seepage Weir 3A Relocation	Date: 14 AUGUST 2000	Page: 1 of 6
	Reviewed By: DSS	
	Contract Number: DACW61 -02-B-0029	
	U.S. Army Engineer Division Corps of Engineers Philadelphia, Pennsylvania	



Photo #5



Photo #6



Photo #7



Photo #8

<p>PLATE 2 SITE PHOTOGRAPHS</p> <p>Lehigh River Basin Lehigh River, PA F.E. Walter Dam Seepage Weir 3A Relocation</p>	Date: 14 AUGUST 2000	Page: 2 of 6
	Reviewed By: DSS	
	Contract Number: DACW61-02-B-0029	
<p>U.S. Army Engineer Division Corps of Engineers Philadelphia, Pennsylvania</p>		



Photo #9



Photo #10



Photo #11



Photo #12

PLATE 3 SITE PHOTOGRAPHS Lehigh River Basin Lehigh River, PA F.E Walter Dam Seepage Weir 3A Relocation	Date: 14 AUGUST 2000	Page: 3 of 6
	Reviewed By: DSS	
	Contract Number: DACW61-02-B-0029	
	U.S. Army Engineer Division Corps of Engineers Philadelphia, Pennsylvania	



Photo #13



Photo #14

<p>PLATE 4 SITE PHOTOGRAPHS</p> <p>Lehigh River Basin Lehigh River, PA F.E. Walter Dam Seepage Weir 3A Relocation</p>	Date: 14 AUGUST 2000	Page: 4 of 6
	Reviewed By: DSS	
	Contract Number: DACW61-02-B-0029	
	<p>U.S. Army Engineer Division Corps of Engineers Philadelphia, Pennsylvania</p>	

DRILLING LOG			NAD	PDO	OF 2 SHEETS	
1. PROJECT F.E. WALTER (Piezometers)			10. SIZE AND TYPE OF BIT <i>4" R Series N&M</i>			
2. LOCATION (Coordinates or Station) E 2558440 N 653485			11. DATUM FOR ELEVATION SHOW (TBM or B.M.) M.S.L.			
3. DRILLING AGENCY Mobile District			12. MANUFACTURER'S DESIGNATION OF DRILL Failing 42 SA (modified)			
4. HOLE NO. (As shown on drawing title) and file number LWL-107H			13. TOTAL NO. OF OVERBURDEN SAMPLES TAKEN 0			
5. NAME OF DRILLER R.C. Roberts			14. TOTAL NUMBER CORE BOXES 1			
6. DIRECTION OF HOLE <input checked="" type="checkbox"/> VERTICAL <input type="checkbox"/> INCLINED <i>110° FROM VERT.</i>			15. ELEVATION GROUND WATER 1238.1			
7. THICKNESS OF OVERBURDEN 5.7			16. DATE HOLE STARTED 10-15-69 COMPLETED 10-28-69			
8. DEPTH DRILLED INTO ROCK 5.7			17. ELEVATION TOP OF HOLE 1263.0			
9. TOTAL DEPTH OF HOLE 63.4			18. TOTAL CORE RECOVERY FOR WORKING %			
			19. SIGNATURE OF INSPECTOR E. Cole			
ELEVATION	DEPTH	LEGEND	CLASSIFICATION OF MATERIALS (Description)	% CORE RECOVERY	LOG OR SAMPLE NO.	REMARKS (Drilling time, water loss, depth of penetration, etc., if significant)
0			COBBLES, med-gr quartzitic	50%	3.2'	Hole located in Down stream Fill Area using 6" core BBL - lost 150" Gyle Mud - lost 200" Bentonite using 425% Core BBL Cobble appear to be part of Boulders
5			COBBLES to 0.6'	20%	4.2'	
			Coarse GRAVEL & COBBLES to .6'	20%		
10			COBBLES to .4"	70%	10.6'	
			BOULDER 9 1/2" Quartzite Conglomerate	40%	15.1'	
15			(2) lg. quartzite BOULDERS .85 x 1.0'	40%		
				200'	20.0'	
			BOULDER 1.05' long and COBBLES to 0.5'	75%	24.1'	
			(2) pieces of C-GRAVEL and COBBLES to .35	30%	26.0'	
25			Bry, coarse, rounded GRAVEL	30%	22.0'	
			BOULDERS & COBBLES		29.8'	lost used rock bit rough drilling used R-series core barrel
30			Med-gr, hard quartzitic sandstone BOULDERS	55%	24.5'	
35			COBBLES & GRAVEL	30%	26.7'	
			COBBLES		38.0'	rock bit rough drilling
40				50%	31.0'	
			COBBLES to 0.7' lg. quartzite	40%	44.8'	Note: Loss of All drilling fluids was a continuing occurrence from Top to Bottom of hole
45				55%	42.1'	
				20%	44.7'	

<p>PLATE 5 PIEZOMETER INSTALLATION LOGS</p> <p>Lehigh River Basin Lehigh River, PA F.E. Walter Dam Seepage Weir 3A Relocation</p>	Date: 14 AUGUST 2000	Page: 5 of 6
	Reviewed By: DSS	
	Contract Number: DACW61-02-B-0029	
<p>U.S. Army Engineer Division Corps of Engineers Philadelphia, Pennsylvania</p>		

DRILLING LOG				OF 2 SHEETS		
1. PROJECT <i>F.E. WALTER (Piezometers)</i>			10. SIZE AND TYPE OF BIT			
2. LOCATION (Coordinate or Station)			11. DAY(S) FOR ELEVATION SHOWN (TBM or BSL)			
3. DRILLING AGENCY			12. MANUFACTURER'S DESIGNATION OF DRILL			
4. HOLE NO. (As shown on drawing etc. and its location) <i>LWL-10 E11</i>			13. TOTAL NO. OF CORE BOXES TAKEN			
5. NAME OF DRILLER			14. TOTAL NUMBER CORE BOXES			
6. DIRECTION OF HOLE <input type="checkbox"/> VERTICAL <input type="checkbox"/> INCLINED _____ DEG. FROM VERT.			15. ELEVATION GROUND WATER			
7. THICKNESS OF OVERBURDEN			16. DATE HOLE STARTED			
8. DEPTH DRILLED INTO ROCK			17. ELEVATION TOP OF HOLE			
9. TOTAL DEPTH OF HOLE			18. TOTAL CORE RECOVERY FOR BORING			
			19. SIGNATURE OF INSPECTOR			
ELEVATION a	DEPTH b	LEGEND c	CLASSIFICATION OF MATERIALS (Description) d	% CORE RECOVERY e	BOX OR SAMPLE NO. f	REMARKS (Including lith, water level, depth of overburden, etc., if appropriate) g
50			COBBLES, Multicolored Sandstone & Quartzite to .8" in size	75% 53.7'	51a'	
			Coarse subrad. GRAVEL & Sandstone COBBLES	20% 53.2'	52'	
55			Top of Rock	15% 53.0'	53a'	core Bbl. dropped from 52.5' to 52.0'
			SANDSTONE-Quartzitic, gray massive, v. hard, med. jointed w/ horizontal & vertical jts	53.6'	53.6'	lost water return @ 56.8' to completion of hole
60			Fragmental w/ brown clay from 60.1 to 63.4' L.R. 200	100% 45% 60.1'	60.1'	
				29% 63.4'	63.4'	
65			Bottom of Hole 63.4'			
70						

PLATE 6 PIEZOMETER INSTALLATION LOGS Lehigh River Basin Lehigh River, PA F.E. Walter Dam Seepage Weir 3A Relocation	Date: 14 AUGUST 2000	Page: 6 of 6
	Reviewed By: DSS	
	Contract Number: DACW61-02-B-0029	
	U.S. Army Engineer Division Corps of Engineers Philadelphia, Pennsylvania	

SECTION 01060

SAFETY

PART 1 GENERAL

1.1 SCOPE OF SECTION

The work specified in this section includes the development and enforcement of a safety and accident prevention program.

1.2 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by basic designation only.

U.S. ARMY CORPS OF ENGINEERS (USACE)

EM 385-1-1 (Latest Rev.) U.S. Army Corps of Engineers
Safety and Health Requirements Manual

NOTE: EM 385-1-1 and its changes are available at
<http://www.hq.usace.army.mil/soh/EM385/385TOC.htm>. The Contractor shall be responsible for complying with the current edition and all changes posted on the web as of the effective date of this solicitation.

U.S. ARMY CORPS OF ENGINEERS (PHILADELPHIA DISTRICT)

Liberty from Accidents Program (1996) Philadelphia District Awards
Program

1.3 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by, the office indicated prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved or reviewed by, the office indicated prior to commencing the particular task to which the submittal is associated.

SD-01 Preconstruction Submittals

Qualifications; G,DO.

Name and qualifications of the Contractor's proposed safety representative.

Accident Prevention Plan; G,DO.

An accident prevention plan, prepared by the prime Contractor for the specific work, implementing in detail the pertinent requirements of EM 385-1-1 shall be submitted for approval prior to the start of work. A

suggested format for the accident prevention plan is included in EM 385-1-1, Appendix A. The plan shall be prepared for all sites and shall include, but is not limited to, the topic areas listed in Appendix A therein and the requirements of the Paragraph entitled: SAFETY AND HEALTH PROVISIONS. Each topic shall be developed in a concise manner to include management and operational aspects.

SD-07 Certificates

Activity Phase Hazard Analysis Plan; G,DO.

Prior to beginning each major phase of work, an activity hazard analysis (phase plan) shall be prepared by the Contractor for that phase of work and submitted for approval. The suggested format for the analysis is contained in Figure 1-1 of EM 385-1-1. A phase is defined as an operation involving a type of work presenting hazards not experienced in previous operations or where a new subcontractor or work crew is to perform work. The analysis shall address the hazards for each activity performed in the phase and shall present the procedures and safeguards necessary to eliminate the hazards or reduce the risk to an acceptable level.

Safety Meeting Reports.

Outline reports of all weekly and monthly safety meeting shall be submitted.

Accident Reports.

A written report for all accidents utilizing ENG FORM 3394 shall be submitted within 24 hours following such accidents.

OSHA 300 Log.

Contractor's OSHA 300 Log of Injuries shall be submitted monthly.

1.4 GENERAL

Worker safety is of paramount importance. The Contractor shall comply with the Contract Clause entitled: ACCIDENT PREVENTION, EM 385-1-1, the Philadelphia District's Liberty from Accidents Program, and all other requirements as specified herein.

PART 2 PRODUCTS (Not Applicable)

PART 3 EXECUTION

3.1 SAFETY PROGRAM

EM 385-1-1 and all subsequent revisions referred to in the Contract Clause entitled: ACCIDENT PREVENTION of this contract, are hereby supplemented as follows:

a. The Contractor shall designate an employee to be the safety representative who shall be responsible for safety matters and accident prevention activities. Such duties shall include: (1) assuring applicable safety requirements are incorporated in work methods and (2) inspecting the work to ensure that daily safety measures and instructions are implemented and documented. The proposed safety representative's name and qualifications shall be submitted in writing for approval by the Contracting Officer. This individual shall have prior experience as a

safety representative or be able to demonstrate familiarity and understanding of the safety requirements over a prescribed trial period. The safety representative shall have the authority to act on behalf of the Contractors general management to take whatever action is necessary to assure compliance with safety requirements. The safety representative is required to be on the site when work, of any kind, is being performed, unless otherwise approved by the COR.

b. Prior to commencement of any work at the job site, a preconstruction safety meeting will be held between the Contractor's safety representative and the Contracting Officer to discuss the Contractor's safety program and to review the Accident Prevention Plan and Activity Phase Hazard Analysis Plan for the first phase of work.

c. Subsequent jobsite safety meetings shall be held as follows:

(1) A safety meeting shall be held at least once a month, documented by the safety representative, with subject and attendees, for all supervisors on the project to review past activities, to plan ahead for new or changed operations and to establish safe working procedures to anticipated hazards. An outline report of each monthly meeting shall be submitted to the Contracting Officer.

(2) At least one safety meeting shall be conducted weekly, or whenever new crews begin work, by the appropriate field supervisors or foremen for all workers. An outline report of the meeting giving date, time, attendance, subjects discussed and who conducted the meeting shall be prepared and furnished to the Contracting Officer.

3.2 PHILADELPHIA DISTRICT LIBERTY FROM ACCIDENTS PROGRAM

The Philadelphia District Liberty from Accidents Program is hereby incorporated as part of these specifications. The Liberty from Accidents Program rewards Contractors who exceed safety standards. The program provides local and District-wide awards on a quarterly and annual basis.

a. The Contractor will be evaluated for awards and the final performance evaluation in safety on the frequency rate for the project. The frequency rate is calculated by the following equation: $\text{frequency} = (\text{number of lost time accidents} \times 200,000) \text{ divided by the number of man-hours for the project}$. The Contractor shall have a proactive safety plan as outlined in the Liberty from Accidents Program.

b. The Contractor evaluation procedure for the safety category shall be as follows:

RATING	CONTRACTOR FREQUENCY RATE
Outstanding	Less than or equal to 0.25.
Above Average	Greater than 0.25 but less than or equal to 0.75.
Satisfactory	Greater than 0.75 but less than or equal to 0.84.
Marginal	Greater than 0.84 but less than or equal to 1.95.
Unsatisfactory	Greater than 1.95.

Extenuating circumstances will be considered to change the safety rating in

limited situations.

3.3 ACCIDENTS

Chargeable lost time accidents are to be investigated by both the Contractor and the Contracting Officer.

3.3.1 Accident Reporting

EM 385-1-1 and the Contract Clause entitled: ACCIDENT PREVENTION are supplemented as follows: The prime Contractor shall report on ENG FORM 3394, provided by the Contracting Officer's Representative, all injuries to employees or to subcontractor employee, and all damage to property and/or equipment. Verbal notification of such accidents shall be made to the Contracting Officer within 8 hours of occurrence. A written report utilizing ENG FORM 3394 shall be submitted to the Contracting Officer within 24 hours following such accidents. The report shall include the following:

a. A description of the circumstances leading up to the accident, the cause of the accident, and corrective measures taken to prevent recurrence.

b. A description of the injury and name and location of the medical facility rendering examination and treatment.

c. A statement as to whether or not the employee was permitted to return to work after examination and treatment by the medical facility, and if not, an estimate or statement of the number of days lost from work. If there have been days lost from work, the employee must be re-examined and declared fit to resume work as of the date of the report.

3.4 OSHA REQUIREMENTS

3.4.1 OSHA 300 Log

A copy of the Contractor's OSHA 300 Log of Injuries shall be submitted in accordance with the Paragraph entitled: SUBMITTALS.

3.4.2 OSHA Inspections

The Contractor shall immediately notify the Contracting Officer when an OSHA Compliance Official (Federal or State representative) presents credentials and informs the Contractor that the workplace will be inspected for OSHA compliance. The Contractor shall also notify the Contracting Officer upon determination that an exit interview will take place upon completion of the OSHA inspection.

3.5 MEASUREMENT AND PAYMENT

No separate measurement or payment will be made for the work specified in this section and all costs in connection therewith shall be included in the costs of all the bid items.

-- End of Section --

SECTION 01320

CONSTRUCTION PHOTOGRAPHY

PART 1 GENERAL

1.1 SCOPE OF SECTION

The work specified in this section includes construction photographs consisting of prints and digital image files showing the pre-construction condition, post-construction condition, progress of work during the contract period, work methods, and equipment utilized.

1.2 REFERENCES (Not Applicable)

1.3 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

SD-07 Certificates

Photography Plan; G COR.

The Contractor shall submit for approval each month his photography plan, which shall include the following information: items to be photographed, locations, and the time the images are to be taken.

Pre-Construction Photographs.

Pre-Construction photographs and digital images shall be furnished to the Government within 10 calendar days of when they are taken. They shall be taken as close as possible to the beginning of the construction work. The Contractor shall provide 3-inch, 3-ring binders and plastic photo-holder pages which shall hold the size of photos submitted. The Contractor shall submit the digital images on a disc or CD.

Construction Photographs.

Construction photographs and digital images shall be furnished to the Government within 10 days of when they are taken throughout the contract period. The photos shall be submitted in plastic photo-holder pages as described above. The digital images shall be submitted on a disc or CD.

Post-Construction Photographs.

Post-Construction photographs and digital images shall be furnished to the Government within 10 calendar days of when they are taken. They shall be taken immediately after the end of the construction work. The photos shall be submitted in plastic photo-holder pages as described above. The digital images shall

be submitted on a disc or CD.

One set of photographs, and digital images, and identification information of the above required photographs, shall be sent to the Philadelphia District Office at the following address:

U.S. Army Corps of Engineers
Philadelphia District
Design Branch (CENAP-EC-DG)
Attn: Troy Cosgrove
Wanamaker Building
100 Penn Square East
Philadelphia, PA 19107-3390

1.4 QUALITY ASSURANCE

All photography shall be performed by a qualified, established commercial photographer.

1.5 GENERAL REQUIREMENTS

1.5.1 Prints

Prints shall be 8" x 10", color, on single weight paper with smooth surface, glossy finish. Identification information on back of each print shall include: name and location of project, item/action being photographed, General Contractor, orientation of view, date and time of exposure, and name and address of photographer.

1.5.2 Digital Images

Digital images shall be taken with a high quality digital camera using a minimum of 3,000,000 pixels. Images shall be identified by number and referenced to a printed listing containing the same identification information as used for the prints. The digital images may be furnished on 3-1/2 inch discs or compact disc (CD).

PART 2 PRODUCTS (Not Applicable)

PART 3 EXECUTION

3.1 PHOTOGRAPHY

A minimum of 15 photographs shall be taken during each phase of the contract period (Pre-Construction, Construction, Post-Construction). The Contractor shall submit color prints and accompanying digital images showing the work methods, equipment utilized, and the progress of work at the following times during the contract period:

a. Prior to commencement of work the Contractor shall photograph the existing conditions of the work site.

b. During the progress of the work, such as at the start and completion of the definable features of work. NOTE: All photography for documenting the "progress of work" shall be of actual, working personnel and equipment, depicting the work methods being utilized, taken during normal working hours.

c. After completion of the work the Contractor shall photograph the

site from the same locations used to determine the existing conditions prior to construction.

d. Special events throughout the contract period as directed by the Contracting Officer's Representative.

3.2 MEASUREMENT AND PAYMENT

No separate measurement or payment will be made for the work specified in this section and all costs in connection therewith shall be included in the costs of all the bid items.

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SECTION 01325

PROJECT SCHEDULE

PART 1 GENERAL

1.1 SCOPE OF SECTION

The work specified in this section includes the development and maintenance of a project schedule to be used to measure the progress of the work, to aid in evaluating time extensions, and to provide the basis of all progress payments.

1.2 REFERENCES

The publications listed below form a part of the specification to the extent referenced. The publications are referenced in the text by basic designation only.

ENGINEERING REGULATIONS (ER)

ER 1-1-11 (1995) Progress, Schedules, and Network Analysis Systems

1.3 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

SD-07 Certificates

Project Schedule; G,COR.

The project schedule, including all requirements as specified herein, shall be submitted within 15 calendar days after receipt by the Contractor of the notice to proceed.

PART 2 PRODUCTS (Not Applicable)

PART 3 EXECUTION

3.1 GENERAL REQUIREMENTS

Pursuant to the Contract Clause, SCHEDULE FOR CONSTRUCTION CONTRACTS, a Project Schedule as described below shall be prepared. The scheduling of construction shall be the responsibility of the Contractor. Contractor management personnel shall actively participate in its development. Subcontractors and suppliers working on the project shall also contribute in developing and maintaining an accurate Project Schedule. The approved Project Schedule shall be used to measure the progress of the work, to aid

in evaluating time extensions, and to provide the basis of all progress payments.

3.2 BASIS FOR PAYMENT

The schedule shall be the basis for measuring Contractor progress. Lack of an approved schedule or scheduling personnel will result in an inability of the Contracting Officer to evaluate Contractor's progress for the purposes of payment. Failure of the Contractor to provide all information, as specified below, shall result in the disapproval of the entire Project Schedule submission and the inability of the Contracting Officer to evaluate Contractor progress for payment purposes. In the case where Project Schedule revisions have been directed by the Contracting Officer and those revisions have not been included in the Project Schedule, the Contracting Officer may hold retainage up to the maximum allowed by contract, each payment period, until revisions to the Project Schedule have been made.

3.3 PROJECT SCHEDULE

The computer software system utilized by the Contractor to produce the Project Schedule shall be capable of providing all requirements of this specification. Failure of the Contractor to meet the requirements of this specification shall result in the disapproval of the schedule. Manual methods used to produce any required information shall require approval by the Contracting Officer.

3.3.1 Use of the Critical Path Method

The Critical Path Method (CPM) of network calculation shall be used to generate the Project Schedule. The Contractor shall provide the Project Schedule in the Precedence Diagram Method (PDM).

3.3.2 Level of Detail Required

The Project Schedule shall include an appropriate level of detail. Failure to develop or update the Project Schedule or provide data to the Contracting Officer at the appropriate level of detail, as specified by the Contracting Officer, shall result in the disapproval of the schedule. The Contracting Officer will use, but is not limited to, the following conditions to determine the appropriate level of detail to be used in the Project Schedule:

3.3.2.1 Activity Durations

Contractor submissions shall follow the direction of the Contracting Officer regarding reasonable activity durations. Reasonable durations are those that allow the progress of activities to be accurately determined between payment periods (usually less than 2 percent of all non-procurement activities' Original Durations are greater than 20 days).

3.3.2.2 Procurement Activities

Tasks related to the procurement of long lead materials or equipment shall be included as separate activities in the project schedule. Long lead materials and equipment are those materials that have a procurement cycle of over 90 days. Examples of procurement process activities include, but are not limited to: submittals, approvals, procurement, fabrication, and delivery.

3.3.2.3 Critical Activities

The following activities shall be listed as separate line activities on the Contractor's project schedule:

- a. Submission and approval of mechanical/electrical layout drawings.
- b. Submission and approval of O & M manuals.
- c. Submission and approval of as-built drawings.
- d. Submission and approval of 1354 data and installed equipment lists.
- e. Submission and approval of testing and air balance (TAB).
- f. Submission of TAB specialist design review report.
- g. Submission and approval of fire protection specialist.
- h. Submission and approval of testing and balancing of HVAC plus commissioning plans and data.
- i. Air and water balance dates.
- j. HVAC commissioning dates.
- k. Controls testing plan.
- l. Controls testing.
- m. Performance Verification testing.
- n. Other systems testing, if required.
- o. Prefinal inspection.
- p. Correction of punchlist from prefinal inspection.
- q. Final inspection.

3.3.2.4 Government Activities

Government and other agency activities that could impact progress shall be shown. These activities include, but are not limited to: approvals, inspections, utility tie-in, Government Furnished Equipment (GFE) and Notice to Proceed (NTP) for phasing requirements.

3.3.2.5 Responsibility

All activities shall be identified in the project schedule by the party responsible to perform the work. Responsibility includes, but is not limited to, the subcontracting firm, contractor work force, or government agency performing a given task. Activities shall not belong to more than one responsible party. The responsible party for each activity shall be identified by the Responsibility Code.

3.3.2.6 Work Areas

All activities shall be identified in the project schedule by the work area in which the activity occurs. Activities shall not be allowed to cover more than one work area. The work area of each activity shall be identified by the Work Area Code.

3.3.2.7 Modification or Claim Number

Any activity that is added or changed by contract modification or used to justify claimed time shall be identified by a mod or claim code that changed the activity. Activities shall not belong to more than one modification or claim item. The modification or claim number of each activity shall be identified by the Mod or Claim Number. Whenever possible, changes shall be added to the schedule by adding new activities. Existing activities shall not normally be changed to reflect modifications.

3.3.2.8 Bid Item

All activities shall be identified in the project schedule by the Bid Item to which the activity belongs. An activity shall not contain work in more than one bid item. The bid item for each appropriate activity shall be identified by the Bid Item Code.

3.3.2.9 Phase of Work

All activities shall be identified in the project schedule by the phases of work in which the activity occurs. Activities shall not contain work in more than one phase of work. The project phase of each activity shall be by the unique Phase of Work Code.

3.3.2.10 Category of Work

All Activities shall be identified in the project schedule according to the category of work which best describes the activity. Category of work refers, but is not limited, to the procurement chain of activities including such items as submittals, approvals, procurement, fabrication, delivery, installation, start-up, and testing. The category of work for each activity shall be identified by the Category of Work Code.

3.3.2.11 Feature of Work

All activities shall be identified in the project schedule according to the feature of work to which the activity belongs. Feature of work refers, but is not limited to, a work breakdown structure for the project. The feature of work for each activity shall be identified by the Feature of Work Code.

3.3.3 Scheduled Project Completion

The schedule interval shall extend from NTP to the contract completion date.

3.3.3.1 Project Start Date

The schedule shall start no earlier than the date on which the NTP was acknowledged. The Contractor shall include as the first activity in the project schedule an activity called "Start Project". The "Start Project" activity shall have an "ES" constraint date equal to the date that the NTP was acknowledged, and a zero day duration.

3.3.3.2 Constraint of Last Activity

Completion of the last activity in the schedule shall be constrained by the contract completion date. Calculation on project updates shall be such that if the early finish of the last activity falls after the contract completion date, then the float calculation shall reflect a negative float on the critical path. The Contractor shall include as the last activity in the project schedule an activity called "End Project". The "End Project" activity shall have an "LF" constraint date equal to the completion date for the project, and a zero day duration.

3.3.3.3 Early Project Completion

In the event the project schedule shows completion of the project prior to the contract completion date, the Contractor shall identify those activities that have been accelerated and/or those activities that are scheduled in parallel to support the Contractor's "early" completion. Contractor shall specifically address each of the activities noted in the narrative report at every project schedule update period to assist the Contracting Officer in evaluating the Contractor's ability to actually complete prior to the contract period.

3.3.4 Interim Completion Dates

Contractually specified interim completion dates shall also be constrained to show negative float if the early finish date of the last activity in that phase falls after the interim completion date.

3.3.4.1 Start Phase

The Contractor shall include as the first activity for a project phase an activity called "Start Phase X" where "X" refers to the phase of work. The "Start Phase X" activity shall have an "ES" constraint date equal to the date on which the NTP was acknowledged, and a zero day duration.

3.3.4.2 End Phase

The Contractor shall include as the last activity in a project phase an activity called "End Phase X" where "X" refers to the phase of work. The "End Phase X" activity shall have an "LF" constraint date equal to the completion date for the project, and a zero day duration.

3.3.4.3 Phase X

The Contractor shall include a hammock type activity for each project phase called "Phase X" where "X" refers to the phase of work. The "Phase X" activity shall be logically tied to the earliest and latest activities in the phase.

3.3.5 Default Progress Data Disallowed

Actual Start and Finish dates shall not be automatically updated by default mechanisms that may be included in CPM scheduling software systems. Actual Start and Finish dates on the CPM schedule shall match those dates provided from Contractor Quality Control Reports. Failure of the Contractor to document the Actual Start and Finish dates on the Daily Quality Control report for every in-progress or completed activity, and failure to ensure that the data contained on the Daily Quality Control reports is the sole basis for schedule updating shall result in the disapproval of the Contractor's schedule and the inability of the Contracting Officer to evaluate Contractor progress for payment purposes. Updating of the percent

complete and the remaining duration of any activity shall be independent functions. Program features which calculate one of these parameters from the other shall be disabled.

3.3.6 Out-of-Sequence Progress

Activities that have posted progress without all preceding logic being satisfied (Out-of-Sequence Progress) will be allowed only on a case-by-case approval of the Contracting Officer. The Contractor shall propose logic corrections to eliminate all out of sequence progress or justify not changing the sequencing for approval prior to submitting an updated project schedule.

3.3.7 Negative Lags

Lag durations contained in the project schedule shall not have a negative value.

3.4 PROJECT SCHEDULE SUBMISSIONS

The Contractor shall provide the submissions as described below. The data disk, reports, and network diagrams required for each submission are contained in paragraph SUBMISSION REQUIREMENTS.

3.4.1 Initial Project Schedule Submission

The Initial Project Schedule shall be submitted for approval within 15 calendar days after NTP. The schedule shall provide a reasonable sequence of activities which represent work through the entire project and shall be at a reasonable level of detail.

3.4.2 Periodic Schedule Updates

Based on the result of progress meetings, specified in "Periodic Progress Meetings," the Contractor shall submit periodic schedule updates. These submissions shall enable the Contracting Officer to assess Contractor's progress. If the Contractor fails or refuses to furnish the information and project schedule data, which in the judgement of the Contracting Officer or authorized representative is necessary for verifying the Contractor's progress, the Contractor shall be deemed not to have provided an estimate upon which progress payment may be made.

3.4.3 Standard Activity Coding Dictionary

The Contractor shall use the activity coding structure defined in the Standard Data Exchange Format (SDEF) in ER 1-1-11, Appendix A. This exact structure is mandatory, even if some fields are not used.

3.5 SUBMISSION REQUIREMENTS

The following items shall be submitted by the Contractor for the initial submission, and every periodic project schedule update throughout the life of the project:

3.5.1 Data Disks

Two data disks containing the project schedule shall be provided. Data on the disks shall adhere to the SDEF format specified in ER 1-1-11, Appendix A.

3.5.1.1 File Medium

Required data shall be submitted on 3.5 disks, formatted to hold 1.44 MB of data, under the MS-DOS Version 5. or 6.x, unless otherwise approved by the Contracting Officer.

3.5.1.2 Disk Label

A permanent exterior label shall be affixed to each disk submitted. The label shall indicate the type of schedule (Initial, Update, or Change), full contract number, project name, project location, data date, name and telephone number or person responsible for the schedule, and the MS-DOS version used to format the disk.

3.5.1.3 File Name

Each file submitted shall have a name related to either the schedule data date, project name, or contract number. The Contractor shall develop a naming convention that will ensure that the names of the files submitted are unique. The Contractor shall submit the file naming convention to the Contracting Officer for approval.

3.5.2 Narrative Report

A Narrative Report shall be provided with the , initial, and each update of the project schedule. This report shall be provided as the basis of the Contractor's progress payment request. The Narrative Report shall include: a description of activities along the 2 most critical paths, a description of current and anticipated problem areas or delaying factors and their impact, and an explanation of corrective actions taken or required to be taken. The narrative report is expected to relay to the Government, the Contractor's thorough analysis of the schedule output and its plans to compensate for any problems, either current or potential, which are revealed through that analysis.

3.5.3 Approved Changes Verification

Only project schedule changes that have been previously approved by the Contracting Officer shall be included in the schedule submission. The Narrative Report shall specifically reference, on an activity by activity basis, all changes made since the previous period and relate each change to documented, approved schedule changes.

3.5.4 Schedule Reports

The format for each activity for the schedule reports listed below shall contain: Activity Numbers, Activity Description, Original Duration, Remaining Duration, Early Start Date, Early Finish Date, Late Start Date, Late Finish Date, Total Float. Actual Start and Actual Finish Dates shall be printed for those activities in progress or completed.

3.5.4.1 Activity Report

A list of all activities sorted according to activity number.

3.5.4.2 Logic Report

A list of Preceding and Succeeding activities for every activity in

ascending order by activity number. Preceding and succeeding activities shall include all information listed above in paragraph Schedule Reports. A blank line shall be left between each activity grouping.

3.5.4.3 Total Float Report

A list of all incomplete activities sorted in ascending order of total float. Activities which have the same amount of total float shall be listed in ascending order of Early Start Dates. Completed activities shall not be shown on this report.

3.5.4.4 Earnings Report

A compilation of the Contractor's Total Earnings on the project from the NTP until the most recent Monthly Progress Meeting. This report shall reflect the Earnings of specific activities based on the agreements made in the field and approved between the Contractor and Contracting Officer at the most recent Monthly Progress Meeting. Provided that the Contractor has provided a complete schedule update, this report shall serve as the basis of determining Contractor Payment. Activities shall be grouped by bid item and sorted by activity numbers. This report shall: sum all activities in a bid item and provide a bid item percent; and complete and sum all bid items to provide a total project percent complete. The printed report shall contain, for each activity: the Activity Number, Activity Description, Original Budgeted Amount, Total Quantity, Quantity to Date, Percent Complete (based on cost), and Earnings to Date.

3.5.5 Network Diagram

The network diagram shall be required on the initial schedule submission and on monthly schedule update submissions. The network diagram shall depict and display the order and interdependence of activities and the sequence in which the work is to be accomplished. The Contracting Officer will use, but is not limited to, the following conditions to review compliance with this paragraph:

3.5.5.1 Continuous Flow

Diagrams shall show a continuous flow from left to right with no arrows from right to left. The activity number, description, duration, and estimated earned value shall be shown on the diagram.

3.5.5.2 Project Milestone Dates

Dates shall be shown on the diagram for start of project, any contract required interim completion dates, and contract completion dates.

3.5.5.3 Critical Path

The critical path shall be clearly shown.

3.5.5.4 Banding

Activities shall be grouped to assist in the understanding of the activity sequence. Typically, this flow will group activities by category of work, work area and/or responsibility.

3.5.5.5 S-Curves

Earnings curves showing projected early and late earnings and earnings to date.

3.6 PERIODIC PROGRESS MEETINGS

Progress meetings to discuss payment shall include a monthly onsite meeting or other regular intervals mutually agreed to at the preconstruction conference. During this meeting the Contractor shall describe, on an activity by activity basis, all proposed revisions and adjustments to the project schedule required to reflect the current status of the project. The Contractor shall be responsible for recording and distributing minutes of these meetings. The Contracting Officer will approve activity progress, proposed revisions, and adjustments as appropriate.

3.6.1 Meeting Attendance

The Contractor's Project Manager and Scheduler shall attend the regular progress meeting.

3.6.2 Update Submission Following Progress Meeting

A complete update of the project schedule containing all approved progress, revisions, and adjustments, based on the regular progress meeting, shall be submitted not later than 4 working days after the monthly progress meeting.

3.6.3 Progress Meeting Contents

Update information, including Actual Start Dates, Actual Finish Dates, Remaining Durations, and Cost-to-Date shall be subject to the approval of the Contracting Officer. As a minimum, the Contractor shall address the following items on an activity by activity basis during each progress meeting.

3.6.3.1 Start and Finish Dates

The Actual Start and Actual Finish dates for each activity currently in-progress or completed .

3.6.3.2 Time Completion

The estimated Remaining Duration for each activity in-progress. Time-based progress calculations shall be based on Remaining Duration for each activity.

3.6.3.3 Cost Completion

The earnings for each activity started. Payment will be based on earnings for each in-progress or completed activity. Payment for individual activities will not be made for work that contains quality defects. A portion of the overall project amount may be retained based on delays of activities.

3.6.3.4 Logic Changes

All logic changes pertaining to NTP on change orders, change orders to be incorporated into the schedule, contractor proposed changes in work sequence, corrections to schedule logic for out-of-sequence progress, lag durations, and other changes that have been made pursuant to contract provisions shall be specifically identified and discussed.

3.6.3.5 Other Changes

Other changes required due to delays in completion of any activity or group of activities include: 1) delays beyond the Contractor's control, such as strikes and unusual weather. 2) delays encountered due to submittals, Government Activities, deliveries or work stoppages which make re-planning the work necessary. 3) Changes required to correct a schedule which does not represent the actual or planned prosecution and progress of the work.

3.7 REQUESTS FOR TIME EXTENSIONS

In the event the Contractor requests an extension of the contract completion date, or any interim milestone date, the Contractor shall furnish the following for a determination as to whether or not the Contractor is entitled to an extension of time under the provisions of the contract: justification, project schedule data, and supporting evidence as the Contracting Officer may deem necessary. Submission of proof of delay, based on revised activity logic, duration, and costs (updated to the specific date that the delay occurred) is obligatory to any approvals.

3.7.1 Justification of Delay

The project schedule shall clearly display that the Contractor has used, in full, all the float time available for the work involved with this request.

The Contracting Officer's determination as to the number of allowable days of contract extension shall be based upon the project schedule updates in effect for the time period in question, and other factual information. Actual delays that are found to be caused by the Contractor's own actions, which result in the extension of the schedule, will not be a cause for a time extension to the contract completion date.

3.7.2 Submission Requirements

The Contractor shall submit a justification for each request for a change in the contract completion date of under 2 weeks based upon the most recent schedule update at the time of the NTP or constructive direction issued for the change. Such a request shall be in accordance with the requirements of other appropriate Contract Clauses and shall include, as a minimum:

- a. A list of affected activities, with their associated project schedule activity number.
- b. A brief explanation of the causes of the change.
- c. An analysis of the overall impact of the changes proposed.
- d. A sub-network of the affected area.

Activities impacted in each justification for change shall be identified by a unique activity code contained in the required data file.

3.7.3 Additional Submission Requirements

For any requested time extension of over 2 weeks, the Contracting Officer may request an interim update with revised activities for a specific change request. The Contractor shall provide this disk within 4 days of the Contracting Officer's request.

3.8 DIRECTED CHANGES

If the NTP is issued for changes prior to settlement of price and/or time, the Contractor shall submit proposed schedule revisions to the Contracting Officer within 2 weeks of the NTP being issued. The proposed revisions to the schedule will be approved by the Contracting Officer prior to inclusion of those changes within the project schedule. If the Contractor fails to submit the proposed revisions, the Contracting Officer may furnish the Contractor with suggested revisions to the project schedule. The Contractor shall include these revisions in the project schedule until revisions are submitted, and final changes and impacts have been negotiated. If the Contractor has any objections to the revisions furnished by the Contracting Officer, the Contractor shall advise the Contracting Officer within 2 weeks of receipt of the revisions. Regardless of the objections, the Contractor shall continue to update the schedule with the Contracting Officer's revisions until a mutual agreement in the revisions is reached. If the Contractor fails to submit alternative revisions within 2 weeks of receipt of the Contracting Officer's proposed revisions, the Contractor will be deemed to have concurred with the Contracting Officer's proposed revisions. The proposed revisions will then be the basis for an equitable adjustment for performance of the work.

3.9 OWNERSHIP OF FLOAT

Float available in the schedule, at any time, shall not be considered for the exclusive use of either the Government or the Contractor.

3.10 MEASUREMENT AND PAYMENT

No separate measurement or payment will be made for the work specified in this section and all costs in connection therewith shall be included in the costs of all the bid items.

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SECTION 01330

SUBMITTAL PROCEDURES

PART 1 GENERAL

1.1 SCOPE OF SECTION

The work specified in this section includes the requirement to complete and maintain a submittal register and describes the procedures to be followed for the submission of submittals.

1.2 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

SD-07 Certificates

Review and Complete Submittal Register (ENG Form 4288); G,COR.

Update Submittal Register (ENG Form 4288); G,COR.

1.3 SUBMITTAL IDENTIFICATION (SD)

Submittals required are identified by SD numbers and titles as follows:

SD-01 Preconstruction Submittals

SD-02 Shop Drawings

SD-03 Product Data

SD-04 Samples

SD-05 Design Data

SD-06 Test Reports

SD-07 Certificates

SD-08 Manufacturer's Instructions

SD-09 Manufacturer's Field Reports

SD-10 Operation and Maintenance Data

SD-11 Closeout Submittals

1.4 SUBMITTAL CLASSIFICATION

Submittals are classified as follows:

1.4.1 Government Approved

Government approval is required for extensions of design, critical materials, deviations, equipment whose compatibility with the entire system must be checked, and other items as designated by the Contracting Officer. Within the terms of the Contract Clause entitled "Specifications and Drawings for Construction," they are considered to be "shop drawings."

1.4.2 Information Only

All submittals not requiring Government approval will be for information only. They are not considered to be "shop drawings" within the terms of the Contract Clause referred to above.

1.5 APPROVED SUBMITTALS

The Contracting Officer's approval of submittals shall not be construed as a complete check, but will indicate only that the general method of construction, materials, detailing and other information are satisfactory. Approval will not relieve the Contractor of the responsibility for any error which may exist, as the Contractor under the Contractor Quality Control (CQC) requirements of this contract is responsible for dimensions, the design of adequate connections and details, and the satisfactory construction of all work. After submittals have been approved by the Contracting Officer, no resubmittal for the purpose of substituting materials or equipment will be considered unless accompanied by an explanation of why a substitution is necessary.

1.6 DISAPPROVED SUBMITTALS

The Contractor shall make all corrections required by the Contracting Officer and promptly furnish a corrected submittal in the form and number of copies specified for the initial submittal. If the Contractor considers any correction indicated on the submittals to constitute a change to the contract, a notice in accordance with the Contract Clause "Changes" shall be given promptly to the Contracting Officer.

1.7 WITHHOLDING OF PAYMENT

Payment for materials incorporated in the work will not be made if required approvals have not been obtained.

1.8 GENERAL

The Contractor shall make submittals as required by the specifications. The Contracting Officer may request submittals in addition to those specified when deemed necessary to adequately describe the work covered in the respective sections. Units of weights and measures used on all submittals shall be the same as those used in the contract drawings. Each submittal shall be complete and in sufficient detail to allow ready determination of compliance with contract requirements. Prior to submittal, all items shall be checked and approved by the Contractor's Quality Control (CQC) System Manager and each item shall be stamped, signed, and dated by the CQC System Manager indicating action taken. Proposed deviations from the contract requirements shall be clearly identified. Submittals shall include items such as: Contractor's, manufacturer's, or fabricator's drawings; descriptive literature including (but not limited to) catalog cuts, diagrams, operating charts or curves; test reports; test cylinders; samples; O&M manuals (including parts list); certifications; warranties; and other such required submittals. Submittals requiring Government approval shall be scheduled and made prior to the

acquisition of the material or equipment covered thereby. Samples remaining upon completion of the work shall be picked up and disposed of in accordance with manufacturer's Material Safety Data Sheets (MSDS) and in compliance with existing laws and regulations.

1.9 SUBMITTAL REGISTER

At the end of this section is a submittal register showing items of equipment and materials for which submittals are required by the specifications; this list may not be all inclusive and additional submittals may be required. The Contractor shall update and submit the submittal register to the COR at least monthly.

1.10 SCHEDULING

Submittals covering component items forming a system or items that are interrelated shall be scheduled to be coordinated and submitted concurrently. Certifications to be submitted with the pertinent drawings shall be so scheduled. Adequate time (a minimum of 15 calendar days exclusive of mailing time) shall be allowed and shown on the register for review and approval. No delay damages or time extensions will be allowed for time lost in late submittals.

1.11 TRANSMITTAL FORM (ENG FORM 4025)

The sample transmittal form (ENG Form 4025) attached to this section shall be used for submitting both Government approved and information only submittals in accordance with the instructions on the reverse side of the form. This form shall be properly completed by filling out all the heading blank spaces and identifying each item submitted. Special care shall be exercised to ensure proper listing of the specification paragraph and/or sheet number of the contract drawings pertinent to the data submitted for each item. The Action Code definitions on reverse side of ENG FORM 4025 shall be augmented as follows:

Code B - Approved, except as noted on the submittal and/or attached sheet. Contractor shall complete all noted actions and address all comments prior to proceeding with those items of work associated with and impacted by the noted actions/comments.

Code C - Conditionally approved, except as noted on the submittal and/or attached sheet. Resubmission and approval are required prior to proceeding with those items of work associated with and impacted by the noted actions/comments. The entire submittal, corrected to comply with the noted actions/comments, must be resubmitted

1.12 SUBMITTAL PROCEDURE

Paragraph (g) of Contract Clause: "Specifications and Drawings for Construction," is modified as specified herein. While submittals referred to in the text may use the wording "submitted to the Contracting Officer", submittals will be reviewed as indicated in column "f" of the Submittal Register (ENG Form 4288). Submittals shall be made as follows:

1.12.1 Submittals for Contracting Officer Representative (COR) Review and For Information Only (FIO)

The Contractor shall submit seven copies of submittals, on the submittal register indicated for Contracting Officer Representative (COR) approval,

or, for information only (FIO), to the Contracting Officer Representative.

1.12.2 Submittals for District Office (DO) Review

The Contractor shall submit seven copies of submittals, on the submittal register indicated for the District Office (DO) approval, to the Contracting Officer Representative. The Contracting Officer Representative will forward the submittals to the District Office (DO) for review. Six copies will be submitted to the DO and one copy will be retained by the Contracting Officer Representative. The Government will be responsible for all costs incurred in transmitting these submittals.

1.12.3 Deviations

For submittals which include proposed deviations requested by the Contractor, the column "variation" of ENG Form 4025 shall be checked. The Contractor shall set forth in writing the reason for any deviations and annotate such deviations on the submittal. The Government reserves the right to rescind inadvertent approval of submittals containing unnoted deviations.

1.12.4 Completion of Work

Upon completing the work under this contract, the Contractor shall furnish one set of prints of all shop drawings as finally approved. These drawings shall show all changes and revisions made up to the time the items covered by the shop drawings are completed and accepted."

1.13 CONTROL OF SUBMITTALS

The Contractor shall carefully control his procurement operations to ensure that each individual submittal is made on or before the Contractor scheduled submittal date shown on the approved "Submittal Register."

1.14 GOVERNMENT APPROVED SUBMITTALS

Upon completion of review of submittals requiring Government approval, the submittals will be identified as having received approval by being so stamped and dated. Three copies of the submittal will be retained by the Contracting Officer and the remaining copies of the submittal will be returned to the Contractor.

1.15 INFORMATION ONLY SUBMITTALS

Normally submittals for information only will not be returned. Approval of the Contracting Officer is not required on information only submittals. The Government reserves the right to require the Contractor to resubmit any item found not to comply with the contract. This does not relieve the Contractor from the obligation to furnish material conforming to the plans and specifications; will not prevent the Contracting Officer from requiring removal and replacement of nonconforming material incorporated in the work; and does not relieve the Contractor of the requirement to furnish samples for testing by the Government laboratory or for check testing by the Government in those instances where the technical specifications so prescribe.

1.16 STAMPS

Stamps used by the Contractor on the submittal data to certify that the

submittal meets contract requirements shall be similar to the following:

CONTRACTOR (Firm Name)
 _____ Approved
 _____ Approved with corrections as noted on submittal data and/or attached sheets(s).
 SIGNATURE: _____
 TITLE: _____
 DATE: _____

PART 2 PRODUCTS

PART 3 EXECUTION

3.1 MEASUREMENT AND PAYMENT

No separate measurement or payment will be made for the work specified in this section and all costs in connection therewith shall be included in the costs of all the bid items.

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

INSTRUCTIONS

1. Section I will be initiated by the Contractor in the required number of copies.
2. Each transmittal shall be numbered consecutively in the space provided for "Transmittal No.". This number, in addition to the contract number, will form a serial number for identifying each submittal. For new submittals or resubmittals mark the appropriate box; on resubmittals, insert transmittal number of last submission as well as the new submittal number.
3. The "Item No." will be the same "Item No." as indicated on ENG FORM 4288 for each entry on this form.
4. Submittals requiring expeditious handling will be submitted on a separate form.
5. Separate transmittal form will be used for submittals under separate sections of the specifications.
6. A check shall be placed in the "Variation" column when a submittal is not in accordance with the plans and specifications --also, a written statement to that effect shall be included in the space provided for "Remarks".
7. Form is self-transmittal, letter of transmittal is not required.
8. When a sample of material or Manufacturer's Certificate of Compliance is transmitted, indicate "Sample" or "Certificate" in column c, Section I.
9. U.S. Army Corps of Engineers approving authority will assign action codes as indicated below in space provided in Section I, column i to each item submitted. In addition they will ensure enclosures are indicated and attached to the form prior to return to the contractor. The Contractor will assign action codes as indicated below in Section I, column g, to each item submitted.

THE FOLLOWING ACTION CODES ARE GIVEN TO ITEMS SUBMITTED

- | | |
|---|--|
| A -- Approved as submitted. | E -- Disapproved (See attached). |
| B -- Approved, except as noted on drawings. | F -- Receipt acknowledged. |
| C -- Approved, except as noted on drawings. | FX -- Receipt acknowledged, does not comply as noted with contract requirements. |
| Refer to attached sheet resubmission required. | G -- Other (<i>Specify</i>) |
| D -- Will be returned by separate correspondence. | |
10. Approval of items does not relieve the contractor from complying with all the requirements of the contract plans and specifications.

SUBMITTAL REGISTER

CONTRACT NO.

TITLE AND LOCATION
F.E. Walter Dam Seepage Weir 3A Modification

CONTRACTOR

ACTIVITY NO	TRANSMITTAL NO	SPEC SECT	DESCRIPTION ITEM SUBMITTED	PARAGRAPH	GOVT CLASSIFICATION REVIEW	CONTRACTOR: SCHEDULE DATES			CONTRACTOR ACTION		APPROVING AUTHORITY				MAILED TO CONTR/ DATE RCD FRM APPR AUTH	REMARKS	
						SUBMIT	APPROVAL NEEDED BY	MATERIAL NEEDED BY	ACTION CODE	DATE OF ACTION	DATE FWD TO APPR AUTH/ DATE RCD FROM CONTR	DATE FWD TO OTHER REVIEWER	DATE RCD FROM OTH REVIEWER	ACTION CODE			DATE OF ACTION
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
		00700	SD-01 Preconstruction Submittals														
			Payroll Basic Records & Statements of Compliance		G COR												
			Affirmative Action Compliance Plan		G COR												
			Certificate of Insurance		G DO												
		01060	SD-01 Preconstruction Submittals														
			Qualifications		G DO												
			Accident Prevention Plan		G DO												
			SD-07 Certificates														
			Activity Phase Hazard Analysis Plan		G DO												
			Safety Meeting Reports		FIO												
			Accident Reports		FIO												
			OSHA 300 Log		FIO												
		01320	SD-07 Certificates														
			Photography Plan		G COR												
			Pre-Construction Photographs		FIO												
			Construction Photographs		FIO												
			Post-Construction Photographs		FIO												
		01325	SD-07 Certificates														
			Project Schedule		G COR												
		01330	SD-07 Certificates														
			Review and Complete Submittal Register (ENG Form 4288)		G COR												

SUBMITTAL REGISTER

CONTRACT NO.

TITLE AND LOCATION F.E. Walter Dam Seepage Weir 3A Modification						CONTRACTOR											
ACTIVITY NO	TRANSMITTAL NO	SPEC SECT	DESCRIPTION ITEM SUBMITTED	PARAGRAPH #	GOVT CLASSIFICATION REVW	CONTRACTOR: SCHEDULE DATES			CONTRACTOR ACTION		APPROVING AUTHORITY				MAILED TO CONTR/ DATE RCD FRM APPR AUTH	REMARKS	
						SUBMIT	APPROVAL NEEDED BY	MATERIAL NEEDED BY	ACTION CODE	DATE OF ACTION	DATE FWD TO APPR AUTH/ DATE RCD FROM CONTR	DATE FWD TO OTHER REVIEWER	DATE RCD FROM OTH REVIEWER	ACTION CODE			DATE OF ACTION
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
		01330	Update Submittal Register (ENG Form 4288)		G COR												
		01355	SD-01 Preconstruction Submittals														
			Location of Storage Facilities		G COR												
			SD-07 Certificates														
			Environmental Protection Plan		G COR												
			Soil Erosion and Sediment Control Plan		G COR												
			Landfill		G COR												
		01450	SD-07 Certificates														
			Quality Control Plan		G COR												
			Qualifications		G COR												
			Changes to Quality Control Plan		G COR												
			Daily CQC Report		G COR												
			Preparatory, Initial, and Final Phase Meeting Minutes		G COR												
		01500	SD-01 Preconstruction Submittals														
			Temporary Facilities Plan		G COR												
		01720	SD-06 Test Reports														
			Surveying Procedures and Equipment		G DO												
			SD-07 Certificates														
			Qualifications		G DO												
		01780	SD-07 Certificates														
			Progress Prints		G COR												
			SD-11 Closeout Submittals														

SUBMITTAL REGISTER

CONTRACT NO.

TITLE AND LOCATION
F.E. Walter Dam Seepage Weir 3A Modification

CONTRACTOR

ACTIVITY NO	TRANSMITTAL NO	SPEC SECT	DESCRIPTION ITEM SUBMITTED	PARAGRAPH	GOVT CLASSIFICATION REVIEWER	CONTRACTOR: SCHEDULE DATES			CONTRACTOR ACTION		APPROVING AUTHORITY				MAILED TO CONTR/ DATE RCD FRM APPR AUTH	REMARKS	
						SUBMIT	APPROVAL NEEDED BY	MATERIAL NEEDED BY	ACTION CODE	DATE OF ACTION	DATE FWD TO APPR AUTH/ DATE RCD FROM CONTR	DATE FWD TO OTHER REVIEWER	DATE RCD FROM OTH REVIEWER	ACTION CODE			DATE OF ACTION
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
		01780	As-Built Drawings		G COR												
		02271	SD-03 Product Data														
			Sources for Stone Riprap		G DO												
			Gradation Curves		G DO												
			SD-07 Certificates														
			Stone Riprap Work Plan		G DO												
		02300	SD-01 Preconstruction Submittals														
			Sources for Cutoff Trench Backfill		G DO												
			Trench Backfill Gradation Curves		G DO												
			Sources for Roadway Crushed Stone		G DO												
			Roadway Crushed Stone Gradation Curves		G DO												
			Cutoff Trench Construction and GCL Installation Work Plan		G DO												
			Drainage and Dewatering Work Plan		G DO												
			Access Improvement Plan		G DO												
			SD-06 Test Reports														
			Testing Results		G COR												
			SD-07 Certificates														
			Testing Laboratory Qualifications		G COR												
		02378	SD-03 Product Data														
			GCL Properties		G DO												
			GCL Warranty		FIO												
			SD-04 Samples														

SUBMITTAL REGISTER

CONTRACT NO.

TITLE AND LOCATION F.E. Walter Dam Seepage Weir 3A Modification						CONTRACTOR											
ACTIVITY NO	TRANSMITTAL NO	SPEC SECT	DESCRIPTION ITEM SUBMITTED	PARAGRAPH	GOVT CLASSIFICATION	CONTRACTOR: SCHEDULE DATES			CONTRACTOR ACTION		APPROVING AUTHORITY				MAILED TO CONTR/ DATE RCD FRM APPR AUTH	REMARKS	
						SUBMIT	APPROVAL NEEDED BY	MATERIAL NEEDED BY	ACTION CODE	DATE OF ACTION	DATE FWD TO APPR AUTH/ DATE RCD FROM CONTR	DATE FWD TO OTHER REVIEWER	DATE RCD FROM OTH REVIEWER	ACTION CODE			DATE OF ACTION
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
		02378	Geotextile		G DO												
			SD-06 Test Reports														
			GCL Conformance Tests		G DO												
			SD-07 Certificates														
			Geotextile		G DO												
		02921	SD-01 Preconstruction Submittals														
			Equipment		FIO												
			SD-03 Product Data														
			Equipment		FIO												
			Chemical Treatment Material		FIO												
			SD-06 Test Reports														
			Equipment Calibration		FIO												
			SD-07 Certificates														
			Seed		G COR												
			Fertilizer		G COR												
			SD-11 Closeout Submittals														
			Quantity Check		FIO												
			Maintenance Record		FIO												
		03101	SD-02 Shop Drawings														
			Shop Drawings		G COR												
			SD-03 Product Data														
			Materials		FIO												
			SD-06 Test Reports														
			Inspection		FIO												
			Formwork Not Supporting the Weight of Concrete		G COR												

SUBMITTAL REGISTER

CONTRACT NO.

TITLE AND LOCATION F.E. Walter Dam Seepage Weir 3A Modification						CONTRACTOR											
ACTIVITY NO	TRANSMITTAL NO	SPEC SECT	DESCRIPTION ITEM SUBMITTED	PARAGRAPH	GOVT CLASSIFICATION REVIEWER	CONTRACTOR: SCHEDULE DATES			CONTRACTOR ACTION		APPROVING AUTHORITY					MAILED TO CONTR/ DATE RCD FRM APPR AUTH	REMARKS
						SUBMIT	APPROVAL NEEDED BY	MATERIAL NEEDED BY	ACTION CODE	DATE OF ACTION	DATE FWD TO APPR AUTH/ DATE RCD FROM CONTR	DATE FWD TO OTHER REVIEWER	DATE RCD FROM OTH REVIEWER	ACTION CODE	DATE OF ACTION		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
		03201	SD-02 Shop Drawings Fabrication and Placement		G COR												
			SD-06 Test Reports Materials Tests, Inspections, and Verifications		G DO												
			SD-11 Closeout Submittals Material		G CO												
		03307	SD-03 Product Data Air-Entraining Admixture		G DO												
			Curing Materials		G DO												
			Batching and Mixing Equipment		G COR												
			Conveying and Placing Concrete		G COR												
			SD-06 Test Reports Aggregates		G DO												
			Concrete Mixture Proportions	1.2.3	G DO												
			Testing Results		G COR												
			SD-07 Certificates Cementitious Materials		G COR												
		10050	SD-02 Shop Drawings Shop Drawings		G DO												
			SD-03 Product Data Injection Adhesive Anchors		G DO												

This page was intentionally left blank for duplex printing.

SECTION 01355

ENVIRONMENTAL PROTECTION

PART 1 GENERAL

1.1 SCOPE OF SECTION

This section covers the furnishing of all labor, material and equipment and performing all work required for the protection of the environment during construction operations except for those measures set forth in other sections of these specifications.

1.2 REFERENCES (Not Applicable)

1.3 DEFINITION OF ENVIRONMENTAL PROTECTION

For the purpose of this specification, environmental protection is defined as the retention of the environment in its natural state to the greatest extent possible during project construction and to enhance the natural appearance in its final condition. Environmental protection requires consideration of air, water, and land resources and involves noise, solid waste-management and management of other pollutants. In order to prevent, and to provide for abatement and control of any environmental pollution arising from the construction activities in performance of this contract, the Contractor and his subcontractors shall comply with all applicable Federal, state, and local laws and regulations and shall obtain all necessary permits required by same.

1.4 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by, the office indicated prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved or reviewed by, the office indicated prior to commencing the particular task to which the submittal is associated.

SD-01 Preconstruction Submittals

Location of Storage Facilities; G,COR.

Plans showing storage and other construction facilities shall be submitted for approval of the Contracting Officer.

SD-07 Certificates

Environmental Protection Plan; G,COR.

Prior to commencement of the work, the Contractor shall submit to

the Contracting Officer for approval his proposed environmental protection plan. This shall be followed by a meeting with representatives of the Contracting Officer to develop mutual understandings relative to compliance with this provision and administration of the environmental protection program. Approval of the Contractor's plan for environmental protection will not relieve the Contractor of his responsibility for adequate and continuing control of pollutants.

Soil Erosion and Sediment Control Plan; G,COR.

The Contractor shall prepare and submit to the Carbon County Soil Conservation District for certification, a Soil Erosion and Sediment Control Plan. Three copies of the approved Soil Erosion and Sediment Control Plan shall be submitted to the Contracting Officer prior to the commencement of work.

Landfill; G,COR.

The Contractor shall furnish a copy of the letter of permission from any landfill to be used for the disposal of excavated materials or debris from the project site. The letter shall include any special handling required by the landfill for disposal of "special" materials.

1.5 NOTIFICATION

The Contracting Officer will notify the Contractor in writing of any non-compliance with the aforementioned Federal, state, or local laws or regulations. Such notice, when delivered to the Contractor or his authorized representative at the site of the work, shall be deemed sufficient for the purpose. The Contractor shall, after receipt of such notice, immediately inform the Contracting Officer of proposed corrective action and take such action as may be approved. If the Contractor fails or refuses to comply promptly, the Contracting Officer may issue an order stopping all or part of the work until satisfactory corrective action has been taken. No part of the time lost due to any such stop orders shall be made subject of a claim for extension of time or for excess costs or damages by the Contractor.

1.6 SUBCONTRACTORS

Compliance with the provisions of this section by subcontractors will be the responsibility of the Contractor.

PART 2 PRODUCTS (Not Applicable)

PART 3 EXECUTION

3.1 PROTECTION OF LAND RESOURCES

3.1.1 General

The land resources within the project boundaries and outside the limits of permanent work performed under this contract shall be preserved in their present condition or be restored to a condition after completion of construction that will appear to be natural and not detract from the appearance of the project. The Contractor shall confine his construction

activities to areas defined by the plans and specifications. The following additional requirements are intended to supplement the requirements of the Contract Clauses.

3.1.2 Prevention of Landscape Defacement

Except in areas indicated on the plans or specified to be cleared, the Contractor shall not deface, injure, or destroy trees or shrubs, nor remove or cut them without the authority of the Contracting Officer. Ropes, cables, or guys shall not be fastened to or attached to any existing nearby trees for anchorages unless specifically authorized. Where such special emergency use is permitted, it shall be performed in such a manner as to avoid damage to the trees. The Contractor shall in any event be responsible for any damage resulting from such use. Where the possibility exists that trees may be defaced, bruised, injured, or otherwise damaged by the Contractor's equipment or operations, the Contractor shall adequately protect such trees. Stone, earth or other material that is displaced into uncleared areas shall be removed. Monuments and markers shall be protected before construction operations commence.

3.1.3 Restoration of Landscape Damage

Any tree, turfed areas or other landscape feature scarred or damaged by the Contractor's equipment or operations shall be restored to a condition satisfactory to the Contracting Officer. Restoration of scarred and damaged trees shall be performed in an approved manner by experienced workmen. Trees damaged beyond restoration shall be removed and disposed of under requirements for excavation. Trees that are to be removed because of damage shall be replaced at the Contractor's expense by nursery-grown trees of the same species or a species approved by the Contracting Officer. The size and quality of nursery-grown trees shall also be approved by the Contracting Officer. Any disturbed turfed (grassed) areas shall be seeded and mulched as directed by the Contracting Officer.

3.1.4 Location of Storage Facilities

Contractor's storage and other construction buildings, which are required in the performance of the work, shall be located upon cleared portions of the job site and shall require the written approval of the Contracting Officer. The preservation of the landscape shall be an imperative consideration in the selection of all sites and in the construction of buildings. Where buildings or platforms are constructed on sidehills, the Contracting Officer may require cribbing to be used to obtain level foundations. Benching or leveling of earth may be permitted, depending on the location of the proposed facility.

3.1.5 Post Construction Cleanup or Obliteration

The Contractor shall obliterate all signs of temporary construction facilities, excess materials, or any other vestiges of construction as directed by the Contracting Officer. The area will be restored to near natural conditions which will permit the growth of vegetation thereon.

3.2 RECORDING AND PRESERVING HISTORICAL AND ARCHAEOLOGICAL FINDS

All items having any apparent historical or archaeological interest which are discovered in the course of any construction activities shall be carefully preserved. The Contractor shall leave the archaeological find undisturbed and shall immediately report the find to the Contracting

Officer so that proper authorities may be notified.

3.3 PROTECTION OF WATER RESOURCES

3.3.1 General

The Contractor shall not pollute any streams, rivers or waterways with fuels, oils, bitumens, calcium chloride, acids, insecticides, herbicides or other harmful materials. The Contractor shall investigate and comply with all applicable Federal, state, county, and municipal laws concerning pollution of rivers and streams.

3.3.2 Soil Erosion and Sediment Control

3.3.2.1 Soil Erosion and Sediment Control

The Contractor shall conduct his operations in conformance with his certified Soil Erosion and Sediment Control Plan. Surface drainage from cuts and fills within the limits of the work shall be held in suitable sedimentation ponds or shall be graded to control erosion within acceptable limits. Temporary erosion and sediment control measures shall be provided and maintained until the permanent work is completed and operative. The area of bare soil exposed at any given time by construction shall be restricted to a minimum. Fills and waste areas shall be constructed by selective placement of materials to eliminate silts or clays on the surface which may erode and contaminate the adjacent waterway. The Contractor shall comply with all applicable laws concerning soil erosion and sediment control.

3.3.2.2 General Soil Erosion and Sediment Control Requirements

Surface drainage from cuts and fills within the limits of the work shall be held in suitable sedimentation ponds or shall be graded to control erosion within acceptable limits. Temporary erosion and sediment control measures shall be provided and maintained until the permanent work is completed and operative. The area of bare soil exposed at any given time by construction shall be restricted to a minimum. Fills and waste areas shall be constructed by selective placement of materials to eliminate silts or clays on the surface which may erode and contaminate the adjacent waterway. The Contractor shall comply with all applicable laws concerning soil erosion and sediment control.

3.3.3 Disposal

Disposal of any debris resulting from the contract work and any wastes, effluents, trash, garbage, oil, grease, chemicals, etc., in or adjacent to the work area will not be permitted. If any waste material is dumped in unauthorized areas, the Contractor shall remove the material and restore the area to its original condition. If necessary, contaminated ground shall be excavated, disposed of as directed by the Contracting Officer, replaced with suitable fill material, compacted and finished with topsoil, and planted as required to reestablish vegetation.

3.4 PROTECTION OF FISH AND WILDLIFE

The Contractor shall at all times perform all work and take such steps required to minimize interference with or disturbance to fish and wildlife. The Contractor will not be permitted to alter water flows or otherwise disturb native habitat adjacent to the work area which, in the opinion of

the Contracting Officer, are critical to fish and wildlife.

3.5 DISPOSAL OF DEBRIS

All debris resulting from construction operations on this contract shall be removed from the work site and disposed of at the Contractor's expense. Such disposal shall comply with all applicable Federal, state, and local laws. Such materials shall be removed from the site of the work before the date of completion of the work under these specifications.

3.6 MAINTENANCE OF POLLUTION, EROSION AND SEDIMENTATION CONTROL FACILITIES DURING CONSTRUCTION

During the life of this contract, the Contractor shall maintain all facilities constructed for pollution, erosion and sedimentation control under this contract as long as the operations creating the particular pollutant are being carried out or until the material concerned has become stabilized to the extent that pollution is no longer being created. During the construction period, the Contractor shall conduct frequent training sessions on environmental protection. The curricula should include methods of detecting and avoiding pollution; familiarity with pollution standards, both statutory and contractual; and installation and care of vegetative covers, plants and other facilities to prevent and correct environmental pollution.

3.7 MEASUREMENT AND PAYMENT

The work specified in this section will not be measured separately for payment and all costs in connection therewith will be included in the cost of all the bid items.

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SECTION 01420

SOURCES FOR REFERENCE PUBLICATIONS

PART 1 GENERAL

1.1 REFERENCES

Various publications are referenced in other sections of the specifications to establish requirements for the work. These references are identified in each section by document number, date and title. The document number used in the citation is the number assigned by the standards producing organization, (e.g. ASTM B 564 Nickel Alloy Forgings). However, when the standards producing organization has not assigned a number to a document, an identifying number has been assigned for reference purposes.

1.2 ORDERING INFORMATION

The addresses of the standards publishing organizations whose documents are referenced in other sections of these specifications are listed below, and if the source of the publications is different from the address of the sponsoring organization, that information is also provided. Documents listed in the specifications with numbers which were not assigned by the standards producing organization should be ordered from the source by title rather than by number. The designations "AOK" and "LOK" are for administrative purposes and should not be used when ordering publications.

ACI INTERNATIONAL (ACI)
P.O. Box 9094
Farmington Hills, MI 48333-9094
Ph: 248-848-3700
Fax: 248-848-3701
Internet: <http://www.aci-int.org>
AOK 5/01
LOK 2/01

AMERICAN ASSOCIATION OF STATE HIGHWAY AND TRANSPORTATION OFFICIALS
(AASHTO)
444 N. Capital St., NW, Suite 249
Washington, DC 20001
Ph: 800-231-3475 202-624-5800
Fax: 800-525-5562 202-624-5806
Internet: <http://www.transportation.org>
AOK 5/01
LOK 2/01

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)
100 Barr Harbor Drive
West Conshohocken, PA 19428-2959
Ph: 610-832-9585
Fax: 610-832-9555
Internet: <http://www.astm.org>
AOK 5/01
LOK 3/01

AMERICAN WELDING SOCIETY (AWS)

550 N.W. LeJeune Road
Miami, FL 33126
Ph: 800-443-9353 - 305-443-9353
Fax: 305-443-7559
Internet: <http://www.amweld.org>
AOK 5/01
LOK 3/01

PENNSYLVANIA DEPARTMENT OF TRANSPORTATION (PennDOT)
Forum Place 555 Walnut Street
Harrisburg, PA 17101-1900
Internet: <http://www.dot.state.pa.us>

U.S. ARMY CORPS OF ENGINEERS (USACE)

Order CRD-C DOCUMENTS from:
U.S. Army Engineer Waterways Experiment Station
ATTN: Technical Report Distribution Section, Services
Branch, TIC
3909 Halls Ferry Rd.
Vicksburg, MS 39180-6199
Ph: 601-634-2664
Fax: 601-634-2388
Internet: <http://www.wes.army.mil/SL/MTC/handbook/handbook.htm>

Order Other Documents from:
USACE Publications Depot
Attn: CEIM-SP-D
2803 52nd Avenue
Hyattsville, MD 20781-1102
Ph: 301-394-0081
Fax: 301-394-0084
Internet: <http://www.usace.army.mil/publications>
or <http://www.hnd.usace.army.mil/techinfo/index.htm>
AOK 5/01
LOK 6/00

WESTERN WOOD PRESERVERS INSTITUTE (WWPI)
7017 N.E. Highway 99 # 108
Vancouver, WA 98665
Ph: 360-693-9958
Fax: 360-693-9967
Internet: <http://www.wwpinstitute.org>
e-mail: wwpi@teleport.com
AOK 5/01
LOK 6/00

WESTERN WOOD PRODUCTS ASSOCIATION (WWPA)
Yeon Bldg.
522 SW 5th Ave.
Suite 500
Portland, OR 97204-2122
Ph: 503-224-3930
Fax: 503-224-3934
Internet: <http://www.wwpa.org>
e-mail: info@wwpa.org
AOK 5/01
LOK 6/00

WINDOW AND DOOR MANUFACTURERS ASSOCIATION (WDMA)
1400 East Touhy Ave., Suite 470
Des Plaines, IL 60018
Ph: 847-299-5200 or 800-223-2301
Fax: 708-299-1286
Internet: <http://www.wdma.com>
e-mail: admin@wdma.com
AOK 5/01
LOK 6/00

WOOD MOULDING AND MILLWORK PRODUCERS ASSOCIATION (WMMPA)
507 First Street
Woodland, CA 95695
Ph: 916-661-9591
Fax: 916-661-9586
Internet: <http://www.wmmpa.com>
AOK 5/01
LOK 6/00

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SECTION 01450

CONTRACTOR QUALITY CONTROL

PART 1 GENERAL

1.1 SCOPE OF SECTION

The work specified in this section includes the development and implementation of a quality control program that consists of plans, procedures, and an organization necessary to produce an end product which complies with the contract requirements.

1.2 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by basic designation only.

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM D 3740	(2001) Minimum Requirements for Agencies Engaged in the Testing and/or Inspection of Soil and Rock as Used in Engineering Design and Construction
ASTM E 329	(2000b) Agencies Engaged in the Testing and/or Inspection of Materials Used in Construction

1.3 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

SD-07 Certificates

Quality Control Plan; G,COR.

Quality control plan shall be submitted not later than 10 days after receipt of notice to proceed, and prior to the start of work.

Qualifications; G,COR.

Qualifications of CQC System Manager, Alternate CQC System Manager, and other CQC Personnel indicated in "Experience Matrix."

Changes to Quality Control Plan; G,COR.

Contractor shall notify Contracting Officer, in writing, of any proposed change to the CQC Plan or personnel.

Daily CQC Report; G,COR.

Submitted within 24 hours after the date covered by the report.

Preparatory, Initial, and Final Phase Meeting Minutes; G,COR.

Minutes to be attached to the Daily Quality Control Report for the day of the meeting.

PART 2 PRODUCTS (Not Applicable)

PART 3 EXECUTION

3.1 GENERAL REQUIREMENTS

The Contractor is responsible for quality control and shall establish and maintain an effective quality control system in compliance with the Contract Clause titled "Inspection of Construction." The quality control system shall consist of plans, procedures, and organization necessary to produce an end product which complies with the contract requirements. The system shall cover all construction operations, both onsite and offsite, and shall be keyed to the proposed construction sequence. The site project superintendent will be held responsible for the quality of work on the job and is subject to removal by the Contracting Officer for non-compliance with the quality requirements specified in the contract. The site project superintendent in this context shall be the highest level manager responsible for the overall construction activities at the site, including quality and production. The site project superintendent shall maintain a physical presence at the site at all times, except as otherwise acceptable to the Contracting Officer, and shall be responsible for all construction and construction related activities at the site.

3.2 QUALITY CONTROL PLAN

The Contractor shall furnish for review by the Government, not later than 10 days after receipt of notice to proceed, the Contractor Quality Control (CQC) Plan proposed to implement the requirements of the Contract Clause titled "Inspection of Construction." The plan shall identify personnel, procedures, control, instructions, tests, records, and forms to be used. Construction will be permitted to begin only after acceptance of the CQC Plan or acceptance of an interim plan applicable to the particular feature of work to be started. Work outside of the features of work included in an accepted interim plan will not be permitted to begin until acceptance of a CQC Plan or another interim plan containing the additional features of work to be started.

3.2.1 Content of the CQC Plan

The CQC Plan shall include, as a minimum, the following to cover all construction operations, both onsite and offsite, including work by subcontractors, fabricators, suppliers, and purchasing agents:

- a. A description of the quality control organization, including a chart showing lines of authority and acknowledgment that the CQC staff shall implement the three phase control system for all aspects of the work specified. The staff shall include a CQC System Manager who shall report to the project superintendent.
- b. The name, qualifications (in resume format), duties, responsibilities, and authorities of each person assigned a CQC

function.

- c. A copy of the letter to the CQC System Manager signed by an authorized official of the firm which describes the responsibilities and delegates sufficient authorities to adequately perform the functions of the CQC System Manager, including authority to stop work which is not in compliance with the contract. The CQC System Manager shall issue letters of direction to all other various quality control representatives outlining duties, authorities, and responsibilities. Copies of these letters shall also be furnished to the Government.
- d. Procedures for scheduling, reviewing, certifying, and managing submittals, including those of subcontractors, offsite fabricators, suppliers, and purchasing agents. These procedures shall be in accordance with Section 01330 SUBMITTAL PROCEDURES.
- e. Control, verification, and acceptance testing procedures for each specific test to include the test name, specification paragraph requiring test, feature of work to be tested, test frequency, and person responsible for each test. (Laboratory facilities will be approved by the Contracting Officer.)
- f. Procedures for tracking preparatory, initial, and follow-up control phases and control, verification, and acceptance tests including documentation.
- g. Procedures for tracking construction deficiencies from identification through acceptable corrective action. These procedures shall establish verification that identified deficiencies have been corrected.
- h. Reporting procedures, including proposed reporting formats.
- i. A list of the definable features of work. A definable feature of work is a task which is separate and distinct from other tasks, has separate control requirements, and may be identified by different trades or disciplines, or it may be work by the same trade in a different environment. Although each section of the specifications may generally be considered as a definable feature of work, there are frequently more than one definable features under a particular section. This list will be agreed upon during the coordination meeting.

3.2.2 Acceptance of Plan

Acceptance of the Contractor's plan is required prior to the start of construction. Acceptance is conditional and will be predicated on satisfactory performance during the construction. The Government reserves the right to require the Contractor to make changes in his CQC Plan and operations including removal of personnel, as necessary, to obtain the quality specified.

3.2.3 Notification of Changes

After acceptance of the CQC Plan, the Contractor shall notify the Contracting Officer in writing of any proposed change. Proposed changes are subject to acceptance by the Contracting Officer.

3.3 COORDINATION MEETING

After the Preconstruction Conference, before start of construction, and prior to acceptance by the Government of the CQC Plan, the Contractor shall meet with the Contracting Officer or Authorized Representative and discuss the Contractor's quality control system. The CQC Plan shall be submitted for review a minimum of 7 calendar days prior to the Coordination Meeting. During the meeting, a mutual understanding of the system details shall be developed, including the forms for recording the CQC operations, control activities, testing, administration of the system for both onsite and offsite work, and the interrelationship of Contractor's Management and control with the Government's Quality Assurance. Minutes of the meeting shall be prepared by the Government and signed by both the Contractor and the Contracting Officer. The minutes shall become a part of the contract file. There may be occasions when subsequent conferences will be called by either party to reconfirm mutual understandings and/or address deficiencies in the CQC system or procedures which may require corrective action by the Contractor.

3.4 QUALITY CONTROL ORGANIZATION

3.4.1 Personnel Requirements

The requirements for the CQC organization are a CQC System Manager and sufficient number of additional qualified personnel to ensure safety and contract compliance. The Safety and Health Manager shall receive direction and authority from the CQC System Manager and shall serve as a member of the CQC staff. Personnel identified in the technical provisions as requiring specialized skills to assure the required work is being performed properly will also be included as part of the CQC organization. The Contractor's CQC staff shall maintain a presence at the site at all times during progress of the work and have complete authority and responsibility to take any action necessary to ensure contract compliance. The CQC staff shall be subject to acceptance by the Contracting Officer. The Contractor shall provide adequate office space, filing systems and other resources as necessary to maintain an effective and fully functional CQC organization. Complete records of all letters, material submittals, show drawing submittals, schedules and all other project documentation shall be promptly furnished to the CQC organization by the Contractor. The CQC organization shall be responsible to maintain these documents and records at the site at all times, except as otherwise acceptable to the Contracting Officer.

3.4.2 CQC System Manager

The Contractor shall identify as CQC System Manager an individual within the onsite work organization who shall be responsible for overall management of CQC and have the authority to act in all CQC matters for the Contractor. The CQC System Manager shall be a construction person with a minimum of 10 years of current experience in related work. This CQC System Manager shall be on the site at all times during construction and shall be employed by the prime Contractor. The CQC System Manager shall be assigned as System Manager but may have other duties such as project superintendent in addition to quality control. An alternate for the CQC System Manager shall be identified in the plan to serve in the event of the System Manager's absence. The requirements for the alternate shall be the same as for the designated CQC System Manager.

3.4.3 CQC Personnel

In addition to CQC personnel specified elsewhere in the contract, the Contractor shall provide as part of the CQC organization specialized personnel to assist the CQC System Manager for the following areas: civil/geotechnical. These individuals may be employees of the prime or subcontractor; be responsible to the CQC System Manager; have the necessary education and/or experience in accordance with the experience matrix listed herein. These individuals may perform other duties but must be allowed sufficient time to perform their assigned quality control duties as described in the Quality Control Plan.

Experience Matrix

Area	Qualifications
a. Civil/Geotechnical	Graduate Engineer with 2 years experience in the type of work being performed on this project

3.4.4 Additional Requirement

In addition to the above experience the CQC System Manager shall have completed the course entitled "Construction Quality Management For Contractors".

3.4.5 Organizational Changes

The Contractor shall maintain the CQC staff at full strength at all times. When it is necessary to make changes to the CQC staff, the Contractor shall revise the CQC Plan to reflect the changes and submit the changes to the Contracting Officer for acceptance.

3.5 SUBMITTALS AND DELIVERABLES

Submittals, if needed, shall be made as specified in Section 01330 SUBMITTAL PROCEDURES. The CQC organization shall be responsible for certifying that all submittals and deliverables are in compliance with the contract requirements.

3.6 CONTROL

Contractor Quality Control is the means by which the Contractor ensures that the construction, to include that of subcontractors and suppliers, complies with the requirements of the contract. At least three phases of control shall be conducted by the CQC System Manager for each definable feature of work as follows:

3.6.1 Preparatory Phase

This phase shall be performed prior to beginning work on each definable feature of work, after all required plans/documents/materials are approved/accepted, and after copies are at the work site. This phase shall include:

- a. A review of each paragraph of applicable specifications, reference codes, and standards. A copy of those sections of referenced codes and standards applicable to that portion of the work to be accomplished in the field shall be made available by the

Contractor at the preparatory inspection. These copies shall be maintained in the field and available for use by Government personnel until final acceptance of the work.

- b. A review of the contract drawings.
- c. A check to assure that all materials and/or equipment have been tested, submitted, and approved.
- d. Review of provisions that have been made to provide required control inspection and testing.
- e. Examination of the work area to assure that all required preliminary work has been completed and is in compliance with the contract.
- f. A physical examination of required materials, equipment, and sample work to assure that they are on hand, conform to approved shop drawings or submitted data, and are properly stored.
- g. A review of the appropriate activity hazard analysis to assure safety requirements are met.
- h. Discussion of procedures for controlling quality of the work including repetitive deficiencies. Document construction tolerances and workmanship standards for that feature of work.
- i. A check to ensure that the portion of the plan for the work to be performed has been accepted by the Contracting Officer.
- j. Discussion of the initial control phase.
- k. The Government shall be notified at least 24 hours in advance of beginning the preparatory control phase. This phase shall include a meeting conducted by the CQC System Manager and attended by the superintendent, other CQC personnel (as applicable), and the foreman responsible for the definable feature. The results of the preparatory phase actions shall be documented by separate minutes prepared by the CQC System Manager and attached to the daily CQC report. The Contractor shall instruct applicable workers as to the acceptable level of workmanship required in order to meet contract specifications.

3.6.2 Initial Phase

This phase shall be accomplished at the beginning of a definable feature of work. The following shall be accomplished:

- a. A check of work to ensure that it is in full compliance with contract requirements. Review minutes of the preparatory meeting.
- b. Verify adequacy of controls to ensure full contract compliance. Verify required control inspection and testing.
- c. Establish level of workmanship and verify that it meets minimum acceptable workmanship standards. Compare with required sample panels as appropriate.
- d. Resolve all differences.

- e. Check safety to include compliance with and upgrading of the safety plan and activity hazard analysis. Review the activity analysis with each worker.
- f. The Government shall be notified at least 24 hours in advance of beginning the initial phase. Separate minutes of this phase shall be prepared by the CQC System Manager and attached to the daily CQC report. Exact location of initial phase shall be indicated for future reference and comparison with follow-up phases.
- g. The initial phase should be repeated for each new crew to work onsite, or any time acceptable specified quality standards are not being met.

3.6.3 Follow-up Phase

Daily checks shall be performed to assure control activities, including control testing, are providing continued compliance with contract requirements, until completion of the particular feature of work. The checks shall be made a matter of record in the CQC documentation. Final follow-up checks shall be conducted and all deficiencies corrected prior to the start of additional features of work which may be affected by the deficient work. The Contractor shall not build upon nor conceal non-conforming work.

3.6.4 Additional Preparatory and Initial Phases

Additional preparatory and initial phases shall be conducted on the same definable features of work if: the quality of on-going work is unacceptable; if there are changes in the applicable CQC staff, onsite production supervision or work crew; if work on a definable feature is resumed after a substantial period of inactivity; or if other problems develop.

3.7 TESTS

3.7.1 Testing Procedure

The Contractor shall perform specified or required tests to verify that control measures are adequate to provide a product which conforms to contract requirements. Upon request, the Contractor shall furnish to the Government duplicate samples of test specimens for possible testing by the Government. Testing includes operation and/or acceptance tests when specified. The Contractor shall procure the services of a Corps of Engineers approved testing laboratory or establish an approved testing laboratory at the project site. The Contractor shall perform the following activities and record and provide the following data:

- a. Verify that testing procedures comply with contract requirements.
- b. Verify that facilities and testing equipment are available and comply with testing standards.
- c. Check test instrument calibration data against certified standards.
- d. Verify that recording forms and test identification control number system, including all of the test documentation requirements, have been prepared.

- e. Results of all tests taken, both passing and failing tests, shall be recorded on the CQC report for the date taken. Specification paragraph reference, location where tests were taken, and the sequential control number identifying the test shall be given. If approved by the Contracting Officer, actual test reports may be submitted later with a reference to the test number and date taken. An information copy of tests performed by an offsite or commercial test facility shall be provided directly to the Contracting Officer. Failure to submit timely test reports as stated may result in nonpayment for related work performed and disapproval of the test facility for this contract.

3.7.2 Testing Laboratories

3.7.2.1 Capability Check

The Government reserves the right to check laboratory equipment in the proposed laboratory for compliance with the standards set forth in the contract specifications and to check the laboratory technician's testing procedures and techniques. Laboratories utilized for testing soils, concrete, asphalt, and steel shall meet criteria detailed in ASTM D 3740 and ASTM E 329.

3.7.2.2 Capability Recheck

If the selected laboratory fails the capability check, the Contractor will be assessed a charge of \$1500 to reimburse the Government for each succeeding recheck of the laboratory or the checking of a subsequently selected laboratory. Such costs will be deducted from the contract amount due the Contractor.

3.7.3 Onsite Laboratory

The Government reserves the right to utilize the Contractor's control testing laboratory and equipment to make assurance tests, and to check the Contractor's testing procedures, techniques, and test results at no additional cost to the Government.

3.7.4 Furnishing or Transportation of Samples for Testing

Costs incidental to the transportation of samples or materials shall be borne by the Contractor. Samples of materials for test verification and acceptance testing by the Government shall be delivered to the Corps of Engineers Division Laboratory, f.o.b., at the address provided by the COR.

3.8 COMPLETION INSPECTION

3.8.1 Punch-Out Inspection

Near the end of the work, or any increment of the work established by a time stated in the Special Clause, "Commencement, Prosecution, and Completion of Work", or by the specifications, the CQC Manager shall conduct an inspection of the work. A punch list of items which do not conform to the approved drawings and specifications shall be prepared and included in the CQC documentation, as required by paragraph DOCUMENTATION. The list of deficiencies shall include the estimated date by which the deficiencies will be corrected. The CQC System Manager or staff shall make a second inspection to ascertain that all deficiencies have been corrected.

Once this is accomplished, the Contractor shall notify the Government that the facility is ready for the Government Pre-Final inspection.

3.8.2 Pre-Final Inspection

The Government will perform the pre-final inspection to verify that the facility is complete and ready to be occupied. A Government Pre-Final Punch List may be developed as a result of this inspection. The Contractor's CQC System Manager shall ensure that all items on this list have been corrected before notifying the Government, so that a Final inspection with the customer can be scheduled. Any items noted on the Pre-Final inspection shall be corrected in a timely manner. These inspections and any deficiency corrections required by this paragraph shall be accomplished within the time slated for completion of the entire work or any particular increment of the work if the project is divided into increments by separate completion dates.

3.8.3 Final Acceptance Inspection

The Contractor's Quality Control Inspection personnel, plus the superintendent or other primary management person, and the Contracting Officer's Representative shall be in attendance at the final acceptance inspection. The final acceptance inspection will be formally scheduled by the Contracting Officer based upon results of the Pre-Final inspection. Notice shall be given to the Contracting Officer at least 14 days prior to the final acceptance inspection and shall include the Contractor's assurance that all specific items previously identified to the Contractor as being unacceptable, along with all remaining work performed under the contract, will be complete and acceptable by the date scheduled for the final acceptance inspection. Failure of the Contractor to have all contract work acceptably complete for this inspection will be cause for the Contracting Officer to bill the Contractor for the Government's additional inspection cost in accordance with the contract clause titled "Inspection of Construction".

3.9 DOCUMENTATION

The Contractor shall maintain current records providing factual evidence that required quality control activities and/or tests have been performed. These records shall include the work of subcontractors and suppliers and shall be on an acceptable form that includes, as a minimum, the following information:

- a. Contractor/subcontractor and their area of responsibility.
- b. Operating plant/equipment with hours worked, idle, or down for repair.
- c. Work performed each day, giving location, description, and by whom. When Network Analysis (NAS) is used, identify each phase of work performed each day by NAS activity number.
- d. Test and/or control activities performed with results and references to specifications/drawings requirements. The control phase shall be identified (Preparatory, Initial, Follow-up). List of deficiencies noted, along with corrective action.
- e. Quantity of materials received at the site with statement as to acceptability, storage, and reference to specifications/drawings

requirements.

- f. Submittals and deliverables reviewed, with contract reference, by whom, and action taken.
- g. Offsite surveillance activities, including actions taken.
- h. Job safety evaluations stating what was checked, results, and instructions or corrective actions.
- i. Instructions given/received and conflicts in plans and/or specifications.
- j. Contractor's verification statement.

These records shall indicate a description of trades working on the project; the number of personnel working; weather conditions encountered; and any delays encountered. These records shall cover both conforming and deficient features and shall include a statement that equipment and materials incorporated in the work and workmanship comply with the contract. The original and one copy of these records in report form shall be furnished to the Government daily within 24 hours after the date covered by the report, except that reports need not be submitted for days on which no work is performed. As a minimum, one report shall be prepared and submitted for every 7 days of no work and on the last day of a no work period. All calendar days shall be accounted for throughout the life of the contract. The first report following a day of no work shall be for that day only. Reports shall be signed and dated by the CQC System Manager. The report from the CQC System Manager shall include copies of test reports and copies of reports prepared by all subordinate quality control personnel.

3.10 SAMPLE FORMS

Sample forms enclosed at the end of this section.

3.11 NOTIFICATION OF NONCOMPLIANCE

The Contracting Officer will notify the Contractor of any detected noncompliance with the foregoing requirements. The Contractor shall take immediate corrective action after receipt of such notice. Such notice, when delivered to the Contractor at the work site, shall be deemed sufficient for the purpose of notification. If the Contractor fails or refuses to comply promptly, the Contracting Officer may issue an order stopping all or part of the work until satisfactory corrective action has been taken. No part of the time lost due to such stop orders shall be made the subject of claim for extension of time or for excess costs or damages by the Contractor.

3.12 MEASUREMENT AND PAYMENT

The work specified in this section will not be measured separately for payment and all costs in connection therewith will be included in the cost of all the bid items.

-- End of Section --

(Sample of typical Contractor Quality Control Report)

CONTRACTOR'S NAME
(address)

DAILY CONSTRUCTION QUALITY CONTROL REPORT

Contract No. _____ Date _____

Project Name _____ Report No. _____

Weather _____

Phases of Construction in Progress (Give briefly only phase or phases of work in progress)

Material and/or Equipment Delivered to Site (Including equipment demob)

Inspection Made (Include negative inspections, phase of in-progress construction work inspected and all deficiencies noted during inspections)

Preparatory

Initial

Follow-up

Tests Performed and Results or Tests (including results of tests taken on previous dates)

Verbal Instructions Received (List any instructions given by Contracting Officer personnel on construction deficiencies, retesting required etc., with action to be taken)

Changed Conditions/Delays/Conflicts Encountered

Remarks

SIGNATURE _____
Quality Control Inspector

Contractor' s Verification: The above report is complete and correct and all material and equipment used and work performed during this reporting period are in compliance with the contract and specifications except as noted above, and job safety and health requirements are in accordance with the USACE Safety and Health Requirements Manual EM 385-1-1.

Contractor' s Approved Authorized Representative

SECTION 01500

TEMPORARY CONSTRUCTION

PART 1 GENERAL

1.1 SCOPE OF SECTION

The work covered by this section consists of furnishing all labor, materials, plant and equipment, and performing all operations required for the construction of storage areas, and service facilities needed for execution and completion of the work. Also included are the requirements for project and safety signs at the work site.

1.2 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by, the office indicated prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved or reviewed by, the office indicated prior to commencing the particular task to which the submittal is associated.

SD-01 Preconstruction Submittals

Temporary Facilities Plan; G,COR.

The Contractor shall submit to the Contracting Officer for approval, prior to the start of work, its plans showing the layout and details of all temporary facilities to be used for this contract, including the proposed locations of staging areas.

PART 2 PRODUCTS

2.1 WEATHER INSTRUMENTS

2.1.1 Rain and Snow Gage

National Weather Service standard gage with stand and wind screen. The gage shall be designed to measure both rain and snow, shall be manufactured of copper and brass, and shall contain a funnel, inner tube, outer cylinder and dipstick.

2.1.2 Thermometer

Minimum/maximum outdoor type with instrument shelter. The thermometer shall be mercury filled and designed to indicate minimum, maximum, and current

temperatures from -40 to 130 degrees F. [Where necessary, the instrument shall have a keyed lock.]

2.2 PROJECT AND SAFETY SIGNS

The Contractor shall provide and erect at locations designated by the Contracting Officer, the project and safety signs shown on the sketches attached to this section of this specification.

PART 3 EXECUTION

3.1 CONTRACTOR'S PROJECT OFFICES

A Contractor's project office is not required for this contract. However, the Contractor shall, at all times during the contract period, be equipped and staffed to provide essential information to the Contracting Officer or its authorized representative. The Contractor shall be equipped with a mobile telephone, a copy of all drawings and specifications, and other pertinent information, and shall at all times give the Contracting Officer access thereto.

3.2 WEATHER INSTRUMENTS

The Government currently maintains a rain and snow gage and thermometer with instrument shelter at the F.E. Walter Dam facility. The Contractor shall coordinate with the dam operators in order to utilize these instruments to take daily readings of precipitation and the minimum and maximum temperatures, and shall record such information on the Contractor Quality Control Reports as required under Section 01450 CONTRACTOR QUALITY CONTROL. This information will be used by the Contracting Officer as the basis for determining if the Contractor is entitled to a time extension for unusually severe weather in accordance with Special Clause: "Time Extensions for Unusually Severe Weather."

3.3 DUST CONTROL

The amount of dust resulting from the contract work shall be controlled to prevent the spread of dust to occupied portions of the construction site and to avoid creation of a nuisance in the surrounding area.

3.4 PROTECTION

3.4.1 Protection of Existing Property

Before beginning any contract, the Contractor shall carefully survey the site and examine the drawings and specifications to determine the extent of the work. The Contractor shall take all necessary precautions to avoid damage to existing property to remain in place and any damaged items shall be repaired or replaced as approved by the Contracting Officer at no additional cost to the Government. The Contractor shall carefully coordinate the work of this section with all other work and shall construct and maintain shoring, bracing and supports, as required.

3.4.2 Environmental Protection

The work shall comply with the requirements of Section 01355 ENVIRONMENTAL PROTECTION.

3.5 BURNING

The use of burning at the project site for the disposal of refuse and debris will not be permitted.

3.6 USE OF EXPLOSIVES

Use of explosives will not be permitted.

3.7 HISTORICAL ITEMS

Historical items shall be removed in a manner to prevent damage. The following historical items shall be delivered to the Government for disposition: Corner stones, contents of corner stones, and document boxes wherever located on the site.

3.8 DISPOSAL OF DEBRIS

All combustible and noncombustible construction debris and trash shall be removed from the site. The material shall be disposed of off-site by the Contractor in accordance with all Federal, State, and local regulations. Combustible materials shall be disposed of off the site.

3.9 RESTORATION OF WORK SITE

Removal of all temporary construction and restoration of the work site upon completion of the contract shall be in accordance with the requirements of Section 01355 ENVIRONMENTAL PROTECTION.

3.10 MEASUREMENT AND PAYMENT

No separate measurement or payment will be made for the work specified in this section and all costs in connection therewith shall be included in the costs of all the bid items.

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

Below are two samples of the construction project identification sign showing how this panel is adaptable for use to identify either military (top) or civil works projects (bottom). The graphic format for this 4'x 6' sign panel follows the legend guidelines and layout as specified below. The large 4'x 4' section of the panel on the right is to be white with black legend.

The 2'x 4' section of the sign on the left with the full Corps Signature (reverse version) is to be screen printed Communications Red on the white background. The designation of a sponsor in the area indicated is optional with Military or Civil Works construction signs. Signs may list one sponsoring entity. If agreement on a sponsor designation cannot be achieved,

the area should be left blank.

This sign is to be placed with the Safety Performance sign shown on the following page. Mounting and fabrication details are provided on page 16.4.

Special applications or situations not covered in these guidelines should be referred to the District/Division Sign Program Manager.

Legend Group 1: One- to two-line description of Corps relationship to project.

Color: White
Typeface: 1.25" Helvetica Regular
Maximum line length: 19"

Legend Group 2: Division or District Name (optional). Placed below 10.5" reverse Signature (6" Castle).

Color: White
Typeface: 1.25" Helvetica Regular

Legend Group 2a: One- to three-line identification of Military or Civil Works sponsor (optional). Place below Corps Signature to cross-align with Group 5a-b.

Color: White
Typeface: 1.25" Helvetica Regular
Maximum line length: 19"

Legend Group 3: One- to three-line project title legend describes the work being done under this contract.

Color: Black
Typeface: 3" Helvetica Bold
Maximum line length: 42"

Legend Group 4: One- to two-line identification of project or facility (civil works) or name of sponsoring department (military).



Color: Black
Typeface: 1.5" Helvetica Regular
Maximum line length: 42"

Cross-align the first line of Legend Group 4 with the first line of the Corps Signature (US Army Corps) as shown.

Legend Groups 5a-b: One- to five-line identification of prime contractors including: type (architect, general contractor, etc.), corporate or firm name, city, state. Use of Legend Group 5 is optional.

Color: Black
Typeface: 1.25" Helvetica Regular
Maximum line length: 21"

All typography is flush left and rag right, upper and lower case with initial capitals only as shown. Letter- and word-spacing to follow Corps standards as specified in Appendix D.



Sign Type	Legend Size (A)	Panel Size	Post Size	Specification Code	Mounting Height	Color Bkg/Lgd
CID-01	various	4' x 6'	4" x 4"	HDO-3	48"	WH-RD/BK

Each contractor's safety record is to be posted on Corps managed or supervised construction projects and mounted with the construction project identification sign specified on page 16.2.

The graphic format, color, size and type-faces used on the sign are to be reproduced exactly as specified below.

The title with First Aid logo in the top section of the sign, and the performance record captions are standard for all signs of this type. Legend groups 2 and 3 below identify the project and the contractor and are to be placed on the sign as shown.

Safety record numbers are mounted on individual metal plates and are

screw-mounted to the background to allow for daily revisions to posted safety performance record.

Special applications or situations not covered in these guidelines should be referred to the District/Division Sign Program Manager.

Legend Group 1: Standard two-line title "Safety is a Job Requirement" with (8" od.) Safety Green First Aid logo.
Color: To match PMS 347
Typeface: 3" Helvetica Bold
Color: Black

Legend Group 2: One- to two-line project title legend describes the work being done under this contract and name of host project.
Color: Black
Typeface: 1.5" Helvetica Regular
Maximum line length: 42"

Legend Group 3: One- to two-line identification: name of prime contractor and city, state address.
Color: Black
Typeface: 1.5" Helvetica Regular
Maximum line length: 42"


Legend Group 4: Standard safety record captions as shown.
Color: Black
Typeface: 1.25" Helvetica Regular

Replaceable numbers are to be mounted on white .060 aluminum plates and screw-mounted to background.
Color: Black
Typeface: 3" Helvetica Regular
Plate size: 2.5" x 4.5"

All typography is flush left and rag right, upper and lower case with initial capitals only as shown. Letter and word spacing to follow Corps standards as specified in Appendix D.



Sign Type	Legend Size (A)	Panel Size	Post Size	Specification Code	Mounting Height	Color Bkg/Lgd
CID-02	various	4' x 4'	4" x 4"	HDO-3	48"	WH/BK-SG



All Construction Project Identification signs and Safety Performance signs are to be fabricated and installed as described below. The signs are to be erected at a location designated by the Contracting Officer Representative and shall conform to the size, format, and typographic standards shown on pages

The sign panels are to be fabricated from .75" High Density Overlay Plywood. Panel preparation to follow HDO specifications provided in Appendix B.

Sign graphics to be prepared on a white non-reflective vinyl film with positionable adhesive backing.

All graphics except for the Communications Red background with Corps signature on the project sign are to be die-cut or computer-cut non-reflective vinyl, pre-spaced legends prepared in the sizes and typefaces specified and applied to the background panel following the graphic formats shown on pages 16.2-3.

The 2' x 4' Communications Red panel (to match PMS-032) with full Corps signature (reverse version) is to be screen printed on the white background. Identification of the district or division may be applied under the signature with white cut vinyl letters prepared to Corps standards. Large scale reproduction artwork for the signature is provided on page 4.8 (photographically enlarge from 6.875" to 10.5").

Drill and insert six (6) .375" T-nuts from the front face of the HDO sign panel. Position holes as shown. Flange of T-nut to be flush with sign face.

Apply graphic panel to prepared HDO plywood panel following manufacturers' instructions.


Sign uprights to be structural grade 4" x 4" treated Douglas Fir or Southern Yellow Pine, No.1 or better. Post to be 12' long. Drill six (6) .375" mounting holes in uprights to align with T-nuts in sign panel. Countersink (.5") back of hole to accept socket head cap screw (4" x .375").

Assemble sign panel and uprights. Imbed assembled sign panel and uprights in 4' hole. Local soil conditions and/or wind loading may require bolting additional 2" x 4" struts on inside face of uprights to reinforce installation as shown.

16.2-3. Detailed specifications for HDO plywood panel preparation are provided in Appendix B.

Shown below the mounting diagram is a panel layout grid with spaces provided for project information. Photocopy this page and use as a worksheet when preparing sign legend orders.

For additional information on the proper method to prepare sign panel graphics, contact the District/Division Sign Program Manager.



Construction Project Sign
Legend Group 1: Corps Relationship

1. _____
2. _____

Legend Group 2: Division/District Name

1. _____
2. _____

Legend Group 3: Project Title

1. _____
2. _____
3. _____

Legend Group 4: Facility Name

1. _____
2. _____

Legend Group 5a: Contractor/A&E

1. _____
2. _____
3. _____
4. _____
5. _____

Legend Group 2a: Military/Civil Works Sponsor

1. _____
2. _____

Legend Group 5b: Contractor/A&E

1. _____
2. _____
3. _____
4. _____
5. _____

Safety Performance Sign
Legend Group 1: Project Title

1. _____
2. _____

Legend Group 2: Contractor/A&E

1. _____
2. _____

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SECTION 01720

SURVEY REQUIREMENTS

PART 1 GENERAL

1.1 SCOPE OF SECTION

The work covered by this section consists of furnishing all labor, materials, plant and equipment, and performing all operations required in conducting surveys and survey data submittals.

1.2 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by basic designation only.

U.S. ARMY CORPS OF ENGINEERS (COE)

EM 1110-1-1005 (31 Aug 1994) Topographic Surveying Manual

1.3 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by (if "G" designation) or reviewed by (if for information only), the CO prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved by (if "G" designation) or reviewed by (if for information only), the CO prior to commencing the particular task to which the submittal is associated.

SD-06 Test Reports

Surveying Procedures and Equipment; G,DO.

All surveying procedures, methods, and equipment for landward beach surveys, hydrographic surveys, and tidal monitoring, shall be reviewed and approved by the Government Survey Point of Contact prior to the start of any type of surveying work.

SD-07 Certificates

Qualifications; G,DO.

Provide qualifications of the independent licensed surveyor(s) for land and hydrographic surveying.

PART 2 PRODUCTS (Not Applicable)

PART 3 EXECUTION

3.1 SURVEY REQUIREMENTS

The Contractor shall be responsible for conducting all surveys required to demonstrate that the construction is in compliance with the specified tolerances and the lines, grades, and elevations shown on the drawings. Surveys shall be taken by a Pennsylvania licensed surveyor. These surveys shall consist of cross-sections taken before and after excavation, filling, and riprap placement, as specified in Section 00800 SPECIAL CLAUSES: QUANTITY SURVEYS. .

3.2 GENERAL SURVEY REQUIREMENTS

3.2.1 Qualifications of Surveyor

All surveys must be performed by an independent survey company. All land surveys shall be performed under the direction and supervision of a Professional Licensed Surveyor.

3.2.2 Control

Survey control will be established from the existing survey baseline control description data information as shown on the contract drawings and listed in Section 00845 SURVEY DESCRIPTION SHEETS. The Contractor shall utilize North American Vertical Datum (NAVD) 1988 as the vertical datum. The Contractor shall utilize Pennsylvania State Plane Coordinate System (NAD 1983) as the horizontal reference datum.

3.2.3 Intervals

Survey intervals for the cross sections shall be taken at the starting and ending stations of each work item and every 20 feet or as specified. The survey control to be used for vertical control are shown on the Contract Drawings and as described in Section 00845 SURVEY DESCRIPTION SHEETS.

3.2.4 Tolerances

The landward portion of the profile lines shall be surveyed utilizing surveying procedures and methodology that meet or exceed accuracy tolerances of +/- 0.10 feet in the vertical and +/- 0.50 feet in the horizontal, with a 95% confidence level. All topographic or land based surveys performed in conjunction with this Contract shall meet all criteria outlined in EM 1110-1-1005.

3.2.5 Data Submittal

All survey cross section data shall be reduced and tabulated as a series of offset and elevation pairs. Horizontal distances of each survey point shall be referenced as negative seaward from the established Corps baseline point, and positive landward from the baseline. In addition, all survey points shall be recorded in three dimensions, using the Pennsylvania State Plane Coordinate System, NAD83 and NAVD88 for elevations. The data shall be entered into a digital format in the DOS operating system on 1.44 Mb 3 1/2" double sided/high density micro disks or CD. The data shall be submitted in the following file:

ASCII files having a descriptive header for each profile line followed by three columns: Eastings (X), Northings (Y) and Elevation (Z).

Plotted cross section drawings in AutoCAD 2000 format shall also be submitted for each cross section survey taken. The grid spacing shall be 10 feet in the vertical and 10 feet in the horizontal. Each drawn cross section shall show the station that it was taken from. These drawings shall be submitted on CD.

3.2.6 Timely Submission of Survey Data

Survey data, unless specified otherwise, shall be submitted to the COR within 5 workdays of completion of the surveys.

3.3 MEASUREMENT AND PAYMENT

The work specified in this section for surveying will not be measured for payment. All costs in connection therewith shall be considered incidental to those bid items to which the surveys are incidental.

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SECTION 01780

AS-BUILT DRAWINGS

PART 1 GENERAL

1.1 SCOPE OF SECTION

The work specified in this section includes the preparation of as-built drawings complete, as a requirement of this contract.

1.2 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

SD-07 Certificates

Progress Prints; G,COR.

The Contractor shall submit as-built marked prints with submission of each monthly pay estimate.

SD-11 Closeout Submittals

As-Built Drawings; G,COR.

The Contractor shall submit as-built drawings as specified herein.

PART 2 PRODUCTS (Not Applicable)

PART 3 EXECUTION

3.1 PROGRESS MARKED-UP AS-BUILT PRINTS

The Contractor shall mark-up one set of paper prints to show the as-built conditions for the project. These as-built marked prints shall be kept current and available on the jobsite at all times. All changes from the contract plans which are made in the work or additional information which might be uncovered in the course of construction shall be accurately and neatly recorded as they occur by means of details and notes. The as-built marked prints will be jointly inspected for accuracy and completeness by the Contracting Officer's representative and a responsible representative of the Construction Contractor prior to submission of each monthly pay estimate. The drawings shall show the following information, but not be limited thereto:

- a. The location and description of any utility lines or other installations of any kind or description known to exist within the construction area. The location shall include dimensions to permanent features.
- b. The location and dimensions of any changes within the building or structure.

- c. Correct grade or alignment of roads, structures, or utilities if any changes were made from the contract plans.
- d. Correct elevation if changes were made in site grading.
- e. Changes in details of design or additional information obtained from working drawings specified to be prepared and/or furnished by the Contractor including but not limited to fabrication, erection, installation plans and placing details, pipe sizes, insulation material, dimensions of equipment foundations, etc.
- f. The topography and grades of all drainage installed or affected as part of the project construction.
- g. All changes or modifications which result from the final inspection.
- h. Where contract drawings or specifications allow options, only the option selected for construction shall be shown on the as-built prints.

3.2 PRELIMINARY SUBMITTALS

The Contractor shall prepare the progress as-built prints and these shall be delivered to the Contracting Officer at the time of final inspection for his review and approval. These as-built marked prints shall be neat, legible and accurate. The review by Government personnel will be expedited to the maximum extent possible. Upon approval, the as-built marked prints will be returned to the Contractor for use in preparation of final as-built drawings. If upon review, the drawings are found to contain errors and/or omissions, they will be returned to the Contractor for corrections. The Contractor shall complete the corrections and return the as-built marked prints to the Contracting Officer within ten (10) calendar days.

3.3 DRAWING PREPARATION

3.3.1 General Requirements

Upon approval of the as-built prints submitted, the Contractor will be furnished the contract drawings on 3-1/2 inch floppy disks or compact disc (CD) in AutoCAD 2000 format with all amendments incorporated. The drawing files shall be modified as necessary to correctly show all the features of the project as it has been constructed by bringing the contract set into agreement with the approved as-built prints, adding such additional drawings as may be necessary.

3.3.2 Modification of Contract Drawings

Only personnel proficient in the preparation of engineering drawings and the use of AutoCAD 2000, to standards satisfactory and acceptable to the Contracting Officer, shall be employed to modify the contract drawings or prepare additional new drawings. All additions and corrections to the contract drawings shall be done using AutoCAD 2000 in a professional manner, and shall match the existing linework and/or lettering used on the drawings in type, density, size and style. The title block to be used for any new as-built drawings shall be the same as that used on the original drawings.

3.3.3 Identification of Final As-Built Drawings

When final revisions have been completed, each drawing shall be identified with the words "RECORD DRAWING AS-BUILT" followed by the name of the General Contractor in letters at least 3/16-inch high. All contract drawings shall be annotated and dated in the revision block as either "AS-BUILT DRAWING" denoting no revision on the sheet or "REVISED AS-BUILT DRAWING" denoting one or more revisions. For drawings having as-built revisions, a revision number contained within a 3/16 inch high triangle shall be included in the revision block. All changes to drawings shall be encircled with a series of short arcs forming a "cloud", with the triangle revision number positioned immediately next to each cloud.

3.4 FINAL REQUIREMENTS

After receipt by the Contractor of the approved as-built prints and the original contract drawings, the Contractor shall within 30 days for contracts less than \$5 million or within 60 days for contracts of \$5 million or more, make the final as-built submittal. This submittal shall consist of the completed as-built drawings on 3-1/2 inch floppy disk or compac disk (CD) in AutoCAD 2000 format, one full-size mylar copy of the drawings, and the return of the approved as-built prints. All drawings shall be complete in all details. All AutoCAD files and reproducible drawings will become the property of the Government upon final approval. Failure to submit the above as-built information as required will be cause for withholding any payment due the Contractor under this contract. The Contracting Officer will review all as-built drawings for accuracy and conformance to the above requirements. The Contractor shall make all corrections, changes, additions, and deletions required to meet these standards. Approval and acceptance of final as-built drawings will be required before final payment is made to the Contractor.

3.5 MEASUREMENT AND PAYMENT

No separate measurement or payment will be made for the work specified in this section and all costs in connection therewith shall be included in the costs of all the bid items.

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SECTION 02230

SITE CLEARING

PART 1 GENERAL

1.1 GENERAL REQUIREMENTS

The work of this Section shall include the removal and disposal of the existing weir and the clearing and grubbing of areas within the Limit of Disturbance indicated on the Contract Drawings, as required for completion of the work. It is anticipated that areas to be cleared and grubbed shall include areas required for flow diversion and access improvements, proposed borrow areas, and areas proposed for construction of the earthen embankment and cut-off trench as indicated on the Contract Drawings. Clearing and grubbing shall be limited to that necessary to complete the work. All cleared and grubbed materials shall be removed from the site weekly, unless otherwise directed, to avoid accumulation at the site. Materials that cannot be removed weekly shall be stored in areas specified by the Contracting Officer.

1.2 DEFINITIONS

1.2.1 Clearing

Clearing shall consist of the felling, trimming, and cutting of trees into sections, removal of the existing weir, removal of rocks and boulders, and the satisfactory disposal of the weir, rocks and boulders, trees and other vegetation designated for removal, including down timber, snags, brush, and rubbish present in the areas to be cleared.

1.2.2 Grubbing

Grubbing shall consist of the removal and disposal of stumps, roots larger than 3 inches in diameter, and matted roots from the designated grubbing areas.

1.3 ENVIRONMENTAL PROTECTION

The work shall comply with the requirements of Section 01355, ENVIRONMENTAL PROTECTION.

1.4 BURNING

The use of burning at the project site for the disposal of cleared or grubbed material will not be permitted.

PART 2 PRODUCTS (Not Applicable)

PART 3 EXECUTION

3.1 CLEARING

Trees, stumps, roots, brush, and other vegetation in areas to be cleared shall be cut off flush with or below the original ground surface, except such trees and vegetation as may be indicated or directed to be left

standing. Trees directed to be left standing within the cleared areas shall be trimmed of dead branches 1-1/2 inches or more in diameter and shall be trimmed of all branches the heights indicated or directed. Limbs and branches to be trimmed shall be neatly cut close to the bole of the tree or main branches. Cuts more than 1-1/2 inches in diameter shall be painted with a tree-wound paint approved by the Contracting Officer. Trees and vegetation to be left standing shall be protected from damage incident to clearing, grubbing, and construction operations by the erection of barriers or by such other means as the circumstances require.

3.2 GRUBBING

Material to be grubbed, together with logs and other organic or metallic debris not suitable for foundation purposes, shall be removed to a depth of not less than 18 inches below the original surface level of the ground in areas indicated to be grubbed and in areas indicated as construction areas under this contract. Depressions made by grubbing shall be filled with suitable material and compacted to make the surface conform with the original adjacent surface of the ground.

3.3 DISPOSAL OF MATERIALS

3.3.1 Rock Materials

Rocks and boulders cleared from the construction areas shall remain the property of the Government. Rocks and boulders shall be stockpiled at a location designated by the Contracting Officer.

3.3.2 Materials Other than Rock

The existing weir, all felled timber, logs, stumps, roots, brush, rotten wood, and other refuse from the clearing and grubbing operations, except for salable timber and rocks and boulders, shall be disposed of outside the limits of Government-controlled land, except when otherwise directed in writing. Such directive will state the conditions covering the disposal of such products and will also state the areas in which they may be placed. All material shall be disposed of promptly, in a legal manner, at the Contractor's expense.

3.4 CLEAN UP

All material shall be removed and transported in a manner that prevents spillage on streets or adjacent areas. Federal, State and Local regulations regarding hauling and disposal shall apply.

3.5 MEASUREMENT AND PAYMENT

3.5.1 Site Clearing

No measurement will be made for the clearing and grubbing specified in this Section and on the Contract Drawings. Payment will be made at the Contract Lump Sum price for Bid Item No. 2, "Site Clearing," which shall constitute full compensation to the Contractor for all costs associated with the clearing and grubbing, including disposal of cleared and grubbed materials as required by this Section.

-- End of Section --

SECTION 02271

RIPRAP

PART 1 GENERAL

1.1 SUMMARY

The work covered by this section consists of furnishing all labor, materials, plant, and equipment, and performing all operations required for placing stone riprap, as specified herein and as shown on the Contract Drawings.

1.2 STONE RIPRAP SOURCES

Stone meeting the requirements of these specifications must be acquired from an approved source. Regardless of the source used by the Contractor, the stone riprap shall meet the requirements of Part 2 of this Section.

1.3 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by basic designation only.

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM C 127 (1988) Standard Test Method for Specific Gravity and Absorption of Coarse Aggregate

ASTM C 131 (1989) Standard Test Method for Resistance to Degradation of Small-Size Coarse Aggregate by Abrasion in the Los Angeles Machine

ASTM C 295 (1990) Standard Guide for Petrographic Examination of Aggregate for Concrete

CRD-C-144 (1992) Standard Test Method for Resistance of Rock to Freezing and Thawing

PENNSYLVANIA DEPARTMENT OF TRANSPORTATION (PennDOT)

Section 850 (2000 SPECIFICATIONS) Aggregate

1.4 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by, the office

indicated prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved or reviewed by, the office indicated prior to commencing the particular task to which the submittal is associated.

SD-03 Product Data

Sources for Stone Riprap; G,DO. Gradation Curves; G,DO.

The proposed source of the stone to be used for the work shall be submitted for approval by the Contracting Officer no less than 14 days in advance of delivery of material to the work site. Suitable test and service records for that source shall be submitted which will be used by the Contracting Officer to determine the acceptability of the stone from that source. In the event such data is unavailable, the Contractor shall procure the services of an independent industry-recognized testing laboratory to perform the required acceptance tests.

The Government will visit the selected quarry to inspect stone quality at least 7 days before any stone delivery to the work site. The Contractor shall have a truck load of each stone type dumped at the quarry. The stone shall be properly graded for inspection by the Government.

The Contractor shall submit gradation curves to verify that the stone riprap meets the requirements specified herein.

SD-07 Certificates

Stone Riprap Work Plan; G,DO.

The Contractor shall submit their proposed plan for transportation, handling, storage, and placement of the stone riprap for approval by the Contracting Officer. This plan shall be submitted at least 14 working days prior to the start of placement of the stone riprap.

PART 2 PRODUCTS

2.1 STONE RIPRAP

2.1.1 Quality

Riprap stone shall be crushed stone. The stone shall be sound, durable and of suitable quality to ensure performance in the work and in the climate in which it is to be used. Stone shall be free from cracks, seams, and other defects that would tend to increase its deterioration from the elements. The stone shall be blocky and angular quarried material, with the least dimension not less than one-third the greatest dimension. Flat slabs, boulders, and parts of boulders will not be acceptable. The inclusion of objectionable quantities of dirt, sand, clay, and rock fines will not be permitted. The stone dry density shall not be less than 165 pounds per cubic foot.

2.1.2 Testing

The following tests will be used by the Government to determine the acceptability of the stone sources selected by the Contractor.

PROPERTY	TEST METHOD	ACCEPTABLE TEST RESULTS
Petrographic	ASTM C 295	Fresh, interlocking, crystalline, with few voids, no clay minerals and no soluble minerals.
Specific Gravity and Absorption	ASTM C 127	Minimum Unit Weight (dry) of 165 pounds per cubic foot. Absorption less than 1%.
Abrasion Resistance	ASTM C 131	Less than 20% loss for 500 revolutions.
Freezing/Thawing	CRD-C-144	Less than 10% loss for 12 cycles.

Additional testing shall be required if results from the tests, specified above, are close to the limits of acceptability. In the event test reports are not available, as in the case of newly operated sources, the Contractor shall perform such tests as are necessary to determine the acceptability of the stone for use in the work. Approval of a source of stone is not to be construed as approval of all material from that source. The right is reserved to reject materials from certain localized areas, zones, strata, or channels, when such materials are unsuitable for use as determined by the Contracting Officer. Individual stones or loads or parts of loads may be rejected if material does not meet the specifications.

2.1.3 Gradation

Riprap shall meet the gradation requirements of PennDOT R-4 as specified in Section 850 of the PennDOT Specifications. The stone shall be blended at the quarry. Blending at the work site is prohibited.

PART 3 EXECUTION

3.1 FOUNDATION PREPARATION

The geotextile shall be installed on the prepared surfaces in accordance with Section 02378 GEOSYTHETICS.

3.2 STONE RIPRAP

3.2.1 Method of Placement

Stone riprap materials shall be carefully placed on the geotextile as indicated on the Contract Drawings. The riprap shall be placed in such a manner as to produce a reasonably well-graded mass of rock with the minimum practicable percentage of voids. Placement shall also be performed in such a manner as to avoid displacing the underlying geotextile. The riprap shall not be dropped onto the geotextile from a height greater than 1 foot. Any damage to the foundation surface or to the geotextile resulting from riprap placement shall be repaired as directed by the Contracting Officer before continuing with the work. Compaction of the riprap materials is not required. However, the rearranging of individual riprap stones by

mechanical equipment or by hand shall be required to the extent necessary to obtain a reasonably even finished surface. Riprap placement equipment, or any other heavy equipment, will not be permitted on the geotextile or riprap.

3.2.2 Distribution of Stone Size

Placing the riprap by dumping into chutes or by similar method likely to cause segregation of the various sizes will not be permitted. The desired distribution of the various sizes of stone throughout the mass shall be obtained by selective loading of the material at the quarry by controlled placement of successive loads during final placement, or by other methods of placement which will produce the specified results.

3.2.3 Maintenance of Riprap

The Contractor shall maintain the riprap until accepted by the Government and any material displaced by any cause shall be replaced at no additional cost to the Government, to the lines and grades indicated on the Contract Drawings.

3.2.4 SURVEY REQUIREMENTS

The Contractor shall be responsible for conducting all surveys as required to demonstrate that the construction is in compliance with the specified tolerances and the lines, grades, and elevations shown on the drawings. Cross sections taken at 20 foot intervals along the length of the embankment. Three cross sections shall be taken in the weir spillway at the two top of slopes and at the bottom of the weir spillway. Prior to the start of placement of riprap, a survey will be performed to determine the existing embankment fill surface elevations along the proposed embankment alignment. Another survey of the final riprap grades shall be performed following the completion of riprap placement to confirm the required embankment geometry. The cross sections shall be taken perpendicular to the centerline of the embankment and shall extend at least 10 feet beyond limit of fill.

3.3 MEASUREMENT AND PAYMENT

The work specified in this section for the riprap stone will be measured for payment by the number of tons (2,000 lbs.) of material satisfactorily placed and accepted. Quantity of stone will be measured from certified weigh tickets. Deductions from those quantities will be made for rejected material. Payment will be made at the contract unit price for Base Bid Item No. 4, "Stone Riprap". Payment for this bid item shall include the labor, equipment, and materials required to place the riprap stone and any required material testing and surveys.

-- End of Section --

SECTION 02300

EARTHWORK

PART 1 GENERAL

1.1 SUMMARY

The work specified in this section includes the earthwork activities involved in the excavation and backfill of the cutoff trench, placement of the embankment fill, and placement of the roadway crushed stone to be used in providing improved access to the site.

1.2 BORROW SOURCE FOR EMBANKMENT FILL

The source for embankment fill shall be the on-site borrow area designated as the Existing Waste Area on the Contract Drawings. On-site borrow materials used as embankment fill must meet the requirements of embankment fill as specified in this section. Therefore, sorting, separating and raking-out of these materials may be required and should be anticipated by the Contractor. All borrow activities shall be performed in accordance with the requirements of Paragraph titled BORROW AREA in this Section. If the Contractor proposes to use an off-site borrow source the material shall have between 15 and 50 percent passing the #200 sieve, contain stones less than 3 inches and shall be approved by the Contracting Officer.

1.3 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by basic designation only.

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM D 1556	(1990; R 1996) Density and Unit Weight of Soil in Place by the Sand-Cone Method
ASTM D 1557	(1998) Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/cu. ft. (2,700 kN-m/cu. m.))
ASTM D 2487	(1998) Classification of Soils for Engineering Purposes (Unified Soil Classification System)
ASTM D 2922	(1996) Density of Soil and Soil-Aggregate in Place by Nuclear Methods (Shallow Depth)
ASTM D 3017	(1988; R 1996e1) Water Content of Soil and Rock in Place by Nuclear Methods (Shallow Depth)

AMERICAN ASSOCIATION OF STATE HIGHWAY AND TRANSPORTATION OFFICIALS
(AASHTO)

AASHTO M 43-88

(1988) Sizes of Aggregate for Road and
Bridge Construction

COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF TRANSPORTATION (PennDOT)

Section 703

(2000 SPECIFICATIONS) Aggregate

1.4 DEFINITIONS

1.4.1 Satisfactory Materials for Embankment Fill

Satisfactory materials for embankment fill shall comprise any materials classified by ASTM D 2487 as SW, SP, SM, SW-SM, SC, SW-SC, SP-SM, SP-SC, CL, ML, or CL-ML containing stones of less than 12 inches in all dimensions. Embankment fill utilized as GCL Cover Soil shall meet the requirements of embankment fill and shall not contain stones greater than 3 inch in all dimensions.

1.4.2 Unsatisfactory Materials

Materials which do not comply with the requirements for satisfactory materials are unsatisfactory. Unsatisfactory materials also include trash; refuse; and material classified as satisfactory which contains root and other organic matter or frozen material. Unsatisfactory materials shall be disposed of as indicated in Paragraph "BORROW AREA" of this Section of the Specification. The Contracting Officer shall be notified of any contaminated materials.

1.4.3 Degree of Compaction

Degree of compaction required is expressed as a percentage of the maximum density obtained by the Modified Proctor test procedure as presented in ASTM D 1557 abbreviated as a percent of laboratory maximum density.

1.5 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by, the office indicated prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved or reviewed by, the office indicated prior to commencing the particular task to which the submittal is associated.

SD-01 Preconstruction Submittals

Sources for Cutoff Trench Backfill; G,DO
Trench Backfill Gradation Curves; G,DO

The Contractor shall submit to the Contracting Officer for approval, prior to delivery, their proposed source for the cutoff trench backfill. The

test data specified herein for those sources shall be submitted. In the event such data is unavailable, the Contractor shall procure the services of an industry- recognized testing laboratory to perform the required acceptance tests. The results of all acceptance tests shall be furnished to the Contracting Officer at least 14 days prior to the delivery of the crushed stone to the work site. All testing shall be entirely at the Contractor's expense.

The Contractor shall submit gradation curves to verify that the crushed stone meets the requirements specified herein for cutoff trench backfill.

Sources for Roadway Crushed Stone; G,DO
Roadway Crushed Stone Gradation Curves; G,DO

The Contractor shall submit to the Contracting Officer for approval, prior to delivery, their proposed source for the roadway crushed stone. The test data specified herein for those sources shall be submitted. In the event such data is unavailable, the Contractor shall procure the services of an industry- recognized testing laboratory to perform the required acceptance tests. The results of all acceptance tests shall be furnished to the Contracting Officer at least 14 days prior to the delivery of the crushed stone to the work site. All testing shall be entirely at the Contractor's expense.

The Contractor shall submit gradation curves to verify that the roadway crushed stone meets the requirements specified herein.

Cutoff Trench Construction and GCL Installation Work Plan; G,DO

The Contractor shall prepare a Cutoff Trench Construction and GCL Installation Work Plan outlining the proposed methods to be used in construction of the cutoff trench as required by the Contract Drawings and this Specification. This work plan shall include details regarding the proposed methods for excavation of the cutoff trench to the required depth; installation of the GCL and geotextile in the cutoff trench, including the proposed methods for maintaining the GCL against the excavation side wall and the geotextile against the GCL during backfill of the trench, and methods for joining adjacent GCL panels within the cutoff trench; and placement of the trench backfill. This work plan shall also address the stability of the proposed excavation, as well as dewatering of the trench during installation of the geosynthetics and placement of the backfill materials. Included in this plan shall also be the method of placing the GCL on the embankment, the GCL cover soil and the method used to attach the GCL to the weir frame. This plan shall be submitted to the Contracting Officer for review and approval a minimum of 14 calendar days prior to the start of cutoff trench construction activities.

Drainage and Dewatering Work Plan; G,DO

The procedures proposed for the accomplishment of diversion of the surface and seepage flow and dewatering of the work site during construction shall be submitted for approval at least 14 calendar days prior to the start of land disturbing activities at the site. The Work Plan shall include a detailed description of the methods and equipment to be used for the diversion and dewatering, the sequence of operations, and a schedule for implementation of the diversion. This plan shall also provide for coordination between the Contractor and the U.S. Army Corps of Engineers Hydrology and Hydraulics Branch regarding potential releases from the dam during the construction period.

Access Improvement Plan; G,DO

The Contractor shall prepare an Access Improvement Work Plan detailing the access improvements proposed as part of the project. This plan shall be submitted to the Contracting Officer for review and approval a minimum of 14 calendar days prior to the start of land disturbing activities at the site.

SD-06 Test Reports

Testing Results; G,COR.

Within one week of conclusion of physical tests, including proctor tests and nuclear density tests, three copies of test results, including calibration curves and results of calibration tests.

SD-07 Certificates

Testing Laboratory Qualifications; G,COR.

Qualifications of the commercial testing laboratory which will be performing the required testing shall be submitted to the Contracting Officer a minimum of 7 calendar days prior to the start of any earthmoving activities related to the cutoff trench or embankment construction.

1.6 SUBSURFACE DATA

Test pit logs, indicating the subsurface conditions and the depths at which boulders and massive rock were encountered in the vicinity of the proposed work are included on the Contract Drawings. Piezometer installation logs for two existing piezometers located in the vicinity of the proposed work, which provide additional information regarding the subsurface conditions and the depths at which boulders and massive rock were encountered, are included as Plates 5 and 6 of Section 01010. The corresponding test pit and piezometer locations are indicated on the Contract Drawings. These data represent the best subsurface information available in the vicinity of the proposed construction; however, variations may exist in the subsurface between test pit and piezometer locations.

PART 2 PRODUCTS

2.1 CUTOFF TRENCH BACKFILL

The cutoff trench backfill shall meet the requirements of AASHTO SP No. 67 Aggregate as specified in AASHTO M 43-88.

2.2 ROADWAY CRUSHED STONE

Crushed stone placed for the access roadway shall meet the requirements of Course Aggregate 2A as specified in Section 703 of the PennDOT Specifications.

2.3 Geotextile

The geotextile shall be as specified in Section 02378 GEOTEXTILE.

PART 3 EXECUTION

3.1 Access Road Improvements

If improvements are required, it is anticipated that, as a minimum, access improvements shall include clearing, grubbing and regrading of a haul road, at least twelve feet wide, to provide a stable access way for both street-legal and off-road construction vehicles and equipment to the construction site. The limits of improvement shall be 150 feet north of the location of survey marker OUT-2 to 130 feet north east to the waste berm area and for estimating purposes the length shall be a total of 280 feet. All road beds shall be graded to a longitudinal slope of 2.5H:1V or flatter, with a cross slope of 5H:1V or flatter. Depending upon the conditions encountered, the use of geotextile fabric and crushed stone may be required along portions of the haul road. If required, the crushed stone shall meet the requirements for roadway crushed stone as specified herein and shall be a minimum of 8 inches in thickness. Any access improvements shall remain in place following the completion of the project.

Access improvements shall be made prior to the start of any other land disturbing activities at the site. The Contractor shall restore any damage (i.e.; rutting) to the improved access road due to the construction operations at the Contractors expense.

3.2 STRIPPING OF TOPSOIL

Where present within the areas proposed for construction of the embankment, cutoff trench and in the embankment fill borrow area, topsoil shall be stripped in its entirety. Topsoil shall be kept separate and temporarily stockpiled for future use in restoration of the borrow area or disposal on-site as directed by the Contracting Officer.

3.3 DRAINAGE AND DEWATERING

3.3.1 Drainage

Surface water shall be directed away from excavation and construction sites to prevent erosion and undermining of foundations. Diversion ditches, dikes and grading shall be provided and maintained as necessary during construction. Excavated slopes and backfill surfaces shall be protected to prevent erosion and sloughing. Excavation shall be performed so that the site, the area immediately surrounding the site, and the area affecting operations at the site shall be continually and effectively drained and free of standing water.

3.3.2 Dewatering

Groundwater flowing toward or into excavations shall be controlled to prevent sloughing of excavation slopes and walls, boils, uplift and heave in the excavation and to eliminate interference with orderly progress of construction. French drains, sumps, ditches or trenches will not be permitted within 3 feet of the foundation of any structure, except with specific written approval, and after specific contractual provisions for restoration of the foundation area have been made. Control measures shall be taken by the time the excavation reaches the water level in order to maintain the integrity of the in situ material. While the excavation is open, the water level shall be maintained continuously, at least 0.5 feet below the working level.

3.4 CUTOFF TRENCH EXCAVATION

The Contractor shall perform excavation for the cutoff trench at the

locations and to the widths and depths indicated on the Contract Drawings, in accordance with the approved Cutoff Trench Construction and GCL Installation Work Plan. The trench shall be excavated to the top of bedrock or to a maximum depth of 10 feet below the existing ground surface.

As indicated in the test pit logs included on the contract drawings, boulders may be encountered during excavation for the trench. Accordingly, removal of boulders and overexcavation of the trench may be required and should be anticipated by the Contractor. If rock is encountered in the excavation, the Contractor shall determine, to the satisfaction of the Contracting Officer, whether the rock represents bedrock or boulders. The Contractor shall proceed with the excavation, or terminate the excavation, as determined by the Contracting Officer. Excavated soil materials suitable for use as embankment fill shall be temporarily stockpiled for use as embankment fill. Excavated materials unsuitable for use as embankment fill shall be temporarily stockpiled. Upon completion of placement of the embankment fill, these unsuitable materials shall be placed in the embankment fill borrow area as part of the borrow area restoration or otherwise disposed of on-site as directed by the Contracting Officer. Rocks and boulders excavated from the borrow area which are not suitable for use as embankment fill shall remain the property of the Government and shall be stockpiled at a location designated by the Contracting Officer. During construction, cutoff trench excavation and backfill shall be performed in a manner and sequence that will provide proper drainage at all times. The cutoff trench excavation shall be kept free of water during installation of the GCL and geotextile, and until placement of the trench backfill is complete.

3.5 EMBANKMENT FILL

3.5.1 Preparation of Ground Surface for Embankment

3.5.1.1 General Requirements

Ground surface on which fill is to be placed shall be stripped of live, dead, or decayed vegetation, rubbish, debris, and other unsatisfactory material; plowed, disked, or otherwise broken up to a depth of 6 inches; pulverized; moistened or aerated as necessary; thoroughly mixed; and compacted to at least 90 percent laboratory maximum density. All areas to receive fill or riprap shall be free of standing water. Compaction shall be accomplished by sheepsfoot rollers, pneumatic-tired rollers, steel-wheeled rollers, vibratory compactors, or other approved equipment. The prepared ground surface shall be scarified and moistened or aerated as required just prior to placement of embankment materials to assure adequate bond between embankment material and the prepared ground surface.

3.5.1.2 Frozen Materials

Embankment fill shall not be placed on a foundation which contains frozen material, or which has been subjected to freeze-thaw action. This prohibition encompasses all foundation types, including the natural ground, all prepared subgrades and all layers of previously placed and compacted earth fill which become the foundations for successive layers of earth fill. All material that freezes or has been subjected to freeze-thaw action during the construction work, or during periods of temporary shutdowns, such as, but not limited to, nights, holidays, weekends, winter shutdowns, or earthwork operations, shall be removed to a depth that is acceptable to the Contracting Officer and replaced with new material. Alternatively, the material will be thawed, dried, reworked, and recompacted to the specified criteria before additional material is placed.

The Contracting Officer will determine when placement of fill shall cease due to cold weather. The Contracting Officer may elect to use average daily air temperatures, and/or physical observation of the soils for his determination. Embankment material shall not contain frozen clumps of soil, snow, or ice.

3.5.2 Backfill

Embankment backfill shall be placed in maximum 12 inch horizontal lifts and compacted to at least 90 percent laboratory maximum density. Ground surface on which backfill is to be placed shall be prepared as specified in paragraph PREPARATION OF GROUND SURFACE FOR EMBANKMENTS. Compaction requirements for backfill materials shall also conform to the applicable portions of the paragraph PREPARATION OF GROUND SURFACE FOR EMBANKMENT. Compaction shall be accomplished by sheepsfoot rollers, pneumatic-tired rollers, steel-wheeled rollers, vibratory compactors, or other approved equipment.

3.5.3 Testing

Testing shall be performed by an approved commercial testing laboratory. Field in-place density shall be determined in accordance with ASTM D 2922. ASTM D 2922 results in a wet unit weight of soil and ASTM D 3017 shall be used to determine the moisture content of the soil. The calibration curves furnished with the moisture gauges shall also be checked along with density calibration checks as described in ASTM D 3017; the calibration checks of both the density and moisture gauges shall be made at the beginning of a job on each different type of material encountered and at intervals as directed by the Contracting Officer. When test results indicate, as determined by the Contracting Officer, that compaction is not as specified, the material shall be removed, replaced and recompact to meet specification requirements. Tests on recompact areas shall be performed to determine conformance with specification requirements. Inspections and test results shall be certified by a professional engineer registered in the Commonwealth of Pennsylvania. These certifications shall state that the tests and observations were performed by or under the direct supervision of the engineer and that the results are representative of the materials or conditions being certified by the tests. The following number of tests, if performed at the appropriate time, will be the minimum acceptable for each type operation.

3.5.3.1 Optimum Moisture and Laboratory Maximum Density

Proctor tests shall be performed for each type material used as embankment fill to determine the optimum moisture and laboratory maximum density values. A minimum of two proctor tests shall be performed for the embankment fill.

3.5.3.2 In-place Densities

A minimum of three in-place nuclear density tests shall be performed per lift of embankment fill.

3.5.3.3 Check Tests on In-Place Densities

In-place densities shall be checked using ASTM D 1556 a minimum of two times during placement of the embankment fill; once in the first lift of embankment fill and once following the placement of approximately fifty percent of the embankment fill. Additional checks shall be performed as

requested by the Contracting Officer.

3.5.4 Finishing

The surface of embankment shall be finished to a smooth and compact surface in accordance with the lines, grades, and cross sections or elevations shown. The degree of finish for graded areas shall be within 0.1 foot of the grades and elevations indicated.

3.5.5 Subgrade and Embankment Protection

The embankment shall be kept shaped and drained. Proper drainage around the embankment shall be effectively maintained at all times. The finished subgrade shall not be disturbed by traffic or other operation and shall be protected and maintained by the Contractor in a satisfactory condition until the completion of the project. The storage or stockpiling of materials on the finished embankment shall not be permitted. No seeding of the embankment shall be performed until the embankment has been checked and approved by the Contracting Officer.

3.6 GCL Cover Soil Placement

GCL cover soil shall be placed in maximum 12 inch lifts. Nominal compaction of the cover soil shall be required. The GCL cover soil shall be compacted with one pass of the placement equipment. Care shall be taken not to damage the GCL and no equipment shall traffic on the GCL without at least 12 inches of cover soil in place.

3.7 TRENCH BACKFILL

Trench backfill shall be placed in maximum 24 inch thick loose lifts and compacted with the backhoe bucket. Placement of additional compaction equipment into the cutoff trench will not be required.

3.8 BORROW AREA

With the exception of suitable embankment fill materials stockpiled as part of the cutoff trench excavation activities, all embankment fill materials shall be obtained from within the embankment fill borrow area indicated as the Existing Waste Berm on the Contract Drawings. All borrow shall be obtained from within the Limit of Disturbance indicated on the Contract Drawings. No borrow activities shall be performed within ten feet of the existing piezometers located within the borrow area. Piezometers damaged or destroyed by the Contractor shall be replaced, to the satisfaction of the Contracting Officer, at the sole expense of the Contractor, prior to completion of the project. The maximum depth for excavation of borrow materials is three feet below the existing ground surface. Necessary clearing, grubbing, and satisfactory drainage of borrow pits and the disposal of debris thereon shall be considered related operations to the borrow operation. Soil materials excavated from the borrow area which are not suitable for use as embankment fill shall be temporarily stockpiled on-site and placed back within the borrow area at the completion of excavation activities. The borrow area shall be neatly trimmed and graded to drain after the excavation is completed. Slopes at any location within the restored borrow area shall not be steeper than 3H:1V. The Contractor shall ensure that borrow operations result in minimum detrimental effects on natural environmental conditions. Rocks and boulders excavated from the borrow area which are not suitable for use as embankment fill shall remain the property of the Government and shall be stockpiled at a location

designated by the Contracting Officer.

3.9 MEASUREMENT AND PAYMENT

3.9.1 Cutoff Trench Excavation

There will be no measurement or payment for cutoff trench excavation. All costs associated with excavation and disposal of these materials shall be included in the unit costs for cutoff trench backfill as indicated in this Section.

3.9.2 Cutoff Trench Backfill

The unit of measurement for cutoff trench backfill will be the cubic yard. The volume to be paid for will be the number of cubic yards calculated using the length and depth of trench shown on the Contract Drawings and a trench width of three feet. If the trench depth is limited to less than the 10 feet indicated on the Contract Drawings due to the presence of bedrock, the depth of the trench used for calculation of the volume for cutoff trench backfill may be revised accordingly by the Contracting Officer. Payment for the cutoff trench backfill will be made at the Contract Unit Price for Bid Item No. 5, "Cutoff Trench Excavation and Backfill," which shall constitute full compensation to the Contractor for all costs associated with the trench excavation, trench dewatering, separation and stockpiling and/or disposal of excavated materials, backfill of the trench with crushed stone backfill, and preparation of the Cutoff Trench Construction and GCL Installation Work Plan as required by this Section.

3.9.3 Access Road Improvements

There will be no measurement or payment for access road improvements. All costs associated with hauling and placing these materials, including the required submittals and testing shall be made at the Contract Lump Sum price for Bid Item No. 1, "Access Road Improvements".

3.9.4 Drainage and Dewatering

There will be no measurement for the diversion of flow as discussed in this section. All costs in connection with the drainage and dewatering, including development and approval of the Drainage and Dewatering Work Plan and coordination with the U.S. Army Corps of Engineers Hydrology and Hydraulics Branch, shall be included in the Contract Lump Sum Price for Bid Item No. 3, "Drainage and Dewatering".

3.9.5 Embankment Fill

The unit of measurement for embankment fill will be the cubic yard, computed by the average end area method from cross sections taken at 20 foot intervals along the length of the embankment. Three cross sections shall be taken in the weir spillway at the two top of slopes and at the bottom of the weir spillway. Prior to the start of placement of embankment fill, a survey will be performed to determine the existing ground surface elevations along the proposed embankment alignment. Another survey of the final embankment grades shall be performed following the completion of embankment fill placement to confirm the required embankment geometry. The survey shall be performed by a Pennsylvania licensed surveyor. The Contractor shall be responsible for all costs associated with the survey. The volume to be paid for will be the number of cubic yards calculated

using the pre-fill and post-fill placement surveys. The measurement will not include the volume of any fill placed prior to the taking of ground surface elevations of the undisturbed grade. Payment for the embankment fill will be made at the Contract Unit Price for Bid Item No. 6, "Embankment Fill," which shall constitute full compensation to the Contractor for all costs associated with the surveys, operation and restoration of the on-site embankment fill borrow source, screening, hauling and placement of the embankment fill, and drainage and dewatering of the fill/riprap placement area in accordance with the requirements of this Section, including the required submittals and testing.

3.9.6 GCL Cover Soil

The unit of measurement for GCL cover soil will be the cubic yard, computed by the average end area method from cross sections taken at 20 foot intervals along the length of the embankment. Three cross sections shall be taken in the weir spillway at the two top of slopes and at the bottom of the weir spillway. Prior to the start of placement of GCL cover soil, a survey will be performed to determine the existing embankment fill surface elevations along the proposed embankment alignment. Another survey of the final GCL cover soil grades shall be performed following the completion of GCL cover soil placement to confirm the required embankment geometry. The survey shall be performed by a Pennsylvania licensed surveyor. The Contractor shall be responsible for all costs associated with the survey. The volume to be paid for will be the number of cubic yards calculated using the pre-fill and post-fill placement surveys. The measurement will not include the volume of any fill placed prior to the taking of embankment fill elevations. Payment for the GCL cover soil will be made at the Contract Unit Price for Bid Item No. 7, "GCL Cover Soil" which shall constitute full compensation to the Contractor for all costs associated with the surveys, screening, hauling and placement of the GCL cover soil, and drainage and dewatering of the fill/riprap placement area in accordance with the requirements of this Section, including the required submittals and testing.

-- End of Section --

SECTION 02378

GEOSYNTHETICS

PART 1 GENERAL

1.1 SUMMARY

The work of this section shall include placement of the geosynthetic clay liner and the geotextile in the cutoff trench and placement of the geotextile on the embankment, beneath all riprap, as indicated on the Contract Drawings.

1.2 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by basic designation only.

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM D 123	(1993a) Standard Terminology Relating to Textiles
ASTM D 2216	(1996) Laboratory Determination of Water (Moisture) Content of Soil and Rock
ASTM D 3786	(1987) Hydraulic Bursting Strength of Knitted Goods and Nonwoven Fabrics - Diaphragm Bursting Strength Tester Method
ASTM D 4355	(1992) Deterioration of Geotextile from Exposure to Ultraviolet light and Water (Xenon-Arc Type Apparatus)
ASTM D 4491	(1992) Water Permeability of Geotextiles By Permittivity
ASTM D 4533	(1991) Trapezoid Tearing Strength of Geotextile
ASTM D 4632	(1991) Grab Breaking Load and Elongation of Geotextiles
ASTM D 4643	(1993) Determination of Water (Moisture) Content of Soil by the Microwave Oven Method
ASTM D 4751	(1993) Determining the Apparent Opening Size of a Geotextile
ASTM D 4833	(1988) Index Puncture Resistance of Geotextiles, Geomembranes, and Related Products

ASTM D 4873	(1988) Guide for Identification, Storage, and Handling of Geotextiles
ASTM D 5261	Test Method for Measuring Mass per Unit Area of Geotextile
ASTM D 5321	(1992) Determining the Coefficient of Soil and Geosynthetic or Geosynthetic and Geosynthetic Friction by the Direct Shear Method
ASTM D 5887	(1995) Measurement of Index Flux Through Saturated Geosynthetic Clay Liner Specimens Using a Flexible Wall Permeameter
ASTM D 5888	(1995) Storage and Handling of Geosynthetic Clay Liners
ASTM D 5889	(1995) Quality Control of Geosynthetic Clay Liners
ASTM D 5890	(1995) Swell Index of Clay Mineral Component of Geosynthetic Clay Liners
ASTM D 5891	(1995) Fluid Loss of Clay Component of Geosynthetic Clay Liners
ASTM D 5993	(1996) Measuring Mass Per Unit of Geosynthetic Clay Liners

1.3 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by, the office indicated prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved or reviewed by, the office indicated prior to commencing the particular task to which the submittal is associated.

SD-03 Product Data

GCL Properties; G,DO.

The GCL manufacturer's certified raw and roll material data sheets. The certification shall indicate that the GCL has been continuously inspected for broken needles using an in-line metal detector and all broken needles have been removed. The certified data sheets shall be attested to by a person having legal authority to bind the GCL manufacturing company. Certified test results, along with a sample of the GCL to be used on this project measuring a minimum of 12 inches by 12 inches, shall be submitted at least 5 working days prior to delivery of the GCL.

GCL Warranty

The GCL manufacturer's warranty statement.

SD-04 Samples

Geotextile; G,DO.

If requested by the Contracting Officer, the Contractor shall provide to the Government geotextile samples for testing to determine compliance with any or all of the requirements in this specification. When samples are to be provided, they shall be submitted a minimum of 14 days prior to the beginning of installation of the geotextile. A written certificate of compliance signed by a legally authorized official from the company shall be submitted, in duplicate, upon delivery of the geotextile. The certificate shall state that the geotextile shipped to the site meets the chemical requirements and exceeds the minimum average roll value listed in TABLE 1, MINIMUM PHYSICAL REQUIREMENTS FOR GEOTEXTILE. Upon request, the contractor shall supply quality control and quality assurance test results for the geotextile. All samples provided shall be from the same production lot as will be supplied for the contract, and shall be the full manufactured width of the geotextile by at least 10 feet long. Samples submitted for testing shall be identified by manufacturers lot designation. The manufacturer shall certify that the geotextile has been inspected using permanent on-line metal detectors and does not contain any needles.

SD-06 Test Reports

GCL Conformance Tests; G,DO.

Independent QC laboratory test results for the GCL including descriptions of equipment and test methods.

SD-07 Certificates

Geotextile; G,DO.

The Contractor shall submit a certification of the geotextile material from the manufacturer, along with a sample of the geotextile to be used on this project, measuring a minimum of 12 inches by 12 inches, at least 5 working days prior to delivery of the geotextile. The geotextile to be used shall be accepted on the basis of mill certificates or affidavits. The Contractor shall furnish the Contracting Officer, a mill certificate or affidavit signed by a legally authorized official from the company manufacturing the geotextile. The mill certificate or affidavit shall attest that the geotextile meets the chemical, physical and manufacturing requirements stated in this specification.

1.4 QUALIFICATIONS

The geosynthetic clay liner shall be the product of a GCL Manufacturer who has produced the proposed GCL using the same bentonite, geotextiles, sewing thread, and adhesive for at least 5 completed projects and shall have produced a minimum of 1,000,000 square feet of the proposed GCL.

1.5 SHIPMENT, HANDLING, AND STORAGE

1.5.1 Geotextile

Only approved geotextile rolls shall be delivered to the project site. All geotextile shall be labeled, shipped, stored, and handled in accordance

with ASTM D 4873. No hooks, tongs, or other sharp instruments shall be used for handling geotextile.

1.5.2 Geosynthetic Clay Liner

1.5.2.1 Delivery

Delivery, storage, and handling of GCL shall be in accordance with ASTM D 5888. The Contracting Officer shall be present during delivery and unloading of the GCL. Rolls shall be packaged in an opaque, waterproof, protective covering and wrapped around a central core. Tears in the packaging shall be repaired to restore a waterproof protective barrier around the GCL. Unloading of rolls from the delivery vehicles shall be done preventing damage to the GCL and its packaging.

1.5.2.2 Storage

Field storage shall be in flat dry areas where water cannot accumulate and the GCL rolls can be protected from damage. Storage of the rolls on blocks or pallets will not be allowed unless the GCL rolls are fully supported as approved by the Contracting Officer. Stacks of GCL rolls shall be no greater than three high. Rolls shall be covered with a water proof tarpaulin or plastic sheet if stored outdoors.

1.5.2.3 Handling

Rolls shall not be dragged, lifted by one end, or dropped to the ground from the delivery vehicle. A pipe or solid bar of sufficient strength to support the full weight of the roll without significant bending shall be used for all unloading and handling activities. The diameter of the pipe shall be small enough to be easily inserted through the core of the GCL roll. Chains shall be used to link the ends of the core pipe to the ends of a spreader bar. The spreader bar shall be wide enough to prevent the chains from rubbing against the ends of the GCL roll. Alternatively, a stinger bar protruding from the end of a forklift or other equipment may be used. The stinger bar shall be at least three-fourths the length of the core and also must be capable of supporting the full weight of the GCL without significant bending. If recommended by the manufacturer, a sling handling method utilizing appropriate loading straps may be used.

PART 2 PRODUCTS

2.1 MATERIALS

2.1.1 Geotextile

2.1.1.1 General

The geotextile shall be a non-woven, needlepunched pervious sheet of plastic yarn as defined by ASTM D 123. The geotextile shall have a minimum unit weight of 10 ounces per square yard as determined by ASTM D 5261 and shall equal or exceed the minimum average roll values listed in TABLE 1, MINIMUM PHYSICAL REQUIREMENTS FOR GEOTEXTILE. Strength values indicated in the table are for the weaker principal direction.

TABLE 1
MINIMUM PHYSICAL REQUIREMENTS FOR GEOTEXTILE

PROPERTY	UNITS	ACCEPTABLE VALUES	TEST METHOD
----------	-------	-------------------	-------------

TABLE 1
 MINIMUM PHYSICAL REQUIREMENTS FOR GEOTEXTILE

GRAB STRENGTH	lb	250	ASTM D 4632
GRAB ELONGATION	percent	50	ASTM D 4632
PUNCTURE	lb	165	ASTM D 4833
BURST STRENGTH	psi	550	ASTM D 3786
TRAPEZOID TEAR	lb	100	ASTM D 4533
PERMEABILITY	cm/sec	0.30	ASTM D 4491
FLOW RATE	gal/min/sq ft	85	ASTM D 4491
APPARENT OPENING SIZE	U.S. SIEVE	100	ASTM D 4751
PERMITTIVITY	sec ⁻¹	1.2	ASTM D 4491
ULTRAVIOLET DEGRADATION	Percent	70 AT 500 Hrs	ASTM D 4355

2.1.1.2 Geotextile Fiber

Fibers used in the manufacturing of the geotextile shall consist of a long-chain synthetic polymer composed of at least 85 percent by weight of polyolefins, polyesters, or polyamides. Stabilizers and/or inhibitors shall be added to the base polymer if necessary to make the filaments resistant to deterioration caused by ultraviolet light and heat exposure. Reclaimed or recycled fibers or polymer shall not be added to the formulation. Geotextile shall be formed into a network such that the filaments or yarns retain dimensional stability relative to each other, including the edges. The edges of the geotextile shall be finished to prevent the outer fiber from pulling away from the geotextile.

2.1.2 Securing Pins

The geotextile shall be secured to the embankment or foundation soil by pins to prevent movement prior to placement of revetment materials. Other appropriate means to prevent movement such as staples, sand bags, and stone could also be used. Securing pins shall be inserted through both strips of overlapped geotextile along the line passing through midpoints of the overlap. Securing pins shall be removed as placement of revetment materials are placed to prevent tearing of geotextile or enlarging holes. The maximum spacing between securing pins depends on the steepness of the embankment slope. The maximum pins spacing shall be equal to or less than the values listed in TABLE 2, MAXIMUM SPACING FOR SECURING PINS. When windy conditions prevail at the construction site, the number of pins should be increased upon the demand of the Contracting Officer. Terminal ends of the geotextile shall be anchored with key trench or apron at crest, toe of the slope and upstream and downstream limits of installation.

TABLE 2
 MAXIMUM SPACING FOR SECURING PINS

EMBANKMENT	SPACING, feet
STEEPER THAN 1V ON 3H	2
1V ON 3H TO 1V ON 4H	3
FLATTER THAN 1V ON 4H	5

2.1.1.3 Geosynthetic Clay Liner

The GCL shall be a manufactured product consisting of a sodium montmorillonite clay (bentonite) layer evenly distributed between two geotextiles. The GCL shall conform to the property requirements listed in Table 3 and shall be free of tears, holes, or other defects which may affect its serviceability. Encapsulating geotextiles shall be mechanically bonded together using a needle punch. The GCL shall be continuously inspected for broken needles using an in-line metal detector and broken needles shall be removed. The minimum manufactured GCL sheet width shall be 13.5 feet and the minimum manufactured GCL sheet length shall be 98 feet.

TABLE 3 - GCL PROPERTIES

	TEST METHOD	TEST VALUE
BENTONITE		
Swell Index Test, minimum	ASTM D 5890	24 mL
Fluid Loss, maximum	ASTM D 5891	18 mL
COMPOSITE		
Bentonite Mass/Unit Area, MARV, Notes 1 and 2	ASTM D 5993	0.75 lbs/sq foot
Tensile Strength, MARV	ASTM D 4632	90 lbs/in
Peak Mid-Plane Shear Strength (hydrated), minimum at a normal stress of 200 psf	ASTM D 5321	500 psf
Index Flux, maximum	ASTM D 5887	.00000001 cubic m/sq m/sec
Peel Strength, MARV	ASTM D 4632	15 lbs.

Note 1: MARV = minimum average roll value.

Note 2: Bentonite mass/unit area shall be computed at 0 percent moisture content. Moisture content shall be determined by ASTM D 2216 or ASTM D 4643. Bentonite mass/unit area is exclusive of glues added to the bentonite.

2.2 INSPECTIONS, VERIFICATIONS, AND TESTING

2.2.1 Geotextile Manufacturing and Sampling

The geotextile shall meet the requirements specified in TABLE 1, MINIMUM PHYSICAL REQUIREMENTS FOR GEOTEXTILE.

2.2.2 GCL Manufacturing Sampling and Testing

The GCL and its components shall be sampled and tested in accordance with the GCL manufacturer's approved QC manual. The GCL manufacturer's QC procedures shall be in accordance with ASTM D 5889. Test results not meeting the requirements specified in Table 3 shall result in the rejection of applicable rolls. The GCL manufacturer's QC manual shall describe procedures used to determine rejection of applicable rolls. As a minimum, rolls produced immediately prior to and immediately after the failed roll shall be tested for the same failed parameter. Testing shall continue until a minimum of three successive rolls on both sides of the original failing roll pass the failed parameter.

PART 3 EXECUTION

3.1 INSTALLATION OF THE GEOTEXTILE

3.1.1 General

The geotextile shall be placed in the manner and at the locations indicated on the Contract Drawings. At the time of installation, the geotextile shall be rejected if it has defects, rips, holes, flaws, deterioration or damage incurred during manufacture, transportation or storage.

3.1.2 Surface Preparation for the Geotextile

Surface on which the geotextile will be placed shall be prepared, to a relatively smooth surface condition, in accordance with the applicable portion of this specification and shall be free from obstruction, debris, depressions, erosion feature, or vegetation. Any irregularities will be removed so as to insure continuous, intimate contact of the geotextile with all the surface. Any loose material, soft or low density pockets of material, will be removed; erosion features such as rills, gullies etc. must be graded out of the surface before geotextile placement.

3.1.3 Placement of the Geotextile on the Embankment

The geotextile shall be placed with the long dimension perpendicular to the longitudinal centerline of the embankment and laid smooth and free of tension, stress, folds, wrinkles, or creases. Where possible, a continuous strip shall be placed from one side of the embankment to the other, so that there are no joints parallel to the embankment. If a continuous strip cannot be installed, the geotextile shall be anchored at the crest of the embankment in accordance with the manufacturer's recommendation. The placement procedure requires that the length of the unspliced geotextile be greater than the slope length. The Contractor shall adjust the actual

length of the geotextile used based on initial installation experience. The geotextile shall be placed to provide a minimum width of 24 inches of overlap for each joint. Temporary pinning of the geotextile to help hold it in place until the riprap is placed shall be allowed. The temporary pins shall be removed as the riprap is placed to relieve high tensile stress which may occur during placement of material on the geotextile. Trimming shall be performed in such a manner that the geotextile shall not be damaged in any way.

3.1.4 Placement of the Geotextile in Cutoff Trench

The geotextile shall be placed in the cutoff trench, as indicated on the Contract Drawings and in accordance with the approved Cutoff Trench Construction Work Plan, following placement of the GCL in the trench. A single panel shall be installed to extend the entire depth of the trench. Joining of panels in the horizontal direction shall not be allowed. The deployed geotextile panels shall lie as flat as practical against the GCL, with no wrinkles or folds. The geotextile panels shall be anchored as per manufactures recommendations.

3.1.5 Protection of the Geotextile

The geotextile shall be protected at all times during construction from contamination by surface runoff and any geotextile so contaminated shall be removed and replaced with uncontaminated geotextile. Any damage to the geotextile during its installation or during placement of riprap shall be replaced by the Contractor at no cost to the Government. The work shall be scheduled so that the covering of the geotextile with a layer of the specified material is accomplished within 2 calendar days after placement of the geotextile. Failure to comply shall require replacement of geotextile. The geotextile shall be protected from damage prior to and during the placement of riprap. Before placement of riprap, the Contractor shall demonstrate that the placement technique will not cause damage to the geotextile. In no case shall any type of equipment be allowed on the unprotected geotextile.

3.1.6 Geotextile Overlapping

The overlap of geotextile shall be 24 inches. Appropriate measures will be taken to insure required overlap exists after riprap placement.

3.2 INSTALLATION OF THE GCL

3.2.1 GCL Placement

The GCL shall be placed in the cutoff trench, as indicated on the Contract Drawings and in accordance with the approved Cutoff Trench Construction Work Plan. The side wall of the cutoff trench along which the GCL will be placed shall be smooth and free of vegetation, standing water, frozen material, and angular stones or other foreign matter that could damage the GCL. Prior to the placement of any portion of the GCL, the Contracting Officer shall review the side wall of the trench to confirm that it meets the requirements of this Section. The GCL shall be installed as soon as practical after approval of the trench side wall, but, the GCL shall not be deployed if any portion of the trench side wall is frozen. Immediately prior to deployment, the packaging shall be carefully removed without damaging the GCL. GCL which has been hydrated prior to the placement of the trench backfill shall be removed and replaced. Hydrated GCL is defined as material which has become soft as determined by squeezing the material

with finger pressure or material which has exhibited swelling. The GCL shall be placed along the sidewall of the trench using a method that supports the weight of the GCL along its entire length until the placement of the GCL cushion geotextile and trench backfill in that portion of the trench is complete. A single panel shall be installed to extend the entire depth of the trench. Joining of panels in the horizontal direction shall not be allowed. Dragging of GCL panels over the ground surface shall be minimized. Deployed GCL panels shall lie flat against the side wall, with no wrinkles or folds. The GCL shall be deployed on the embankment to elevation 1247.5 feet, except in the area behind the weir frame. In the area of the weir frame the GCL shall be sloped from elevation 1247.5 feet to elevation 1241.5 feet and held at that elevation along the entire length of the weir frame. All GCL in the vicinity of the weir frame shall be in contact with the weir frame for a minimum of 1 foot and attach to the weir frame as recommended by the manufacture. The GCL panels shall be anchored as per manufactures recommendations. GCL cover soil, as specified in Section 2300 shall be placed over the GCL as specified in Section 2300.

3.2.2 GCL Overlapping

Adjacent panels shall be positioned with the overlap recommended by the manufacturer, but not less than 12 inches after shrinkage for panel sides. Dirt or other foreign matter shall be removed from the overlap area. Construction adhesive or other methods, as recommended by the manufacturer and outlined in the GCL Installation Work Plan submitted and approved by the Government, shall be used for joining adjacent panels.

3.2.3 Protection

Only those GCL panels which can be placed and backfilled in the same day shall be unpackaged and installed.

3.2.4 Repairs

Holes or tears in GCL shall be repaired by placing a patch of GCL extending a minimum of 12 inches beyond the edges of the hole or tear on all sides. Bentonite mastic shall be applied in the overlap area. Patches shall be secured with a construction adhesive or other approved methods as recommended by the manufacturer.

3.3 MEASUREMENT AND PAYMENT

3.3.1 Embankment Geotextile

Installed embankment geotextile will be measured for payment in place to the nearest square feet of protected area as delineated on the Contract Drawings. Payment shall be made at the Contract Unit Price for Bid Item Number 8 "Embankment Geotextile," and shall constitute full compensation to the Contractor for providing all plant, labor, material, and equipment and performing all operations necessary for the complete and satisfactory installation of the geotextile. The following items are included in the Contract Unit Price for Embankment Geotextile and shall not be counted a second time in the process of determining the extent of geotextile placed: Material and associated equipment and operation used in laps or anchor trenches; and securing pins and associated material, equipment, and operations. No payment will be made for geotextiles replaced because of waste, contamination, damage, repair, or due to contractor fault or negligence.

3.3.2 Cutoff Trench Geotextile

Installed cutoff trench geotextile will be measured for payment in place to the nearest square feet. The installed area shall be calculated using the length and depth of the cutoff trench as delineated on the Contract Drawings. Payment shall be made at the Contract Unit Price for Bid Item Number 9 "Cutoff Trench Geotextile," and shall constitute full compensation to the Contractor for providing all plant, labor, material, and equipment and performing all operations necessary for the complete and satisfactory installation of the geotextile in the cutoff trench. The material and associated equipment and operation used in laps shall be included in the Contract Unit Price for Cutoff Trench Geotextile and shall not be counted a second time in the process of determining the extent of geotextile placed. No payment will be made for geotextile replaced because of waste, contamination, damage, repair, or due to contractor fault or negligence.

3.3.3 Geosynthetic Clay Liner

Installed GCL will be measured for payment in place to the nearest square feet. The installed area shall be calculated using the length and depth of the cutoff trench as delineated on the Contract Drawings, plus the length of GCL above the top of the trench, on the slope of the embankment, as delineated on the Contract Drawings. Payment shall be made at the Contract Unit Price for Bid Item Number 10 "Geosynthetic Clay Liner," and shall constitute full compensation to the Contractor for providing all plant, labor, material, and equipment and performing all operations necessary for the complete and satisfactory installation of the GCL. The material and associated equipment and operation used in laps and joining adjacent panels shall be included in the Contract Unit Price for Geosynthetic Clay Liner and shall not be counted a second time in the process of determining the extent of GCL placed. No payment will be made for GCL replaced because of waste, contamination, damage, repair, or due to contractor fault or negligence.

-- End of Section --

SECTION 02921

SEEDING

PART 1 GENERAL

1.1 SUMMARY

The work of this Section shall include the placement of seed and soil supplements to areas disturbed during construction, including, but not limited to, the embankment fill borrow area.

1.2 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by basic designation only.

AGRICULTURAL MARKETING SERVICE (AMS)

AMS-01 (Aug 95) Federal Seed Act Regulations Part 201

1.3 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by, the office indicated prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved or reviewed by, the office indicated prior to commencing the particular task to which the submittal is associated.

SD-01 Preconstruction Submittals

Equipment

A listing of equipment to be used for the seeding operation.

SD-03 Product Data

Equipment

Chemical Treatment Material

Manufacturer's literature including physical characteristics, application and installation instructions for equipment and chemical treatment material.

SD-06 Test Reports

Equipment Calibration

Certification of calibration tests conducted on the equipment used in the seeding operation.

SD-07 Certificates

Seed; G,COR. Fertilizer; G,COR.

Prior to the delivery of materials, certificates of compliance attesting that materials meet the specified requirements. Certified copies of the material certificates shall include the following:

- a. Seed. Classification, botanical name, common name, percent pure live seed, minimum percent germination and hard seed, maximum percent weed seed content, and date tested.
- b. Fertilizer. Chemical analysis and composition percent.

SD-11 Closeout Submittals

Quantity Check

Bag count or bulk weight measurements of material used compared with area covered to determine the application rate and quantity installed.

Maintenance Record

Maintenance work performed, grass repaired or reinstalled, diagnosis for unsatisfactory stand of grass plants.

1.4 INSPECTION AND STORAGE

1.4.1 Fertilizers

Fertilizers shall be delivered to the site in the original, unopened containers plainly marked with the chemical analysis of the product, or, if provided in bulk, a certificate guaranteeing the fertilizer analysis must accompany each delivery to the project.

1.4.2 Inspection

Seed shall be inspected upon arrival at the job site for conformity to species and quality. Seed that is wet, moldy, or bears a test date five months or older, shall be rejected. Unacceptable materials shall be removed from the job site.

1.4.3 Storage

Seed shall be stored in cool, dry location away from contaminants, as designated by the Contracting Officer.

PART 2 PRODUCTS

2.1 SEED

2.1.1 Seed Classification

State-approved seed of the latest season's crop shall be provided in original sealed packages bearing the producer's guaranteed analysis for percentages of mixture, purity, germination, hard seed, weed seed content,

and inert material. Labels shall be in conformance with AMS-01 and applicable state seed laws.

2.1.2 Seed Species and Mixtures

Temporary and permanent seed species and mixtures shall be proportioned by weight as follows:

Botanical Name	Common Name	Mixture Percent by Weight	Percent Pure Live Seed
Festuca elatior arundinacea	Tall Fescue, Kentucky 31	46	98
Festuca ovina var. durinuscula	Waldina Hard Fescue	33	98
Lolium pepenne	Ryegrass, Perennial	4	98
Festuca rubra	Red Fescue	17	98

2.1.3 Quality

Weed seed shall be a maximum one percent by weight of the total mixture.

2.1.4 Seed Mixing

The mixing of seed may be done by the seed supplier prior to delivery, or on site as directed.

2.1.5 Substitutions

Substitutions will not be allowed without written request and approval from the Contracting Officer.

2.2 FERTILIZER

The fertilizer analysis shall yield the following values in pounds of actual plant food per acre: 70 pounds nitrogen; 42 pounds available phosphoric acid; and 28 pounds water soluble potash. Fertilizer shall be controlled release commercial grade, free flowing, uniform in composition, and consist of a nitrogen-phosphorus-potassium ratio. The fertilizer shall be derived from sulphur coated urea, urea formaldehyde, plastic or polymer coated pills, or isobutylenediurea (IBDU). Fertilizer shall be balanced with the inclusion of trace minerals and micro-nutrients.

2.3 WATER

Water shall be the responsibility of the Contractor, unless otherwise noted. Water shall not contain elements toxic to plant life.

2.4 SURFACE EROSION CONTROL MATERIAL

Surface erosion control materials, if required, shall conform to the following:

2.4.1 Surface Erosion Control Blanket

Blanket shall be machine produced mat of wood excelsior formed from a web of interlocking wood fibers; covered on one side with either knitted straw blanket-like mat construction; covered with biodegradable plastic mesh; or interwoven biodegradable thread, plastic netting, or twisted kraft paper cord netting.

2.4.2 Surface Erosion Control Fabric

Fabric shall be knitted construction of polypropylene yarn with uniform mesh openings 3/4 to 1 inch square with strips of biodegradable paper. Filler paper strips shall have a minimum life of 6 months.

2.4.3 Erosion Control Material Anchors

Erosion control anchors shall be as recommended by the manufacturer.

PART 3 EXECUTION

3.1 SEEDING CONDITIONS

3.1.1 Seeding Conditions

Seeding operations shall be performed only during periods when beneficial results can be obtained. When drought, excessive moisture, or other unsatisfactory conditions prevail, the work shall be stopped when directed. When special conditions warrant a variance to the seeding operations, proposed alternate times shall be submitted for approval.

3.1.2 Equipment Calibration

Immediately prior to the commencement of seeding operations, calibration tests shall be conducted on the equipment to be used. These tests shall confirm that the equipment is operating within the manufacturer's specifications and will meet the specified criteria. The equipment shall be calibrated a minimum of once every day during the operation. The calibration test results shall be provided within 1 week of testing.

3.2 SITE PREPARATION

Soil on slopes up to a maximum 3-horizontal-to-1-vertical shall be tilled to a minimum 4 inch depth. Rototillers shall be used where soil conditions and length of slope permit. Drainage patterns shall be maintained as indicated on drawings. Areas compacted by construction operations shall be completely pulverized by tillage.

3.3 INSTALLATION

Prior to installing seed, any previously prepared surface compacted or damaged shall be reworked to meet the requirements of paragraph SITE PREPARATION. Seeding operations shall not take place when the wind velocity will prevent uniform seed distribution.

3.3.1 Installing Seed and Fertilizer

The seed and fertilizer shall be applied by mixing them in an aqueous solution. Seed shall be mixed to ensure broadcast at the rate of 65 pounds per acre. Fertilizer shall be applied according to the quantities of

actual plant food per acre required as specified in this Section. Seed and fertilizer shall be added to water and thoroughly mixed to meet the rates specified. The time period for the slurry to be held in the slurry shall be a maximum 24 hours. Slurry shall be uniformly applied under pressure over the entire area. The hydroseed area shall not be rolled.

3.3.2 Watering Seed

Watering shall be started immediately after completing the seeding of an area. Water shall be applied to supplement rainfall at a rate sufficient to ensure moist soil conditions to a minimum 1 inch depth. Run-off and puddling shall be prevented. Watering trucks shall not be driven over turf areas, unless otherwise directed. Watering of other adjacent areas or plant material shall be prevented.

3.4 SURFACE EROSION CONTROL

3.4.1 Surface Erosion Control Material

Surface erosion control materials shall be placed on all slopes 3H:1V or steeper. Surface erosion control material shall be installed in accordance with manufacturer's instructions. Placement of the material shall be accomplished without damage to installed material or without deviation to finished grade.

3.5 QUANTITY CHECK

For materials provided in bags, the empty bags shall be retained for recording the amount used. For materials provided in bulk, the weight certificates shall be retained as a record of the amount used. The amount of material used shall be compared with the total area covered to determine the rate of application used. Differences between the quantity applied and the quantity specified shall be adjusted as directed.

3.6 RESTORATION AND CLEAN UP

3.6.1 Restoration

Existing turf areas that have been damaged from the seeding operation shall be restored to original condition at Contractor's expense.

3.6.2 Clean Up

Excess and waste material shall be removed from the seeded areas and shall be disposed offsite.

3.7 PROTECTION OF INSTALLED AREAS

Immediately upon completion of the seeding operation in an area, the area shall be protected against traffic or other use by erecting barricades and providing signage as required, or as directed.

3.8 SEED ESTABLISHMENT PERIOD

3.8.1 Commencement

The seed establishment period to obtain a healthy stand of grass plants shall begin on the first day of work under this contract and shall end 3 months after the last day of the seeding operation. Written calendar time

period shall be furnished for the seed establishment period.

3.8.2 Satisfactory Stand of Grass Plants

Grass plants shall be evaluated for species and health when the grass plants are a minimum 1 inch high. A satisfactory stand of grass plants from the seeding operation for a field area shall be a minimum 10 grass plants per square foot. The total bare spots shall not exceed 2 percent of the total seeded area.

3.8.3 Maintenance During Establishment Period

Maintenance of the seeded areas shall include protecting embankments and ditches from surface erosion; maintaining erosion control materials; and protecting installed areas from traffic.

3.8.3.1 Repair or Reinstall

Unsatisfactory stand of grass plants shall be repaired or reinstalled, and eroded areas shall be repaired in accordance with paragraph SITE PREPARATION.

3.8.3.2 Maintenance Record

A record of each site visit shall be furnished, describing the maintenance work performed; areas repaired or reinstalled; and diagnosis for unsatisfactory stand of grass plants.

3.9 MEASUREMENT AND PAYMENT

There shall be no measurement or payment for work specified in this section and all costs in connection herewith shall be considered incidental to Bid Item No. 6, "Embankment Fill" as specified in Section 02300.

-- End of Section --

SECTION 03101

FORMWORK FOR CONCRETE

PART 1 GENERAL

1.1 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by basic designation only.

ACI INTERNATIONAL (ACI)

ACI 347R (1994) Guide for Formwork for Concrete

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM C 31 (1994) Making and Curing Concrete Test Specimens in the Field

ASTM C 39 (1993a) Compressive Strength of Cylindrical Concrete Specimens

ASTM C 1077 (1995a) Laboratories Testing Concrete and Concrete Aggregates for Use in Construction and Criteria for Laboratory Evaluation

DEPARTMENT OF COMMERCE (DOC)

DOC PS 1 (1983) Construction and Industrial Plywood

1.2 DESIGN REQUIREMENTS

The design, engineering, and construction of the formwork shall be the responsibility of the Contractor. The formwork shall be designed for anticipated live and dead loads and shall comply with the tolerances specified in Section 03307 CONCRETE FOR MINOR STRUCTURES, paragraph Construction Tolerances.

1.3 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by, the office indicated prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved or reviewed by, the office indicated prior to commencing the particular task to which the submittal is associated.

SD-02 Shop Drawings

Shop Drawings; G,COR.

Drawings and design computations for all formwork required shall be submitted at least 10 working days either before shop or field fabrication or before delivery of prefabricated forms.

SD-03 Product Data

Materials

Manufacturer's literature shall be submitted for plywood, concrete form hard board, form accessories, prefabricated forms, form coating and form-lining materials.

SD-06 Test Reports

Inspection.

The Contractor shall submit field inspection reports for concrete forms and embedded items.

Formwork Not Supporting the Weight of Concrete; G,COR.

If forms are to be removed in less than 24 hours on formwork not supporting the weight of concrete, the evaluation and results of the control cylinder tests shall be submitted to and approved before the forms are removed.

1.4 SHOP DRAWINGS

The shop drawings and data submitted shall include the type, size, quantity, and strength of all materials of which the forms are made, the plan for jointing of facing panels, details affecting the appearance, and the assumed design values and loading conditions. Drawings and design computations shall be prepared under the supervision of a professional engineer registered in the State of Pennsylvania and shall include method of supporting formwork.

PART 2 PRODUCTS

2.1 MATERIALS

2.1.1 Forms and Form Liners

Forms and form liners shall be fabricated with facing materials that will produce a finish meeting the specified construction tolerance requirements and the following surface classifications as defined in ACI 347R.

2.1.1.1 Class "A" Finish

This class of finish shall apply to the face of the weir frame on which the weir plate will be mounted. The form facing material shall be composed of new, well-matched tongue-and-groove lumber or new plywood panels conforming to DOC PS 1, Grade B-B concrete form, Class I.

2.1.1.2 Class "C" Finish

This class of finish shall apply to all surfaces of the weir frame except

as otherwise specified. The form facing may be either tongue-and-groove lumber, plywood, concrete form hard board or steel. Wood form facing for curved or warped surfaces shall be composed of splines of lumber which can be bent to the required shape without splitting or cracking.

2.1.2 Form Coating

Form coating shall be commercial formulation that will not bond with, stain, cause deterioration, or any other damage to concrete surfaces. The coating shall not impair subsequent treatment of concrete surfaces depending upon bond or adhesion nor impede the wetting of surfaces to be cured with water or curing compounds. If special form liners are to be used, the Contractor shall follow the recommendation of the form coating manufacturer.

2.2 ACCESSORIES

Ties and other similar form accessories to be partially or wholly embedded in the concrete shall be of a commercially manufactured type. After the ends or end fasteners have been removed, the embedded portion of metal ties shall terminate not less than 2 inches from any concrete surface either exposed to view or exposed to water. Plastic snap ties may be used in locations where the surface will not be exposed to view. Form ties shall be constructed so that the ends or end fasteners can be removed without spalling the concrete.

PART 3 EXECUTION

3.1 INSTALLATION

3.1.1 Form Construction

Forms shall be constructed true to the structural design and required alignment. The form surface and joints shall be mortar tight and supported to achieve safe performance during construction, concrete placement, and form removal. The Contractor shall continuously monitor the alignment and stability of the forms during all phases to assure the finished product will meet the required surface class specified in paragraph FORMS AND FORM LINERS and tolerances specified in paragraph DESIGN REQUIREMENTS. Failure of any supporting surface either due to surface texture, deflection or form collapse shall be the responsibility of the Contractor as will the replacement or correction of unsatisfactory surfaces. When forms for continuous surfaces are placed in successive units, care shall be taken to fit the forms over the completed surface to obtain accurate alignment of the surface and to prevent leakage of mortar. Forms shall not be re-used if there is any evidence of defects which would impair the quality of the resulting concrete surface. All surfaces of used forms shall be cleaned of mortar and any other foreign material before reuse.

3.1.2 Chamfering

Exposed joints, edges and external corners shall be chamfered, where indicated on the Contract Drawings, by molding placed in the forms. Chamfered joints shall not be permitted where earth or rock fill is placed in contact with concrete surfaces. Chamfered joints shall be terminated twelve inches outside the limit of the earth or rock fill so that the end of the chamfers will be clearly visible.

3.1.3 Coating

Forms for exposed or painted surfaces shall be coated with form oil or a form-release agent before the form or reinforcement is placed in final position. The coating shall be used as recommended in the manufacturer's instructions. Forms for unexposed surfaces may be wet with water in lieu of coating immediately before placing concrete, except that, in cold weather when freezing temperatures are anticipated, coating shall be mandatory. Surplus coating on form surfaces and coating on reinforcing steel and construction joints shall be removed before placing concrete.

3.2 FORM REMOVAL

Forms shall not be removed without approval. The minimal time required for concrete to reach a strength adequate for removal of formwork without risking the safety of workers or the quality of the concrete depends on a number of factors including, but not limited to, ambient temperature, concrete lift heights, type and amount of concrete admixture, and type and amount of cementitious material in the concrete. It is the responsibility of the Contractor to consider all applicable factors and leave the forms in place until it is safe to remove them. In any case forms shall not be removed unless the minimum time and minimum compressive strength requirements below are met, except as otherwise directed or specifically authorized. When conditions are such as to justify the requirement, forms will be required to remain in place for a longer period. All removal shall be accomplished in a manner which will prevent damage to the concrete and ensure the complete safety of the structure. Where forms support more than one element, the forms shall not be removed until the form removal criteria are met by all supported elements. Form removal shall be scheduled so that all necessary repairs can be performed as specified in Section 03307 CONCRETE FOR MINOR STRUCTURES, paragraph FINISHING. Evidence that concrete has gained sufficient strength to permit removal of forms shall be determined by tests on control cylinders. All control cylinders shall be stored in the structure or as near the structure as possible so they receive the same curing conditions and protection methods as given those portions of the structure they represent. Control cylinders shall be removed from the molds at an age of no more than 24 hours. All control cylinders shall be prepared and tested in accordance with ASTM C 31 and ASTM C 39 at the expense of the Contractor by an independent laboratory that complies with ASTM C 1077 and shall be tested within 4 hours after removal from the site.

3.2.1 Formwork Not Supporting Weight of Concrete

Formwork for walls, columns, sides of beams, gravity structures, and other vertical type formwork not supporting the weight of concrete shall not be removed in less than 24 hours after concrete placement is completed.

3.2.2 Formwork Supporting Weight of Concrete

Formwork supporting weight of concrete and shoring shall not be removed until structural members have acquired sufficient strength to safely support their own weight and any construction or other superimposed loads to which the supported concrete may be subjected. As a minimum, forms shall be left in place until control concrete test cylinders indicate evidence the concrete has attained at least 75 percent of the compressive strength required for the structure in accordance with the quality and location requirements of Section 03307 CONCRETE FOR MINOR STRUCTURES, paragraph DESIGN AND PERFORMANCE REQUIREMENTS.

3.3 INSPECTION

Forms and embedded items shall be inspected in sufficient time prior to each concrete placement by the Contractor in order to certify to the Contracting Officer that they are ready to receive concrete. The results of each inspection shall be reported in writing.

3.4 MEASUREMENT AND PAYMENT

No measurement shall be made for design, engineering and construction of the concrete formwork as specified in this Section. Payment for the design, engineering and construction of the concrete formwork shall be incidental to the Contract Lump Sum Price for Bid Item No. 11, "Concrete Weir Frame" This price shall be full compensation for furnishing all material, labor, equipment, supplies and incidentals necessary to complete the work as specified in this Section.

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SECTION 03201

STEEL BARS FOR CONCRETE REINFORCEMENT

PART 1 GENERAL

1.1 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by basic designation only.

ACI INTERNATIONAL (ACI)

ACI 315 (1995) ACI Detailing Manual: Section
Details and Detailing of Concrete
Reinforcement

ACI 318/318R (1995) Building Code Requirements for
Reinforced Concrete

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM A 615/A 615M (1996a) Deformed and Plain Billet-Steel
Bars for Concrete Reinforcement

AMERICAN WELDING SOCIETY (AWS)

AWS D1.4 (1992) Structural Welding Code -
Reinforcing Steel

1.2 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by, the office indicated prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved or reviewed by, the office indicated prior to commencing the particular task to which the submittal is associated.

SD-02 Shop Drawings

Fabrication and Placement; G,COR.

The Contractor shall submit shop drawings which include: reinforcement steel placement drawings; reinforcement steel schedules showing quantity, size, shape, dimensions, weight per foot, total weights and bending details; and details of bar supports showing types, sizes, spacing and sequence.

SD-06 Test Reports

Materials Tests, Inspections, and Verifications; G,DO

Certified test reports of reinforcement steel showing that the steel complies with the applicable specifications shall be furnished for each steel shipment and identified with specific lots prior to placement. Three copies of the heat analyses shall be provided for each lot of steel furnished and the Contractor shall certify that the steel conforms to the heat analyses.

SD-11 Closeout Submittals

Material; G,CO.

A system of identification which shows the disposition of specific lots of approved materials in the work shall be established and submitted before completion of the contract.

PART 2 PRODUCTS

2.1 MATERIALS

Material shall conform to the following requirements.

2.1.1 Steel Bars

Steel bars shall comply with the requirements of ASTM A 615/A 615M, Grade 60, deformed, of the sizes and lengths shown.

2.1.2 Accessories

2.1.2.1 Bar Supports

Bar supports shall comply with the requirements of ACI 315. Supports for bars in concrete with formed surfaces exposed to view or to be painted shall be stainless steel or precast concrete supports. Precast concrete supports shall be wedged-shaped, not larger than 3-1/2 by 3-1/2 inches, of thickness equal to that indicated for concrete cover and have an embedded hooked tie-wire for anchorage.

2.1.2.2 Wire Ties

Wire ties shall be 16 gage or heavier black annealed wire.

PART 3 EXECUTION

3.1 FABRICATION AND PLACEMENT

Reinforcement steel and accessories shall be fabricated and placed as specified and shown on approved shop drawings. Fabrication and placement details of steel and accessories not specified or shown shall be in accordance with ACI 315 and ACI 318/318R or as directed. Steel shall be fabricated to shapes and dimensions shown, placed where indicated within specified tolerances and adequately supported during concrete placement. At the time of concrete placement all steel shall be free from loose, flaky rust, scale (except tight mill scale), mud, oil, grease or any other coating that might reduce the bond with the concrete.

3.1.1 Hooks and Bends

Steel bars shall be mill or field-bent. All steel shall be bent cold unless authorized. No steel bars shall be bent after being partially embedded in concrete unless indicated or authorized.

3.1.2 Welding

Welding of steel bars will be permitted only where indicated or authorized. Welding shall be performed in accordance with AWS D1.4 except where otherwise specified or indicated.

3.1.3 Placing Tolerances

3.1.3.1 Spacing

The spacing between adjacent bars and the distance between layers of bars may not vary from the indicated position by more than one bar diameter nor more than 1 inch.

3.1.3.2 Concrete Cover

The minimum concrete cover of main reinforcement steel bars shall be as shown on the Contract Drawings. The allowable variation from the minimum cover shown on the Contract Drawings shall be as follows:

MINIMUM COVER SHOWN	VARIATION
6 inch	plus 1/2 inch
4 inch	plus 3/8 inch
3 inch	plus 3/8 inch
2 inch	plus 1/4 inch
1-1/2 inch	plus 1/4 inch
1 inch	plus 1/8 inch
3/4 inch	plus 1/8 inch

3.1.4 Splicing

Splices in steel bars shall be made only as required. Bars may be spliced at alternate or additional locations at no additional cost to the Government subject to approval.

3.1.4.1 Lap Splices

Lap splices shall be used only for bars smaller than size 14 and welded wire fabric. Lapped bars may be placed in contact and securely tied or spaced transversely apart to permit the embedment of the entire surface of each bar in concrete. Lapped bars shall not be spaced farther apart than 1/5 the required length of lap or 6 inches.

3.2 MEASUREMENT AND PAYMENT

No measurement shall be made for furnishing and placing deformed steel bars for concrete reinforcement as specified in this Section. Payment for furnishing and placing deformed steel bars shall be incidental to the Contract Lump Sum Price for Bid Item No. 11, "Concrete Weir Frame" This price shall be full compensation for furnishing all material, labor, equipment, supplies and incidentals necessary to complete the work as specified in this Section.

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SECTION 03307

CONCRETE FOR MINOR STRUCTURES

PART 1 GENERAL

1.1 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by basic designation only.

ACI INTERNATIONAL (ACI)

- | | |
|--------------|---|
| ACI 308 | (1992) Standard Practice for Curing Concrete |
| ACI 318/318R | (1995) Building Code Requirements for Reinforced Concrete |

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

- | | |
|------------|--|
| ASTM C 31 | (1994) Making and Curing Concrete Test Specimens in the Field |
| ASTM C 33 | (1993) Concrete Aggregate |
| ASTM C 39 | (1993a) Compressive Strength of Cylindrical Concrete Specimens |
| ASTM C 94 | (1994) Ready-Mixed Concrete |
| ASTM C 143 | (1990a) Slump of Hydraulic Cement Concrete |
| ASTM C 150 | (1995) Portland Cement |
| ASTM C 171 | (1992) Sheet Materials for Curing Concrete |
| ASTM C 172 | (1990) Sampling Freshly Mixed Concrete |
| ASTM C 231 | (1991b) Air Content of Freshly Mixed Concrete by the Pressure Method |
| ASTM C 260 | (1994) Air-Entraining Admixtures for Concrete |
| ASTM C 309 | (1994) Liquid Membrane-Forming Compounds for Curing Concrete |
| ASTM C 618 | (1994a) Coal Fly Ash and Raw or Calcined Natural Pozzolan for Use as a Mineral Admixture in Portland Cement Concrete |
| ASTM C 685 | (1994) Concrete Made by Volumetric Batching and Continuous Mixing |
| ASTM D 75 | (1987; R 1992) Sampling Aggregates |

CORPS OF ENGINEERS (COE)

COE CRD-C 400

(1963) Requirements for Water for Use in
Mixing or Curing Concrete

1.2 DESIGN AND PERFORMANCE REQUIREMENTS

The Government will maintain the option to sample and test aggregates and concrete to determine compliance with the specifications. The Contractor shall provide facilities and labor as may be necessary to assist the Government in procurement of representative test samples. Samples of aggregates will be obtained at the point of batching in accordance with ASTM D 75. Concrete will be sampled in accordance with ASTM C 172. Slump and air content will be determined in accordance with ASTM C 143 and ASTM C 231, respectively, when cylinders are molded. Compression test specimens will be made, cured, and transported in accordance with ASTM C 31. Compression test specimens will be tested in accordance with ASTM C 39. Samples for strength tests will be taken once every truck or, if on-site batching is used, every 2 cubic yards. A minimum of four specimens will be made from each sample; two will be tested at 28 days for acceptance, and one will be tested at 7 days for information.

1.2.1 Strength

Acceptance test results will be the average strengths of two specimens tested at 28 days. The strength of the concrete will be considered satisfactory so long as the average of three consecutive acceptance test results equal or exceed the specified compressive strength, f'c, and no individual acceptance test result falls below f'c by more than 500 psi.

1.2.2 Construction Tolerances

Construction tolerances shall be in accordance with Section 03101 of this Specification.

1.2.3 Concrete Mixture Proportions

Concrete mixture proportions shall be the responsibility of the Contractor. Mixture proportions shall include the dry weights of cementitious material(s); the nominal maximum size of the coarse aggregate; the specific gravities, absorptions, and saturated surface-dry weights of fine and coarse aggregates; the quantities, types, and names of admixtures; and quantity of water per cubic yard of concrete. All materials included in the mixture proportions shall be of the same type and from the same source as will be used on the project. Specified compressive strength f'c shall be 4,000 psi at 28 days. The maximum nominal size coarse aggregate shall be 3/4 inch, in accordance with ACI 318/318R. The air content shall be between 4.5 and 7.5 percent. The slump shall be between 2 and 3 inches. The maximum water cement ratio shall be 0.45.

1.3 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by, the office indicated prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved or reviewed by, the office indicated prior to commencing the particular task to which the submittal is associated.

SD-03 Product Data

Air-Entraining Admixture; G,DO. Curing Materials; G,DO.

Manufacturer's literature available from suppliers which demonstrates compliance with applicable specifications for the above materials.

Batching and Mixing Equipment; G COR.

Batching and mixing equipment will be accepted on the basis of manufacturer's data which demonstrates compliance with the applicable specifications.

Conveying and Placing Concrete; G COR.

The methods and equipment for transporting, handling, depositing, and consolidating the concrete shall be submitted prior to concrete placement.

SD-06 Test Reports

Aggregates; G,DO.

Aggregates will be accepted on the basis of certificates of compliance and test reports that show the material(s) meets the quality and grading requirements of the specifications under which it is furnished.

Concrete Mixture Proportions; G,DO.

Ten days prior to placement of concrete, the contractor shall submit the mixture proportions that will produce concrete of the quality required. Applicable test reports shall be submitted to verify that the concrete mixture proportions selected will produce concrete of the quality specified.

Testing Results; G,COR.

Within one week of a concrete pour, three copies of the results of the tests and inspections conducted at the project site shall be submitted. Three copies of the results of the strength testing shall be submitted within one week of conclusion of the physical tests.

SD-07 Certificates

Cementitious Materials; G,COR.

Certificates of compliance attesting that the concrete materials meet the requirements of the specifications shall be submitted in accordance with the Special Clause "CERTIFICATES OF COMPLIANCE". Cementitious material will be accepted on the basis of a manufacturer's certificate of compliance, accompanied by mill test reports that the material(s) meet the requirements of the specification under which it is furnished.

PART 2 PRODUCTS

2.1 MATERIALS

2.1.1 Cementitious Materials

Cementitious materials shall conform to the appropriate specifications listed:

2.1.1.1 Portland Cement

ASTM C 150, Type II or IIA.

2.1.1.2 Pozzolan

Pozzolan shall conform to ASTM C 618, Class C or F, including requirements of Tables 1A and 2A.

2.1.2 Aggregates

Aggregates shall meet the quality and grading requirements of ASTM C 33 Class Designations 4M or better.

2.1.3 Admixtures

Admixtures to be used, when required or approved, shall comply with the appropriate specification listed. Chemical admixtures that have been in storage at the project site for longer than 6 months or that have been subjected to freezing shall be retested at the expense of the contractor at the request of the Contracting Officer and shall be rejected if test results are not satisfactory.

2.1.3.1 Air-Entraining Admixture

Air-entraining admixture shall meet the requirements of ASTM C 260.

2.1.4 Water

Water for mixing and curing shall be fresh, clean, potable, and free from injurious amounts of oil, acid, salt, or alkali, except that unpotable water may be used if it meets the requirements of COE CRD-C 400.

2.1.5 Curing Materials

Curing materials shall conform to the following requirements.

2.1.5.1 Impervious Sheet Materials

Impervious sheet materials, ASTM C 171, type optional, except polyethylene film, if used, shall be white opaque.

2.1.5.2 Membrane-Forming Curing Compound

ASTM C 309, Type 1, Class B.

PART 3 EXECUTION

3.1 PREPARATION

3.1.1 General

Snow, ice, standing or flowing water, loose particles, debris, and foreign matter shall have been removed from excavation prior to concrete placement.

Earth foundations shall be satisfactorily compacted. Spare vibrators shall be available. The entire preparation shall be accepted by the Contracting Officer prior to placing.

3.1.2 Embedded Items

Reinforcement shall be secured in place. Internal ties shall be arranged so that when the forms are removed all metal will be not less than 2 inches from concrete surfaces permanently exposed to view or exposed to water on the finished structures. Embedded items shall be free of oil and other foreign matters such as loose coatings or rust, paint, and scale. The embedding of wood in concrete will be permitted only when specifically authorized or directed. All equipment needed to place, consolidate, protect, and cure the concrete shall be at the placement site and in good operating condition.

3.1.3 Formwork Installation

Formwork fabrication shall have been completed in accordance with Section 03101 of this Specification.

3.1.4 Production of Concrete

3.1.4.1 Ready-Mixed Concrete

Ready-mixed concrete shall conform to ASTM C 94 except as otherwise specified.

3.1.4.2 Concrete Made by Volumetric Batching and Continuous Mixing

Concrete made by volumetric batching and continuous mixing shall conform to ASTM C 685.

3.1.4.3 Batching and Mixing Equipment

The contractor shall have the option of using an on-site batching and mixing facility. The facility shall provide sufficient batching and mixing equipment capacity to prevent cold joints. The method of measuring materials, batching operation, and mixer shall be submitted for review.

3.2 CONVEYING AND PLACING CONCRETE

Conveying and placing concrete shall conform to the following requirements.

3.2.1 General

Concrete placement shall not be permitted when weather conditions prevent proper placement and consolidation without approval. When concrete is mixed and/or transported by a truck mixer, the concrete shall be delivered to the site of the work and discharge shall be completed within 1-1/2 hours. Concrete shall be conveyed from the mixer to the forms as rapidly as practicable by methods which prevent segregation or loss of ingredients.

Concrete shall be in place and consolidated within 15 minutes after discharge from the mixer. Concrete shall be deposited as close as possible to its final position in the forms and be so regulated that it may be

effectively consolidated in horizontal layers 18 inches or less in thickness with a minimum of lateral movement. The placement shall be carried on at such a rate that the formation of cold joints will be prevented.

3.2.2 Consolidation

Each layer of concrete shall be consolidated by internal vibrating equipment. Internal vibration shall be systematically accomplished by inserting the vibrator through the fresh concrete in the layer below at a uniform spacing over the entire area of placement. The distance between insertions shall be approximately 1.5 times the radius of action of the vibrator and overlay the adjacent, just-vibrated area by a few inches. The vibrator shall penetrate rapidly to the bottom of the layer and at least 6 inches into the layer below, if such a layer exists. It shall be held stationary until the concrete is consolidated and then withdrawn slowly at the rate of about 3 inches per second.

3.2.3 Cold-Weather Requirements

No concrete placement shall be made when the ambient temperature is below 35 degrees F or if the ambient temperature is below 40 degrees F and falling. Suitable covering and other means as approved shall be provided for maintaining the concrete at a temperature of at least 50 degrees F for not less than 72 hours after placing and at a temperature above freezing for the remainder of the curing period. Salt, chemicals, or other foreign materials shall not be mixed with the concrete to prevent freezing. Any concrete damaged by freezing shall be removed and replaced at the expense of the contractor.

3.2.4 Hot-Weather Requirements

When the rate of evaporation of surface moisture, as determined by use of Figure 1 of ACI 308, is expected to exceed 0.2 pound per square foot per hour, provisions for windbreaks, shading, fog spraying, or covering with a light-colored material shall be made in advance of placement, and such protective measures shall be taken as quickly as finishing operations will allow.

3.3 FORM REMOVAL

Form removal shall be in accordance with Section 03101 of this Specification.

3.4 FINISHING

3.4.1 General

No finishing or repair will be done when either the concrete or the ambient temperature is below 50 degrees F.

3.4.2 Finishing Formed Surfaces

All fins and loose materials shall be removed, and surface defects including tie holes shall be filled. All honeycomb areas and other defects shall be repaired. All unsound concrete shall be removed from areas to be repaired. Surface defects greater than 1/2 inch in diameter and holes left by removal of tie rods in all surfaces not to receive additional concrete shall be reamed or chipped and filled with dry-pack mortar. The prepared

area shall be brush-coated with an approved epoxy resin or latex bonding compound or with a neat cement grout after dampening and filled with mortar or concrete. The cement used in mortar or concrete for repairs to all surfaces permanently exposed to view shall be a blend of portland cement and white cement so that the final color when cured will be the same as adjacent concrete.

3.4.3 Finishing Unformed Surfaces

All unformed surfaces that are not to be covered by additional concrete or backfill shall be float finished to elevations shown, unless otherwise specified. Surfaces to receive additional concrete or backfill shall be brought to the elevations shown and left as a true and regular surface. Exterior surfaces shall be sloped for drainage unless otherwise shown. Joints shall be carefully made with a jointing tool. Unformed surfaces shall be finished to a tolerance of 5/16 inch for a trowel finish as determined by a 10 foot straightedge placed on surfaces shown on the plans to be level or having a constant slope. Finishing shall not be performed while there is excess moisture or bleeding water on the surface. No water or cement shall be added to the surface during finishing.

3.4.3.1 Float Finish

Surfaces to be float finished shall be screeded and darbied or bullfloated to eliminate the ridges and to fill in the voids left by the screed. In addition, the darby or bullfloat shall fill all surface voids and only slightly embed the coarse aggregate below the surface of the fresh concrete. When the water sheen disappears and the concrete will support a person's weight without deep imprint, floating should be completed. Floating should embed large aggregates just beneath the surface, remove slight imperfections, humps, and voids to produce a plane surface, compact the concrete, and consolidate mortar at the surface.

3.4.3.2 Trowel Finish

A trowel finish shall be applied to the top surface of the concrete weir frame. Trowelling shall be done immediately following floating to provide a smooth, even, dense finish free from blemishes including trowel marks. Finished surfaces shall be protected from damage during the construction period.

3.5 CURING AND PROTECTION

Beginning immediately after placement and continuing for at least 7 days, all concrete shall be cured and protected from premature drying, extremes in temperature, rapid temperature change, freezing, mechanical damage, and exposure to rain or flowing water. All materials and equipment needed for adequate curing and protection shall be available and at the site of the placement prior to the start of concrete placement. Preservation of moisture for concrete surfaces not in contact with forms shall be accomplished by one of the following methods:

- a. Application of absorptive mats or fabrics kept continuously wet.
- b. Application of impervious sheet material conforming to ASTM C 171.
- c. Application of membrane-forming curing compound conforming to ASTM C 309, Type 1-D, on surfaces permanently exposed to view and Type 2 on other surfaces shall be accomplished in accordance with manufacturer's

instructions.

The preservation of moisture for concrete surfaces placed against wooden forms shall be accomplished by keeping the forms continuously wet for 7 days. If forms are removed prior to end of the required curing period, other curing methods shall be used for the balance of the curing period. During the period of protection removal, the temperature of the air in contact with the concrete shall not be allowed to drop more than 25 degrees F within a 24 hour period.

3.6 TESTS AND INSPECTIONS

3.6.1 General

The individuals who sample and test concrete as required in this specification shall have demonstrated a knowledge and ability to perform the necessary test procedures equivalent to the ACI minimum guidelines for certification of Concrete Field Testing Technicians, Grade I.

3.6.2 Inspection Details

3.6.2.1 Preparations for Placing

Forms shall be inspected in sufficient time prior to each concrete placement by the Contractor to certify that it is ready to receive concrete.

3.6.2.2 Air Content

Samples shall be obtained in accordance with ASTM C 172 and tested in accordance with ASTM C 231.

3.6.2.3 Consolidation and Protection

The Contractor shall ensure that the concrete is properly consolidated, finished, protected, and cured.

3.6.3 Action Required

3.6.3.1 Placing

The placing foreman shall not permit placing to begin until he has verified that an adequate number of acceptable vibrators, which are in working order and have competent operators, are available. Placing shall not be continued if any placed layer is inadequately consolidated.

3.6.3.2 Air Content

Whenever a test result is outside the specification limits, the concrete shall not be delivered to the forms and an adjustment shall be made to the dosage of the air-entrainment admixture.

3.6.3.3 Slump

Whenever a test result is outside the specification limits, the concrete shall not be delivered to the forms and an adjustment should be made in the batch weights of water and fine aggregate. The adjustments are to be made so that the water-cement ratio does not exceed that specified in the submitted concrete mixture proportion.

3.6.4 Reports

The results of all tests and inspections conducted at the project site shall be reported informally at the end of the pour and in writing within one week following the pour.

3.7 MEASUREMENT AND PAYMENT

There will be no measurement for the work performed in this Section. All costs in connection with the placement of concrete for the weir frame shall be included in the Contract Lump Sum Price for Bid Item No. 11, "Concrete Weir Frame." Payment shall include full compensation to the Contractor for all costs associated with the design and placement of formwork, steel reinforcement and the concrete for the weir frame.

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK

SECTION 10050

METAL WEIR AND ACCESSORIES

PART 1 GENERAL

1.1 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to in the text by basic designation only.

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM D 1056 (1998) Specification for Flexible Cellular Materials - Sponge or Expanded Rubber

ASTM F 593 (1998) Specification for Stainless Steel Bolts, Hex Cap Screws, and Studs

1.2 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

NOTE: Any submittals classified as "SD-01 Preconstruction Submittals" are submittals required to be submitted to, and approved by, the office indicated prior to mobilization to the contract work site. All other submittals, classified as "SD-02" through "SD-11," shall be submitted to, and approved or reviewed by, the office indicated prior to commencing the particular task to which the submittal is associated.

SD-02 Shop Drawings

Shop Drawings; G,DO.

Shop drawings showing complete fabrication details of v-notch weir plate and depth gauge.

SD-03 Product Data

Injection Adhesive Anchors; G,DO.

Manufacturer's literature which demonstrates compliance with this Specification and provides manufacturer's installation instructions.

1.3 DELIVERY, STORAGE, AND HANDLING

V-notched weir plate shall be shipped to the site and stored in a manner to prevent damage to the fabrication prior to installation in the finished work.

PART 2 PRODUCTS

2.1 MANUFACTURED PRODUCTS

2.1.1 V-Notch Weir Plate

The V-notched weir plate shall have a notch angle of 90 degrees and a notch depth of 12 inches. The plate shall have overall dimensions of 36 inches high and 84 inches wide.

2.1.1.1 Materials

The weir plate shall be fabricated from Type 304 stainless steel. The plate shall have a minimum thickness of 1/2 inch.

2.1.1.2 Fabrication

The V-notch shall be a machined notch with a sharp upstream edge. The dimensions for the weir plate are on the contract drawings.

2.2 ACCESSORY ITEMS

A stainless steel depth gauge, to be mounted by the Contractor, shall be supplied with the V-notch weir plate.

2.2.1 Depth Gauge

2.2.1.1 Materials

The depth gauge shall be fabricated from Type 316 Stainless Steel.

2.2.1.2 Fabrication

The gauge shall be supplied with elongated holes to allow the elevation of the gauge to be adjusted up or down 1/4 inch. Depth markings on the gauge shall be laser cut through the gauge for long term durability. The markings shall be in units of feet by 1/10th and 100th of a foot.

2.2.2 Neoprene Gasket

The neoprene gasket shall be closed cell expanded neoprene meeting the requirements of ASTM D 1056.

2.2.3 Injection Adhesive Anchors

2.2.3.1 General

Injection adhesive anchors shall be a complete system composed of injectable adhesive used for installation of threaded rods into new concrete, threaded anchor rods, nuts and washers.

2.2.3.2 Materials

Adhesive: Two component adhesive furnished in side by side packs which keep the components separate. Side by Side packs shall accept a static mixing nozzle which thoroughly blends the two components. Adhesive shall be formulated to include resin, hardener, cement and water to provide curing strength and stiffness.

Anchor Rods: 1/2 inch Type 304 or Type 316 stainless steel meeting the

requirements of ASTM F 593 (Condition CW).

Nuts and Washers: Furnish to meet the requirements of anchor rods.

PART 3 EXECUTION

3.1 INSTALLATION

3.1.1 General

V-notch weir plate shall be securely fastened to concrete weir frame as indicated on the Contract Drawings.

3.1.2 Anchorage

Injection Adhesive anchors shall be installed at each hole in weir plate. Injection adhesive anchors shall be installed in strict conformance with manufacturer's installation instructions.

3.1.3 Neoprene Gasket

Prior to installation of neoprene gasket and weir plate, surface of concrete weir frame shall be reviewed for surface irregularities which will interfere with proper seating of gasket and weir plate. Unacceptable surface conditions shall be repaired in accordance with Section 03307, Paragraph FINISHING FORMED SURFACES.

3.1.4 Depth Gauge

Depth gauge shall be installed upstream of the weir plate at a minimum distance of at least four times the depth of the weir notch. The gauge shall be set at an elevation such that the gauge zero is exactly even with the bottom of the weir's v-notch.

3.2 MEASUREMENT AND PAYMENT

There will be no measurement for the work performed in this Section. All costs in connection with the fabrication and installation of the weir plate, gauge and accessories shall be included in the Contract Lump Sum Price for Bid Item No. 12, "Metal Weir and Accessories." Payment shall include full compensation to the Contractor for all costs associated with the the fabrication and installation of the weir plate, gauge and accessories as specified in this Section.

-- End of Section --

THIS PAGE HAS BEEN LEFT INTENTIONALLY BLANK