

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO. 0003		3. EFFECTIVE DATE 25-Jul-2003	4. REQUISITION/PURCHASE REQ. NO. W25PHS-3149-0210		5. PROJECT NO.(If applicable)
6. ISSUED BY US ARMY ENGINEER DISTRICT, PHILADELPHIA CONTRACTING DIVISION WANAMAKER BLDG, 100 PENN SQ PHILADELPHIA PA 19107-3390		CODE DACW61	7. ADMINISTERED BY (If other than item 6) See Item 6		CODE
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. DACW61-03-R-0028	
			X	9B. DATED (SEE ITEM 11) 26-Jun-2003	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE			FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended.					
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required) DESIGN, CONSTRUCT, TEST AND DELIVER A CRANE BARGE					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The above numbered solicitation is amended as follows. THE DATE AND TIME SET FOR RECEIPT OF PROPOSALS REMAINS UNCHANGED. Section E: Page E-16 is deleted in its entirety and substituted therefore with attached page numbered E-16, annotated Amendment 0003. Offerors should acknowledge this amendment by returning a signed copy with their offer. Failure to acknowledge an amendment may be cause for rejection of the offer. All other information remains the same.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		25-Jul-2003	

9. Fixed Fire Extinguishing (CO₂) System

Demonstrate the proper operation of the installed CO₂ system. Tests shall be performed in accordance with the requirements of NFPA12, which includes demonstrating proper operation of the trip devices, nozzles, audible alarms and the automatic shutdown of the ventilation system fans. These tests may be done concurrently with the required ABS tests on this system. A Government representative must be present to witness the tests.

(Note: All tests shall be performed to the satisfaction of the ABS Inspector, responsible for issuing a Statement of Fact for the CO₂ system, and shall also be witnessed by the government representative.)

10. ~~Fire Detection & Alarm System~~ Not Used

~~Demonstrate the operation of the fire detection system. The testing and trials shall demonstrate activation of the alarms from each smoke detector and heat sensor. A representative of the alarm system shall be present during the test and trials of the detection and alarm system.~~

11. HVAC

- Demonstrate the operation of the air conditioning and heating equipment.
- Demonstrate the operation and measure the cfm output of all ventilation fans.

12. Compressed Air System

- Fill the air receiver from empty to automatic shut off using the compressor. Record the time to fill tank and the cut-out pressures of the compressor.
- Bleed air from the system until the respective compressor cuts in. Record the cut-in pressures.
- Demonstrate air availability at each service air connection.

13. Winches and Hoists

- Demonstrate operation of the overhead traveling shop crane, including 100% load test.
- Demonstrate operation of the spud winches.
- Demonstrate operation of the capstans.
- Demonstrate operation of the storage room monorail trolley hoist, including 100% load test.